

Affairs Canada

et du Nord Canada

INDUSTRIAL WATER USE INSPECTION REPORT

DATE: Aug. 25/05COMPANY REP.: Bryan AtkinsonLICENSEE: Communities Bay Resources Ltd.LICENCE #: NWA22CRA0507

WATER SUPPLY

Source: Crater Lake

Quantity Used: _____

Meter Rdg.: _____

Indicate:

A - Acceptable

U - Unacceptable

N/A - Not Applicable

Intake Facilities AFlow Meas. Device NAStorage Structures NAConveyance Lines UTreatment Systems NAPumping Stations NARecycling NAModifications NA

Comments:

Water use should be recorded daily. Water is not treated a spill pan & spill kit should be put on the pump at Crater Lake.

WASTE DISPOSAL

Tailings: NATailings Pond ☐Natural Lake ☐Underground ☐Sewage: burn barrelSewage Treat. System ☐Tailings Pond ☐Natural Water Body ☐Continuous Discharge ☐Inter. Dischg. ☐

Solid Waste:

Open Dump ☐Landfill ☐Burn & Bury ☐Underground ☐

Indicate:

A - Acceptable

U - Unacceptable

N/A - Not Applicable

Discharge Quality NADecant Structures NADyke Inspections NAConveyance Lines NAPond Treatment NARunoff Diversion NADisch. Meas. Dev. NADams, Dykes NAErosion NAFreeboard NASeepages NASpills NA

Effluent Discharge Rate: _____

Samples Collected: _____

Comments:

The camp should have a secondary containment crate for re-fueling at the heli-pad to prevent spills & a spill kit at the heli-pad.

Nunavut Water Board

OCT 11 2005

Public Registry

GENERAL CONDITIONS

Indicate:

A - Acceptable

U - Unacceptable

N/A - Not Applicable

Site & Waste Rock Stockpiles NAGeotechnical Inspection NARestoration Activities NAMine Water Discharge NARecords & Reporting NAPosting, Signage NANew Construction NAChemical Storage NASurv. Net. Prog. NAContingency Plan NAFuel Storage NAAnnual Report NA

Comments:

The storage tanks and the heating drums are too close to the edge of Crater Lake. The accommodations (sheds) will have to be moved by the summer of 2006. Secondary containment should be put in to the edge of Crater Lake. They need to be moved at least 30m (effective) away from the lake edge/edge of the slope.

General Comments:

place for all heating drums to prevent spills.Page 2 attached ☐ Yes ☒ No

Camp Geologist

Licensee Representative's Title

SCOTT STEWART
Inspector's Name

B. Atkinson

Licensee Representative's Signature

Scott Stewart
Inspector's Signature