

## Appendix F

### Section 12.0, 13.0 – Fuel Spill Contingency Plans and Fuel Transfer

Fuel storage will be located within a natural depression located well away (>30m) from any bodies of water at the main camp site location. This short term storage site will be monitored on a regular basis. Transferring of fuels at both camp and drill sites will be completed utilizing a wobble or electric pump with drip tray containment for open standing drums. Spill kits will be located at all sites where fuel is utilized including fuel absorbent matting.

Any spill will be reported in accordance with the instructions contained within the “Spills Report, NWT 1086 (10/79)”. Any contaminated soil will be contained and removed to an appropriate dump site facility.

Nunavut Water  
Board

AUG 13 2004

Public Registry