



ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᓂᓕᓂᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File: 2BE-EQE1926

June 1, 2020

To: Qikiqtani Distribution

Subject: NWB Water Licence Type “B” No: 2BE-EQE1926

NOTICE OF ERRATA

PART D: CONDITIONS APPLYING TO WASTE DISPOSAL

The table under Item 13 should read (updated value in bold):

Parameter	Maximum Average Concentration (mg/L)	Maximum Concentration of Any Grab Sample (mg/L)
Total Suspended Solids	50.0	100
Oil and Grease	No visible sheen	No visible sheen
pH	Between 6.5 and 9.5	Between 6.0 and 9.5

Sincerely,

Karen Kharatyan
Director of Technical Services
Nunavut Water Board