

# UPDATED SPILL CONTINGENCY PLAN

May, 2014



## Greyhound Project

Claims K01191 – K01200.....Map sheet NTS 66A/09

Lat: 64° 38' N Long: 96° 19' W



**PwP consulting**

**Geological Consultant**

To Aura Silver Resources Inc.

*57 Main Street N, Suite 206 Brampton, ON L6X 1S9*

(905) 456-5436, (fax) 456-7180 cell: (416) 705-3421

[pwpconsulting@bellnet.ca](mailto:pwpconsulting@bellnet.ca)

# Aura Silver Resources Spill Contingency Plan

## 1.0 INTRODUCTION

Aura Silver Inc. has prepared this spill contingency plan for drilling and exploration activities being undertaken on its Greyhound Project in the Whitehills Lake of Nunavut.

Company:	Aura Silver Resources Inc.
Project:	Greyhound Project, Whitehills Lake, NU
Company Address:	1128 Clapp Lane, Manotick, On. KYM 1A3
Telephone:	613-692-7704
Email:	jmcneice@bellnet.ca
Attention:	John McNeice, CFO

Effective Date of spill contingency plan: May - June, 2014

### Distribution List:

Robert Boaz	Chief Executive Officer, Aura Silver
John McNeice	Chief Financial Officer, Aura Silver
Allain Vachon	VP, Exploration for Aura Silver
Denis Vaillancourt	Field Manager (representing Agnico Eagle)

The plan will be distributed to all field contract personnel prior to commencement of field operations.

## 1.1 Purpose and Scope

The purpose of this plan is to outline response actions for potential spills of any size, including a worst case scenario for Aura Silvers exploration sites between Half Way Hills and Whitehills Lake. The plan identifies key response personnel and their roles and responsibilities in the event of a spill, as well as the equipment and other resources available to respond to a spill. It details spill response procedures that will minimize potential health and safety hazards, environmental damage, and clean-up efforts. The plan has been prepared to ensure quick access to all the information required in responding to a spill.

## 1.2 Environmental Policy

Aura Silver is committed to the concept of sustainable development and the protection of the environment and human health. The Company's environmental; health and safety policy is to:

- protect employees, the public and the environment
- comply with all applicable legislation, regulations, and authorizations
- work proactively with federal, territorial and Aboriginal governments, other relevant organizations, and the general public, on all aspects of environmental protection
- anticipate future spill control requirements and make provision for them
- keep contractors, inspectors, Land and Water Boards, appropriate governments (Aboriginal, Federal and Territorial) and the public informed of any changes at the site or with project activities.

The Environmental Policy will be presented to all staff during an on-site orientation session. The Policy includes detailed information on the Spill Contingency Plan to ensure that all employees and contractors are knowledgeable about the plan and aware of the locations of the plan on the site at the Greyhound project and in the head office in Manotick, ON. During the orientation meeting, training sessions will be scheduled to ensure contractors have an understanding of the steps to be undertaken in the event of a spill. All contractors will be shown where spill kits are stored, will be made aware of their contents and will be trained in using spill equipment and responding to spills. The Company is committed to keeping personnel up to date on the latest technologies and spill response methods.

## 1.3 Project Description

The Company is exploring for precious metals in the Greyhound area of Nunavut about 50 kilometres north of Baker Lake. The proposed work program will comprise core drilling to test geochemical, structural and airborne EM targets that occur on the Company's mineral claims. It is planned to conduct one or more test of up to 5 targets. One or more angled holes will be drilled to a depth of approximately 50-150 metres on each of the targeted sites. This will comprise drilling of between 5 to 15 holes. Core size will be NQ (approximately 4.5 cm or two inches in diameter). It is expected that this work will take about four to six weeks. If the initial phase of work is successful in delineating a mineralized intersection, a follow-up drill program may be carried out. It is possible that the follow up work could be done in the Fall of 2014 once assays have been interpreted from the spring Phase of drilling. All holes are on land-based targets. Expected time to complete the follow up work, if carried out, would be an additional 4 weeks.

Crews for the drilling will be based at the Meadowbank Mine Site about 50 kilometres north of the area of proposed drilling. Crews will be transferred daily to and from the drill sites either by road or by helicopter. **There is no field camp proposed for this phase of exploration.**

## 1.4 Site description

The drill area is located from 40-50 kilometres north of Baker Lake and centered at Lat: 64° 38' N, Long: 96° 19' W. (Map sheet NTS 66A/09). The hamlet of Baker Lake is the closest community thus the only people immediately affected by a potential spill would be contractors to the Company.

## 1.5 List of Hazardous Materials on-site

There will be one fuel storage area at each drill site at the time of drilling of that site, and will be used for storing diesel fuel for the drill, jet B and possibly propane for heating the water line. Small amounts of other petroleum products such as oils and lubricants will be stored at each drill site to aid in operations of the drill. Table 1 presents a list of hazardous materials on-site, the type of storage container, the average and maximum quantities stored and their storage location. Material Safety Data Sheets for each hazardous material are attached in the Appendices.

**Table 1: List of hazardous materials stored on-site**

Material	Storage at Drill Site	Maximum On-site	Storage Location and Uses
Diesel Fuel	1-2 drum	450-900 L (10 drums)	One fuel storage area – at drill. Fuel will be used to heat the drill shack with an oil stove
Jet B Fuel	1-3 drums	450- 1,350 L	Jet B will be stored at the in-use drill site to use for moving the drill to the next site. All empties will be brought back to the Meadowbank Mine site.
Propane	1-3, 45 kg cylinders	45 – 135 kg	Potentially used for coil stoves to heat water line for drill.
Gasoline	20 litre jerry cans	20 - 60 litres	Potentially for skidoo travel ? if work is done while the ground is frozen and snow covered

Waste oil will be stored in empty 20 litre containers at the fuel storage area at the drill, and carried out by helicopter for off-site disposal at an appropriate waste facility at the Meadowbank Mine. It is expected that production of waste petroleum products will be relatively limited.



Other hazardous materials may be on-site in very small quantities. These may include lubricants, oil and grease for maintenance of motorized equipment, drill rods, and general cleaning products for drill parts.

Motorized equipment on site includes a drill rig and associated water pumps, a portable generator and a fuel transfer hose with pump.

## **1.6 Existing Preventative Measures**

Aura Silver believes that planning for an emergency situation is imperative due to the nature of the materials stored on site as well as the remoteness of the drill sites. Along with the preventative measures outlined below, adequate training of staff and contractors will be paramount.

All hazardous materials to the site will arrive by helicopter, as needed, throughout the duration of the work. They will be unloaded by pilots, Company and/or the drill contractor and carefully moved to the designated fuel storage area at each drill site. Protective personnel gear such as steel toe boots, hard hats and safety glasses will be worn while unloading hazardous materials.

The storage areas for diesel fuel, jet B fuel, gasoline will be bermed with 100% containment and lined with a plastic liner. All containers will be inspected daily for leaks. A drill site will be continuously occupied by licensed personnel and not abandoned until completion of the hole and cleanup of the entire site. Work will occur on a 24-hour basis.

Spill kits will be located at the drill site (see Section 4.1.1 for details on spill kit contents). Appropriately sized fuel transfer hoses with pumps will be used when refueling the helicopter, to avoid any leaks/drips onto the tundra.

The drill manager will conduct daily visual inspections to check for leaks or damage to the fuel storage containers, as well as for stained or discoloured snow and soils around the fuel storage areas and adjacent motorized equipment. For example, lids and caps will be checked for tight seals. A checklist will be used to ensure no areas have been missed and results of the inspections are recorded in the company database. Regular maintenance and oil checks of all motorized equipment will be undertaken to avoid preventable leaks. All drill personnel will be highly trained in northern conditions with numerous years of experience while drilling at the Meadowbank Mine sites.

## **1.7 Additional Copies**

A copy of the Spill Contingency Plan will be kept on-site at all times. A copy is also held at the Company's main office/headquarters in Manotick, Ontario and with the Land and Water Board. Additional copies of the plan can be obtained by contacting the Company directly.

## **1.8 Process for Staff Response to Media and Public Inquiries**

The Company has established procedures for dealing with media and public inquiries. All inquiries are to be directed to the CFO at the headquarters office in Manotick. If the CFO is not available, there will be another staff member available to act in this position. If a reporter or member of the public arrives at the site unexpectedly, the official in charge of responding to their questions will be the Project Geologist/Field Manager. Prior to responding to their questions, the manager will make every effort possible to contact the CFO to discuss the situation.

The manager will always keep the CFO informed of any news or updates of potential interest to the media or general public, such that the Company is prepared to deal with inquiries any time.

If a spill has occurred and a NU Spill Report needs to be filled out, the information will be available for the public to view upon request by contacting the NU Spill Line or by viewing the Hazardous Materials Spills Database online.

## **2.0 RESPONSE ORGANIZATION**

An immediately reportable spill is defined as a release of a substance that is likely to be an imminent environmental or human health hazard or meets or exceeds the volumes outlined in the Appendices. It must be reported to the NU 24-Hour Spill Report Line. Any spills less than these quantities do not need to be reported immediately to the spill reporting line. Rather, these minor spills will be tracked and documented by the company and submitted to the appropriate authority either immediately upon request or at a pre-determined reporting interval. If there is any doubt that the quantity spilled exceeds reportable levels, the spill will be reported to the NU 24-Hour Spill Report Line.

Emergency satellite phones will be located in the drill site and to an established office at the Meadowbank Mine by the drilling contractor. In the event of a spill involving danger to human life these phones will be used to contact emergency response personnel at the Meadowbank Mine site. In addition, contractors will carry two-way radios for communication with the camp manager and other staff on site.

Following reporting of the spill to the field manager, he/she will report spills to the NU 24-Hour Spill Line as necessary. The field manager will also inform the head office for tracking spills in company databases and notify the head office in the event of media inquiries. The 24-hour emergency head office number of the Company is 613- 692-7704.

### **3.0 ACTION PLAN**

#### **3.1 Potential spill sizes and sources for each hazardous material on site**

On the following page, Table 2 provides a list of potential discharge events, with associated discharge volumes and directions, for the primary hazardous materials stored on site. The most likely discharge volume is indicated and the spill cleanup procedures will focus on spills of this quantity. A worst case scenario is also presented. Specific discharge rates are not indicated for each fuel type as these would vary from a few minutes to several hours, based on the source of leak or puncture.

Waste oil, stored in an empty 20 liter pail, could potentially leak. The quantity of waste oil would be quite limited as it will be shipped out by helicopter immediately. The risk of a spill from a waste oil pail impacting the environment is very low as the waste oil pail will be stored in at the fuel storage area close to the drill site.

#### **3.2 Potential environmental impacts of spill (including worst case scenario)**

Overall for all hazardous materials discussed below, impacts are lower during winter as snow is a natural sorbent and ice forms a barrier limiting or eliminating soil or water contamination, thus spills can be more readily recovered.

##### **3.2.1 Jet B Fuel**

Environmental impacts: Jet B fuel may be harmful to wildlife and aquatic life. It is not readily biodegradable and has the potential for bioaccumulation in the environment. Jet B fuel volatilizes relatively quickly. Runoff into water bodies must be avoided.

Worst case scenario: A fuel drum were to be punctured or opened and contents seeped into surrounding soil and through the subsoil into water bodies. This could cause illness or death to aquatic life and indirectly affect wildlife feeding from the land and water.

##### **3.2.2 Diesel Fuel**

Environmental impacts: Diesel may be harmful to wildlife and aquatic life. It is not readily biodegradable and has the potential for bioaccumulation in the environment. Diesel burns slowly and thus risk to the environment is reduced during recovery as burn can be more readily contained compared with volatile fuels. Runoff into water bodies must be avoided.

Worst case scenario: A fuel drum were punctured and contents seeped into surrounding soil and through the subsoil into water bodies. This could cause illness or death to aquatic life, indirectly affecting wildlife feeding from the land and water.

**Table 2: List of hazardous materials, potential discharge events, potential discharge volumes (worst case scenario in brackets) and direction of potential discharge**

Material (sources)	Potential Discharge Event	Discharge Volume (worst case)	Direction of Potential Discharge
<b>Diesel Fuel</b> (drill rig,)	Over pumping of fuel from drum into equipment. Leakage from drill rig/equipment. Minor leaking fuel drum in/outside fuel storage area. Large puncture, fast leaking drum in/outside fuel storage area. All drums punctured and leaking at once (very unlikely).	Likely under 200 L, one drum (maximum )	At drill site or fuel storage area near drill site on flat ground with potential underground seepage.
<b>Jet B Fuel</b> (helicopter)	Overfilling of aircraft. Leak from drum or hose while filling aircraft. Minor leaking fuel drum in or outside of fuel storage area. Large puncture, fast leaking drum in or outside of fuel storage area. All drums punctured and leaking at once (very unlikely)	Likely under 200L, one drum	At fuel storage area near drill site with potential under ground seepage.
<b>Propane</b> (water heaters for drill)	Minor leaking cylinder in or outside of fuel storage area. Large puncture, fast leaking cylinder in or outside of fuel storage area. All cylinders punctured and leaking at once (very unlikely)	Likely under 45 kg or one cylinder	No environmental danger as propane will be dispersed into the air.
<b>Gasoline</b> (portable generator)	Leak or puncture of 20 litre jerry can	Likely 20L (contents of one jerry can)	At fuel storage area near drill site with localized potential of underground seepage.

### **3.2.3 Propane**

Environmental impacts: propane may be harmful only to the immediately surrounding environment. Propane is extremely volatile and is the most flammable material stored on site, thus immediate impacts to the surrounding environment are a concern.

Worst case scenario: A cylinder were to be punctured or failed and contents leaked into the surrounding environment (air) and ignited leading to an explosion. This could have an environmental impact in the immediate surroundings. Safety during emergency response to a propane spill is of the utmost concern.

### **3.2.4 Gasoline**

Environmental impacts: gasoline may be harmful to wildlife and to aquatic life. It is not readily biodegradable and has the potential for bioaccumulation in the environment. Gasoline is quick to volatilize. Runoff into water bodies must be avoided. Worst case scenario: a 20 litre container was punctured or spilled and contents seeped into water body or soil. This could cause localized illness or death to aquatic life and indirectly affect wildlife feeding from the land and water.

## **3.3 Procedures**

### **3.3.1 Procedures for Initial Action**

- Ensure safety of all personnel.
- Assess spill hazards and risks.
- Remove all sources of ignition.
- Stop the spill if safely possible e.g. shut off pump, replace cap, tip drum upward, patch leaking hole. Use the contents of the nearest spill kit to aid in stopping the spill if it is safe to do so. Tyvek suits and chemical master gloves are located in the spill kit and will be worn immediately if there is any risk of being in contact with fuel.
- No matter what the volume is, notify field manager via two way radio.
- Contain the spill – use contents of spill kits to place sorbent materials on the spill, or use shovel to dig dike to contain spill. Methods will vary depending on the nature of the spill. See Section 3.3.3 for more details.

### **3.3.2 Procedures for spill reporting**

Report spill immediately to camp manager, who will determine if spill is to be reported to the NU 24-Hour Spill Line. (867) 920-8130 (fax) 873-6924.

Each spill kit, will have copies of the NU Spill Report form to be filled out (see Appendix B-1). Fill out and fax or email the Spill Report to the staff of the NU 24-Hour spill line. Also fax or email the report to the head office.

NU 24-Hour Spill Line Phone: (867) 920-8130, fax: (867)-873-6924

NU 24-Hour Spill Line Email: [spills@gov.nt.ca](mailto:spills@gov.nt.ca)

Aura Silver Head Office Phone: 613-692-7704, fax: (613) 692-3234

### **3.3.3 Procedures for containing and controlling spills (on land, water, snow)**

- Initiate spill containment by first determining what will be affected by the spill.
- Assess speed and direction of spill and cause of movement (water, wind and slope).
- Determine best location for containing spill, avoiding any water bodies.
- Have a contingency plan ready in case spill worsens beyond control or if the weather or topography impedes containment.

#### **1) Containment of Spills on Land**

Spills on land include spills on rock, gravel, soil and/or vegetation. It is important to note that soil is a natural sorbent, thus spills on soil are generally less serious than spills on water as contaminated soil can be more easily recovered. Generally spills on land occur during the summer or fall when snow cover is at a minimum. It is important that all measures be undertaken to avoid spills reaching open water bodies.

##### **Dykes**

Dykes can be created using soil surrounding a spill on land. These dykes are constructed around the perimeter or down slope of the spilled fuel. A dyke needs to be built up to a size that will ensure containment of the maximum quantity of fuel that may reach it. A plastic tarp can be placed on and at the base of the dyke such that fuel can pool up and subsequently be removed with sorbent materials or by pump into barrels or bags. If the spill is migrating very slowly a dyke may not be necessary and sorbents can be used to soak up fuels before they migrate away from the source of the spill.

##### **Trenches**

Trenches can be dug out to contain spills as long as the top layer of soil is thawed. Shovels and pick axes can be used depending on the size of trench required. It is recommended that the trench be dug to the bedrock or permafrost, which will then provide containment layer for the spilled fuel. Fuel can then be recovered using a pump or sorbent materials.

## **2) Containment of spills on water**

Spills on water such as rivers, streams or lakes are the most serious types of spills as they can negatively impact water quality and aquatic life. All measures need to be undertaken to contain spills on open water.

### **Booms**

Booms are commonly used to recover fuel floating on the surface of lakes or slow moving streams. They are released from the shore of a water body to create a circle around the spill. If the spill is away from the shoreline a boat may be needed to reach the spill, then the boom can be set out. More than one boom may be used at once. Booms may also be used in streams and should be set out at an angle to the current. Booms are designed to float and have sorbent materials built into them to absorb fuels at the edge of the boom. Fuel contained within the circle of the boom will need to be recovered using sorbent materials or pumps and placed into barrels or bags for disposal.

### **Weirs**

Weirs can be used to contain spills in streams and to prevent further migration downstream. Plywood or other materials found on site can be placed into and across the width of the stream, such that water can still flow under the weir. Spilled fuel will float on the water surface and be contained at the foot of the weir. It can then be removed using sorbents, booms or pumps and placed into barrels or plastic bags.

### **Barriers**

In some situations barriers made of netting or fence material can be installed across a stream, and sorbent materials placed at the base to absorb spilled fuel. Sorbents will need to be replaced as soon as they are saturated. Water will be allowed to flow through. This is very similar to the weir option discussed above.

Note that in some cases, it may be appropriate to burn fuel or to let volatile fuels such as gasoline evaporate after containment on the water surface. This will only be undertaken in consultation with, and after approval from the INAC or lead agency Inspector.

## **3) Containment of spills on ice**

Spills on ice are generally the easiest spills to contain due to the predominantly impermeable nature of the ice. For small spills, sorbent materials are used to soak up spilled fuel. Remaining contaminated ice/slush can be scraped and shoveled into a plastic bag or barrel. However, all possible attempts should be made to prevent spills from entering ice covered waters as no easy method exists for containment and recovery of spills if they seep under ice.

#### Dykes

Dykes can be used to contain fuel spills on ice. By collecting surrounding snow, compacting it and mounding it to form a dyke down slope of the spill, a barrier is created thus helping to contain the spill. If the quantity of spill is fairly large, a plastic tarp can be placed over the dyke such that the spill pools at the base of the dyke. The collected fuel can then be pumped into barrels or collected with sorbent materials.

#### Trenches

For significant spills on ice, trenches can be cut into the ice surrounding and/or down slope of the spill such that fuel is allowed to pool in the trench. It can then be removed via pump into barrels, collected with sorbent materials, or mixed with snow and shoveled into barrels or bags.

#### Burning

Burning will only be considered if other approaches are not feasible, and will only be undertaken with the permission of the INAC or lead agency Inspector.

### **4) Containment of Spills on Snow**

Snow is a natural sorbent, thus as with spills on soil, spilled fuel can be more easily recovered. Generally, small spills on snow can be easily cleaned up by raking and shovelling the contaminated snow into plastic bags or empty barrels, and storing these at an approved location.

#### Dykes

Dykes can be used to contain fuel spills on snow. By compacting snow down slope from the spill, and mounding it to form a dyke, a barrier or berm is created thus helping to contain the spill. If the quantity of spill is fairly large, a plastic tarp can be placed over the dyke such that the spill pools at the base of the dyke. The collected fuel/snow mixture can then be shovelled into barrels or bags, or collected with sorbent materials.

### **5) Worst Case Scenarios**

Dealing with spilled fuel which exceeds the freeboard of a dyke or barrier would present a possible worst case scenario for Aura Silver. To contain the overflow, a trench or collection pit would have to be created downstream of the spill to contain the overflow. Another worst case scenario would be an excessive spill on water may be difficult to contain with the booms present at the site. In this case, an emergency response mobile unit would have to be called in to deal with the spill using appropriate equipment.

#### **3.3.4 Procedures for transferring, storing and managing spill related waste**

In most cases, spill cleanups are initiated at the far end of the spill and contained moving toward the centre of the spill. Sorbent socks and pads are generally used for small spill clean



ups. A pump with attached fuel transfer hose can suction spills from leaking containers or large accumulations on land or ice, and direct these larger quantities into empty drums. Hand tools such as cans, shovels, and rakes are also very effective for small spills or hard to reach areas.

Used sorbent materials are to be placed in plastic bags for future disposal. All materials mentioned in this section are available in the spill kits located at the fuel storage areas. Following clean up, any tools or equipment used will be properly washed and decontaminated, or replaced if this is not possible.

For most of the containment procedures outlined in Section 3.3.3, spilled petroleum products and materials used for containment will be placed into empty fuel containers and sealed for proper disposal at an approved disposal facility.

### **3.3.5 Procedures for restoring affected areas**

Once a spill of reportable size has been contained, Aura Silver will consult with INAC or lead agency Inspector assigned to the file to determine the level of cleanup required. The Inspector may require a site specific study to ensure appropriate clean up levels are met. Criteria that may be considered include natural biodegradation of oil, replacement of soil and revegetation.

## **4.0 RESOURCE INVENTORY**

### **4.1 On-site resources**

Spill kits are located near the camp at the fuel storage area near the helicopter pad and at the fuel storage area at the first drill site. The contents are described below. Also, additional equipment as shown below will be kept at each of these sites.

#### **4.1.1 Contents of spill kits**

- 4 tyvek splash suits
- 4 pairs of chemical master gloves
- 10 large bags with ties for temporary use
- 2 oil only booms (5" x 10')
- 50 oil only mats (16" x 20")
- 5 sorbent socks
- 10 sorbent pads
- 2 large tarps
- 1 roll duct tape
- 1 utility knife
- 1 field notebook and pencil
- 1 rake
- 1 pick axe

3 aluminum scoop shovels  
1 instruction binder

#### **4.2 Off-site resources**

Baker Lake is within a half-hour driving distance along an all weather road to the center of the drilling area. Aura Silver will maintain helicopter support throughout the exploration program.

### **5.0 TRAINING PROGRAM**

#### **5.1 Outline**




The contractor training program was developed by Aura Silver and will be conducted and disseminated by the field manager. The following are key steps in the program:

- all individuals entering the site are required to participate in an orientation session, during this session, all locations of the spill plan and spill kits are provided on a map in hard copy
- an overview of the plan is provided by the field manager leading the orientation session
- specific training sessions, including mock spill exercises, are scheduled for individuals directly involved in handling hazardous materials to ensure they know all steps to be undertaken in handling these materials, as well as the steps involved in the event of a spill, including the proper use of spill kits
- all contractors will be required to have their basic first aid training, as well as WHMIS training for the drill crews, before working on the site
- A Level II supervisor will be on-site throughout the program and will have transport of dangerous goods training.

#### **5.2 Training Schedule and update**

A spreadsheet will be kept by the field manager indicating the training undertaken, and expiry dates of specific training (e.g. first aid).

# NT-NU Spill Report Form

  		<b>NT-NU SPILL REPORT</b> OIL, GASOLINE, CHEMICALS AND OTHER HAZARDOUS MATERIALS		<b>NT-NU 24-HOUR SPILL REPORT LINE</b> TEL: (867) 920-8130 FAX: (867) 873-6924 EMAIL: spills@gov.nt.ca	
<b>REPORT LINE USE ONLY</b>					
<b>A</b>	REPORT DATE: MONTH – DAY – YEAR		REPORT TIME		<input type="checkbox"/> ORIGINAL SPILL REPORT, OR <input type="checkbox"/> UPDATE # _____ TO THE ORIGINAL SPILL REPORT
<b>B</b>	OCCURRENCE DATE: MONTH – DAY – YEAR		OCCURRENCE TIME		
<b>C</b>	LAND USE PERMIT NUMBER (IF APPLICABLE)			WATER LICENCE NUMBER (IF APPLICABLE)	
<b>D</b>	GEOGRAPHIC PLACE NAME OR DISTANCE AND DIRECTION FROM NAMED LOCATION			REGION <input type="checkbox"/> NWT <input type="checkbox"/> NUNAVUT <input type="checkbox"/> ADJACENT JURISDICTION OR OCEAN	
<b>E</b>	LATITUDE DEGREES                      MINUTES                      SECONDS			LONGITUDE DEGREES                      MINUTES                      SECONDS	
<b>F</b>	RESPONSIBLE PARTY OR VESSEL NAME		RESPONSIBLE PARTY ADDRESS OR OFFICE LOCATION		
<b>G</b>	ANY CONTRACTOR INVOLVED		CONTRACTOR ADDRESS OR OFFICE LOCATION		
<b>H</b>	PRODUCT SPILLED		QUANTITY IN LITRES, KILOGRAMS OR CUBIC METRES	U.N. NUMBER	
	SECOND PRODUCT SPILLED (IF APPLICABLE)		QUANTITY IN LITRES, KILOGRAMS OR CUBIC METRES	U.N. NUMBER	
<b>I</b>	SPILL SOURCE		SPILL CAUSE		AREA OF CONTAMINATION IN SQUARE METRES
<b>J</b>	FACTORS AFFECTING SPILL OR RECOVERY		DESCRIBE ANY ASSISTANCE REQUIRED		HAZARDS TO PERSONS, PROPERTY OR EQUIPMENT
<b>K</b>	ADDITIONAL INFORMATION, COMMENTS, ACTIONS PROPOSED OR TAKEN TO CONTAIN, RECOVER OR DISPOSE OF SPILLED PRODUCT AND CONTAMINATED MATERIALS				
<b>L</b>	REPORTED TO SPILL LINE BY	POSITION	EMPLOYER	LOCATION CALLING FROM	TELEPHONE
<b>M</b>	ANY ALTERNATE CONTACT	POSITION	EMPLOYER	ALTERNATE CONTACT LOCATION	ALTERNATE TELEPHONE
<b>REPORT LINE USE ONLY</b>					
<b>N</b>	RECEIVED AT SPILL LINE BY	POSITION STATION OPERATOR	EMPLOYER	LOCATION CALLED YELLOWKNIFE, NT	REPORT LINE NUMBER (867) 920-8130
LEAD AGENCY <input type="checkbox"/> EC <input type="checkbox"/> CCG <input type="checkbox"/> GNWT <input type="checkbox"/> GN <input type="checkbox"/> ILA <input type="checkbox"/> INAC <input type="checkbox"/> NES <input type="checkbox"/> TC			SIGNIFICANCE <input type="checkbox"/> MINOR <input type="checkbox"/> MAJOR <input type="checkbox"/> UNKNOWN		FILE STATUS <input type="checkbox"/> OPEN <input type="checkbox"/> CLOSED
AGENCY		CONTACT NAME		CONTACT TIME	REMARKS
LEAD AGENCY					
FIRST SUPPORT AGENCY					
SECOND SUPPORT AGENCY					
THIRD SUPPORT AGENCY					

### Instructions for Completing the NT-NU Spill Report Form

This form can be filled out electronically and faxed to the spill line at 867-873-6924. Commencing on January 2, 2007, the form can also be e-mailed as an attachment to [spills@gov.nt.ca](mailto:spills@gov.nt.ca). Until further notice, please verify receipt of e-mail transmissions with a follow-up telephone call. Spills can still be phoned in by calling collect at 867-920-8130.

<b>A. Report Date/Time</b>	The actual date and time that the spill was reported to the spill line. If the spill is phoned in, the Spill Line will fill this out. <b>Please do not fill in the Report Number;</b> the spill line will assign a number after the spill is reported.
<b>B. Occurrence Date/Time</b>	Indicate, to the best of your knowledge, the exact date and time that the spill occurred. Not to be confused with the report date and time (see above).
<b>C. Land Use Permit Number /Water Licence Number</b>	This only needs to be filled in if the activity has been licenced by the Nunavut Water Board and/or if a Land Use Permit has been issued. Applies primarily to mines and mineral exploration sites.
<b>D. Geographic Place Name</b>	In most cases, this will be the name of the city or town in which the spill occurred. For remote locations – outside of human habitations – identify the most prominent geographic feature, such as a lake or mountain and/or the distance and direction from the nearest population center. <b>You must include the geographic coordinates</b> (Refer to Section E).
<b>E. Geographic Coordinates</b>	This only needs to be filled out if the spill occurred outside of an established community such as a mine site. Please note that the location should be stated in degrees, minutes and seconds of Latitude and Longitude.
<b>F. Responsible Party Or Vessel Name</b>	This is the person who was in management/control/ownership of the substance at the time that it was spilled. In the case of a spill from a ship/vessel, include the name of the ship/vessel. Please include full address, telephone number and e-mail. Use box K if there is insufficient space. <b>Please note that, the owner of the spilled substance is ultimately responsible for any spills of that substance, regardless of who may have actually caused the spill.</b>
<b>G. Contractor involved?</b>	Were there any other parties/contractors involved? An example would be a construction company who is undertaking work on behalf of the owner of the spilled substance and who may have contributed to, or directly caused the spill and/or is responding to the spill.
<b>H. Product Spilled</b>	Identify the product spilled; most commonly, it is gasoline, diesel fuel or sewage. For other substances, avoid trade names. Wherever possible, use the chemical name of the substance and further, identify the product using the four digit UN number (eg: UN1203 for gasoline; UN1202 for diesel fuel; UN1863 for Jet A & B)
<b>I. Spill Source</b>	Identify the source of the spill: truck, ship, home heating fuel tank and, if known, the cause (eg: fuel tank overflow, leaking tank; ship ran aground; traffic accident, vandalism, storm, etc.). Provide an estimate of the extent of the contaminated/impacted area (eg: 10 m <sup>2</sup> )
<b>J. Factors Affecting Spill</b>	Any factors which might make it difficult to clean up the spill: rough terrain, bad weather, remote location, lack of equipment. Do you require advice and/or assistance with the cleanup operation? Identify any hazards to persons, property or equipment: for example, a gasoline spill beside a daycare centre would pose a safety hazard to children. Use box K if there is insufficient space.
<b>K. Additional Information</b>	Provide any additional, pertinent details about the spill, such as any peculiar/unique hazards associated with the spilled material. State what action is being taken towards cleaning up the spill; disposal of spilled material; notification of affected parties. If necessary, append additional sheets to the spill report. Number the pages in the same format found in the lower right hand corner of the spill form: eg, "Page 1 of 2", "Page 2 of 2" etc. <b>Please number the pages to ensure that recipients can be certain that they received all pertinent documents.</b> If only the spill report form was filled out, number the form as "Page 1 of 1".
<b>L. Reported to Spill Line by</b>	Include your full name, employer, contact number and the location from which you are reporting the spill. Use box K if there is insufficient space.
<b>M. Alternate Contact</b>	Identify any alternate contacts. This information assists regulatory agencies to obtain additional information if they cannot reach the individual who reported the spill.
<b>N. Report Line Use Only</b>	<b>Leave Blank.</b> This box is for the <b>Spill Line's use only.</b>








## Immediately Reportable Spill Quantities

TDG Class	Substance for NWT 24 Hour Spill Line	Immediately Reportable Quantities
1 2.3 2.4 6.2 7 None	Explosives Compressed gas (toxic) Compressed gas (corrosive) Infectious substances Radioactive Unknown substance	Any amount
2.1 2.2	Compressed gas (flammable) Compressed gas (non-corrosive, non-flammable)	Any amount of gas from containers with a capacity greater than 100 L
3.1 3.2 3.3	Flammable liquids	> 100 L
4.1 4.2 4.3	Flammable solids Spontaneously combustible solids Water reactant	> 25 kg
5.1 9.1	Oxidizing substances Miscellaneous products or substances excluding PCB mixtures	> 50 L or 50 kg
5.2 9.2	Organic peroxides Environmentally hazardous	> 1 L or 1 kg
6.1 8 9.3	Poisonous substances Corrosive substances Dangerous wastes	> 5 L or 5 kg
9.1	PCB mixtures of 5 or more ppm	> 0.5 L or 0.5 kg
None	Other contaminants (e.g. crude oil, drilling fluid, produced water, waste or spent chemicals, used or waste oil, vehicle fluids, waste water, etc.)	> 100 L or 100 kg
None	Sour natural gas (i.e. contains H <sub>2</sub> S) Sweet natural gas	Uncontrolled release or sustained flow of 10 minutes or more

# Material Safety Data Sheets (MSDS) for hazardous materials stored on site



## Material Safety Data Sheet

WHMIS (Pictograms)	WHMIS (Classification)	Protective Clothing	TDG (pictograms)
 	B-3, D-2B	   	

### Section 1. Chemical Product and Company Identification

<b>Product Name</b>	<b>DIESEL FUEL</b>	<b>Code</b>	W104, W293; SAP: 120, 121, 122, 287
<b>Synonym</b>	Seasonal Diesel, #1 Diesel, #2 Heating Oil, #1 Heating Oil, D50, P50, Arctic Diesel, Farm Diesel, Marine Diesel, Low Sulphur Diesel, LSD, Ultra Low Sulphur Diesel, ULSD, Mining Diesel, Naval Distillate, Dyed Diesel, Marked Diesel, Coloured Diesel	<b>Validated on</b>	2/5/2007.
<b>Manufacturer</b>	PETRO-CANADA P.O. Box 2844 150 – 6th Avenue South-West Calgary, Alberta T2P 3E3	<b>In case of Emergency</b>	Petro-Canada: 403-296-3000 Canutec Transportation: 613-996-6666 Poison Control Centre: Consult local telephone directory for emergency number(s).
<b>Material Uses</b>	Diesel fuels are distillate fuels suitable for use in high and medium speed internal combustion engines of the compression ignition type. Mining Diesel has a higher flash point requirement, for safe use in underground mines.		

### Section 2. Composition and Information on Ingredients

		Exposure Limits (ACGIH)			
Name	CAS #	% (V/V)	TLV-TWA(8 h)	STEL	CEILING
Distillates (petroleum), hydrodesulfurized middle	64742-80-9	100	Not established	Not established	Not established
Kerosine (petroleum), hydrodesulfurized	64742-81-0		200 mg/m <sup>3</sup>	Not established	Not established
Fuels, diesel	68334-30-5		100 mg/m <sup>3</sup>	Not established	Not established
Fuel oil no. 2	68476-30-2		100 mg/m <sup>3</sup>	Not established	Not established
<b>Manufacturer Recommendation</b>	Avoid prolonged or repeated skin contact to diesel fuels which can lead to dermal irritation and may be associated with an increased risk of skin cancer.				
<b>Other Exposure Limits</b>	Consult local, state, provincial or territory authorities for acceptable exposure limits.				

### Section 3. Hazards Identification

<b>Potential Health Effects</b>	Combustible liquid. Exercise caution when handling this material. Contact with this product may cause skin and eye irritation. Prolonged or repeated contact may cause skin irritation, defatting, drying and dermatitis. Inhalation of this product may cause respiratory tract irritation and Central Nervous System (CNS) Depression, symptoms of which may include; weakness, dizziness, slurred speech, drowsiness, unconsciousness and in cases of severe overexposure; coma and death. Ingestion of this product may cause gastro-intestinal irritation. Aspiration of this product may result in severe irritation or burns to the respiratory tract. For more information refer to Section 11 of this MSDS.
---------------------------------	--

### Section 4. First Aid Measures

<b>Eye Contact</b>	Avoid direct contact. Quickly and gently blot or brush away chemical. Immediately flush the contaminated eye(s) with lukewarm, gently flowing water for 15-20 minutes or until the chemical is removed, while holding the eyelid(s) open. Take care not to rinse contaminated water into the unaffected eye or onto the face. Obtain medical attention immediately.
<b>Skin Contact</b>	Avoid direct contact. Wear chemical resistant protective clothing if necessary. Quickly and gently, blot or brush away excess chemical. Wash gently and thoroughly with warm water and non-abrasive soap for 15-20 minutes or until chemical is removed. Under running water, remove contaminated clothing, shoes and leather goods (e.g., watch bands, belts, etc.). Obtain medical attention immediately. Completely decontaminate clothing, shoes and leather goods before reuse or discard.
<b>Inhalation</b>	Take proper precautions to ensure your own safety before attempting rescue (e.g. wear appropriate protective equipment). If breathing has stopped, trained personnel should begin artificial respiration (AR) or, if the heart has stopped, cardiopulmonary resuscitation (CPR) immediately. Immediately transport victim to an emergency care facility.

Continued on Next Page

Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Available in French



<b>DIESEL FUEL</b>		<b>Page Number: 2</b>
<b>Ingestion</b>	NEVER give anything by mouth if victim is rapidly losing consciousness, or is unconscious or convulsing. Have victim rinse mouth thoroughly with water. DO NOT INDUCE VOMITING. Have victim drink 240 to 300 mL (8 to 10 oz) of water to dilute material in stomach. If vomiting occurs naturally, have victim lean forward to reduce risk of aspiration. Repeat administration of water. If breathing has stopped, trained personnel should begin artificial respiration (AR) or, if the heart has stopped, cardiopulmonary resuscitation (CPR) immediately. Quickly transport victim to an emergency care facility.	
<b>Note to Physician</b>	Not available.	

<b>Section 5. Fire-fighting Measures</b>			
<b>Flammability</b>	Combustible liquid.	<b>Flammable Limits</b>	Lower: 0.7% Upper: 6%
<b>Flash Points</b>	Diesel Fuel: Closed Cup: $\geq 45^{\circ}\text{C}$ (113°F) Marine Diesel Fuel: Closed Cup: $\geq 64^{\circ}\text{C}$ (147°F) Mining Diesel: Closed Cup: $\geq 52^{\circ}\text{C}$ (126°F)	<b>Auto-Ignition Temperature</b>	225°C (437°F)
<b>Fire Hazards in Presence of Various Substances</b>	Flammable in presence of open flames, sparks, and heat. Vapours are heavier than air and may travel considerable distance to sources of ignition and flash back. This product can accumulate static charge and ignite.	<b>Explosion Hazards in Presence of Various Substances</b>	Containers may explode in heat of fire. Do not cut, weld, heat, drill or pressurize empty container. Runoff to sewer may create fire or explosion hazard.
<b>Products of Combustion</b>	Carbon oxides (CO, CO <sub>2</sub> ), nitrogen oxides (NO <sub>x</sub> ), sulphur oxides (SO <sub>x</sub> ), sulphur compounds (H <sub>2</sub> S), smoke and irritating vapours as products of incomplete combustion. See Section 11 (Other Considerations) for information regarding the toxicity of the combustion products.		
<b>Fire Fighting Media and Instructions</b>	<p>NAERG2004, GUIDE 128, Flammable liquids (Non-polar/Water-immiscible). CAUTION: This product has a moderate flash point above 40°C: Use of water spray when fighting fire may be inefficient.</p> <p>If tank, rail car or tank truck is involved in a fire, ISOLATE for 800 meters (1/2 mile) in all directions; also consider initial evacuation for 800 meters (1/2 mile) in all directions.</p> <p>SMALL FIRES: Dry chemical, CO<sub>2</sub>, water spray or regular foam. LARGE FIRES: Water spray, fog or regular foam. Do not use straight streams. Move containers from fire area if you can do it without risk. Fires Involving Tanks or Car/Trailer Loads: Fight fire from maximum distance or use unmanned hose holders or monitor nozzles.</p> <p>Cool containers with flooding quantities of water until well after fire is out. Withdraw immediately in case of rising sound from venting devices or any discolouration of tank. ALWAYS stay away from the ends of tanks. For massive fire, use unmanned hose holders or monitor nozzles; if this is impossible withdraw from area and let fire burn. Wear positive pressure self-contained breathing apparatus (SCBA). Structural firefighters' protective clothing will only provide limited protection.</p>		

<b>Section 6. Accidental Release Measures</b>	
<b>Material Release or Spill</b>	Consult current National Emergency Response Guide Book (NAERG) for appropriate spill measures if necessary. IN THE EVENT OF A LARGE SPILL CONSIDER THE FOLLOWING CONTROL MEASURES: Extinguish all ignition sources. Evacuate non-essential personnel. Ventilate area. Stop leak if safe to do so. Dike spilled material. Use appropriate inert absorbent material to absorb spilled product. Collect used absorbent for later disposal. Ground and bond all equipment used to clean up the spilled material, as it may be a static accumulator. Avoid contact with spilled material. Avoid breathing vapours or mists of material. Avoid contaminating sewers, streams, rivers and other water courses with spilled material. Notify appropriate authorities immediately. Ensure clean-up personnel wear appropriate personal protective equipment.

<b>Section 7. Handling and Storage</b>	
<b>Handling</b>	COMBUSTIBLE MATERIAL. Handle with care. Avoid contact with any sources of ignition, flames, heat, and sparks. Ensure all equipment is grounded/bonded. Avoid skin contact. Avoid eye contact. Avoid inhalation of product vapours or mists. Wear proper personal protective equipment (See Section 8). Avoid confined spaces and areas with poor ventilation. Empty containers may contain product residue. Do not pressurize, cut, heat, or weld empty containers. Do not reuse containers without commercial cleaning and/or reconditioning. Personnel who handle this material should practice good personal hygiene during and after handling to help prevent accidental ingestion of this product. Properly dispose of contaminated leather articles including shoes that cannot be decontaminated.
<b>Storage</b>	Store away from heat and sources of ignition. Store in dry, cool, well-ventilated area. Store away from incompatible and reactive materials (See section 5 and 10). Ensure the storage containers are grounded/bonded.

<i>Continued on Next Page</i>	<i>Internet: <a href="http://www.petro-canada.ca/msds">www.petro-canada.ca/msds</a></i>	<i>Available in French</i>
-------------------------------	---	----------------------------

**Section 8. Exposure Controls/Personal Protection**

**Engineering Controls** For normal application, special ventilation is not necessary. If user's operations generate vapours or mist, use ventilation to keep exposure to airborne contaminants below the exposure limit. Make-up air should always be supplied to balance air removed by exhaust ventilation. Ensure that eyewash station and safety shower are close to work-station.

**Personal Protection** - *The selection of personal protective equipment varies, depending upon conditions of use.*

**Eyes** As a minimum, safety glasses with side shields should be worn when handling this material. If product is used in an application where splashing may occur, the use of safety goggles and/or a face shield should be considered.

**Body** If this material may come in contact with the body during handling and use, we recommend wearing appropriate protective clothing to prevent contact with the skin. (Contact your PPE provider for more information.)

**Respiratory** A NIOSH-approved air-purifying respirator with an organic vapour cartridge or canister may be permissible under certain circumstances where airborne concentrations are expected to exceed exposure limits. Protection provided by air-purifying respirators is limited. Use a positive-pressure, air-supplied respirator if there is any potential for uncontrolled release, exposure levels are unknown, or any other circumstances where air-purifying respirators may not provide adequate protection.

**Hands** If this material may come in contact with the hands during handling and use, we recommend wearing gloves of the following material(s): nitrile, neoprene, polyvinyl alcohol (PVA), fluoro-elastomer. Consult your PPE provider for breakthrough times and the specific glove that is best for you based on your use patterns. It should be realized that eventually any material regardless of their imperviousness, will get permeated by chemicals. Therefore, protective gloves should be regularly checked for wear and tear. At the first signs of hardening and cracks, they should be changed.

**Feet** Wear appropriate footwear to prevent product from coming in contact with feet and skin.

**Section 9. Physical and Chemical Properties**

<b>Physical State and Appearance</b>	Bright oily liquid.	<b>Viscosity</b>	1.3 - 4.4 cSt @ 40°C (104°F)
<b>Colour</b>	Clear to yellow / brown (may be dyed for taxation purposes).	<b>Pour Point</b>	Not available.
<b>Odour</b>	Mild petroleum oil like.	<b>Softening Point</b>	Not available.
<b>Odour Threshold</b>	Not available.	<b>Dropping Point</b>	Not available.
<b>Boiling Point</b>	150 to 371°C (302 to 699.8°F)	<b>Penetration</b>	Not available.
<b>Density</b>	0.8 to 0.88 kg/L @ 15°C (59°F)	<b>Oil / Water Dist. Coefficient</b>	Not available.
<b>Vapour Density</b>	4.5 [Air = 1]	<b>Ionicity (in water)</b>	Not available.
<b>Vapour Pressure</b>	1 kPa (7.5 mm Hg) @ 20°C (68°F)	<b>Dispersion Properties</b>	Not available.
<b>Volatility</b>	Semivolatile to volatile.	<b>Solubility</b>	Insoluble in cold water, soluble in non-polar hydrocarbon solvents.

**Section 10. Stability and Reactivity**

<b>Corrosivity</b>	Not available.		
<b>Stability</b>	The product is stable under normal handling and storage conditions.	<b>Hazardous Polymerization</b>	Will not occur under normal working conditions.
<b>Incompatible Substances / Conditions to Avoid</b>	Reactive with oxidizing agents and acids.	<b>Decomposition Products</b>	May release COx, NOx, SOx, H2S, smoke and irritating vapours when heated to decomposition.

**Section 11. Toxicological Information**

<b>Routes of Entry</b>	Skin contact, eye contact, inhalation and ingestion.
<b>Acute Lethality</b>	<p>Acute toxicity information is not available for the product as a whole, therefore, data for some of the ingredients is provided below:</p> <p><b><u>Distillates (petroleum), hydrosulfurized middle (64742-80-9):</u></b>            Acute Inhalation toxicity (LC50): 4600 mg/m<sup>3</sup>/4h (rat)</p> <p><b><u>Kerosine (petroleum), hydrosulfurized (64742-81-0):</u></b>            Acute Oral toxicity (LD50): &gt;5000 mg/kg (rat)            Acute Dermal toxicity (LD50): &gt;2000 mg/kg (rabbit)            Acute Inhalation toxicity (LC50): &gt;5000 mg/m<sup>3</sup>/4h (rat)</p> <p><b><u>Fuels, diesel (68334-30-5):</u></b>            Acute Oral toxicity (LD50): 7500 mg/kg (rat)            Acute Dermal toxicity (LD50): 24500 mg/kg (mouse)</p>

Continued on Next Page

Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Available in French



DIESEL FUEL		Page Number: 4
<b>Fuel oil no. 2 (68476-30-2):</b> Acute Oral toxicity (LD50): 12000 mg/kg (rat)		
<b>Chronic or Other Toxic Effects</b>		
Dermal Route:	This product contains a component (at >= 1%) that can cause skin irritation. Therefore, this product is considered to be a skin irritant. Prolonged or repeated contact may defat and dry skin, and cause dermatitis. (See Other Considerations)	
Inhalation Route:	Inhalation of this product may cause respiratory tract irritation. Inhalation of this product may cause Central Nervous System (CNS) Depression, symptoms of which may include; weakness, dizziness, slurred speech, drowsiness, unconsciousness and in cases of severe overexposure; coma and death.	
Oral Route:	Ingestion of this product may cause gastro-intestinal irritation. Aspiration of this product may result in severe irritation or burns to the respiratory tract. Ingestion of this product may cause Central Nervous System (CNS) Depression, symptoms of which may include; weakness, dizziness, slurred speech, drowsiness, unconsciousness and in cases of severe overexposure; coma and death.	
Eye Irritation/Inflammation:	Short-term exposure is expected to cause only slight irritation, if any.	
Immunotoxicity:	Not available.	
Skin Sensitization:	Contact with this product is not expected to cause skin sensitization, based upon the available data and the known hazards of the components.	
Respiratory Tract Sensitization:	Contact with this product is not expected to cause respiratory tract sensitization, based upon the available data and the known hazards of the components.	
Mutagenic:	This product is not known to contain any components at >= 0.1% that have been shown to cause mutagenicity. Therefore, based upon the available data and the known hazards of the components this product is not expected to be a mutagen.	
Reproductive Toxicity:	This product is not known to contain any components at >= 0.1% that have been shown to cause reproductive toxicity. Therefore, based upon the available data and the known hazards of the components, this product is not expected to be a reproductive toxin.	
Teratogenicity/Embryotoxicity:	This product is not known to contain any components at >= 0.1% that have been shown to cause teratogenicity and/or embryotoxicity. Therefore, based upon the available data and the known hazards of the components, this product is not expected to be a teratogen/embryotoxin.	
Carcinogenicity (ACGIH):	Considered to be A3 by the ACGIH (Kerosine (petroleum), hydrodesulfurized; Fuels, diesel; Fuel oil no. 2) (See Other Considerations)	
Carcinogenicity (IARC):	This product is not known to contain any chemicals at reportable quantities that are listed as group 1, 2A or 2B carcinogens by IARC.	
Carcinogenicity (NTP):	This product is not known to contain any chemicals at reportable quantities that are listed as carcinogens by NTP.	
Carcinogenicity (IRIS):	This product is not known to contain any chemicals at reportable quantities that are listed as carcinogens by IRIS.	
Carcinogenicity (OSHA):	This product is not known to contain any chemicals at reportable quantities that are listed as carcinogens by OSHA.	
Other Considerations	Avoid prolonged or repeated skin contact to diesel fuels which can lead to dermal irritation and may be associated with an increased risk of skin cancer. Diesel engine exhaust particulate is probably carcinogenic to humans (IARC Group 2A).	








Section 12. Ecological Information			
<b>Environmental Fate</b>	Not available.	<b>Persistence/Bioaccumulation Potential</b>	Not available.
<b>BOD5 and COD</b>	Not available.	<b>Products of Biodegradation</b>	Not available.
<b>Additional Remarks</b> No additional remark.			

DIESEL FUEL		Page Number: 5	
Section 13. Disposal Considerations			
Waste Disposal	Spent/ used/ waste product may meet the requirements of a hazardous waste. Consult your local or regional authorities. Ensure that waste management processes are in compliance with government requirements and local disposal regulations.		
Section 14. Transport Information			
TDG Classification	DIESEL FUEL, 3, UN1202, PGIII (CL-TDG)	Special Provisions for Transport	See Transportation of Dangerous Goods Regulations.
Section 15. Regulatory Information			
Other Regulations	This product is acceptable for use under the provisions of WHMIS-CPR. All components of this formulation are listed on the CEPA-DSL (Domestic Substances List).  All components of this formulation are listed on the US EPA-TSCA Inventory.  All components of this product are on the European Inventory of Existing Commercial Chemical Substances (EINECS).  This product has been classified in accordance with the hazard criteria of the Controlled Products Regulations (CPR) and the MSDS contains all of the information required by the CPR.  Please contact Product Safety for more information.		
DSD/DPD (Europe)	Not evaluated.	HCS (U.S.A.)	CLASS: Irritating substance. CLASS: Target organ effects. CLASS: Combustible liquid having a flash point between 37.8°C (100°F) and 93.3°C (200°F).
ADR (Europe) (Pictograms)	NOT EVALUATED FOR EUROPEAN TRANSPORT NON ÉVALUÉ POUR LE TRANSPORT EUROPÉEN.	DOT (U.S.A.) (Pictograms)	Not evaluated for transport Non évalué pour le transport
HMIS (U.S.A.)	Health Hazard 2* Fire Hazard 2 Reactivity 0 Personal Protection H	NFPA (U.S.A.) Health 2 Fire Hazard 2 Reactivity 0 Specific hazard	Rating 0 Insignificant 1 Slight 2 Moderate 3 High 4 Extreme
Section 16. Other Information			
References	Available upon request. * Marque de commerce de Petro-Canada - Trademark		
Glossary	ACGIH - American Conference of Governmental Industrial Hygienists ADR - Agreement on Dangerous goods by Road (Europe) ASTM - American Society for Testing and Materials BOD5 - Biological Oxygen Demand in 5 days CAS - Chemical Abstract Services CEPA - Canadian Environmental Protection Act CERCLA - Comprehensive Environmental Response, Compensation and Liability Act CFR - Code of Federal Regulations CHIP - Chemical Hazard Information and Packaging Approved Supply List  COD - Chemical Oxygen Demand CPR - Controlled Products Regulations DOT - Department of Transportation (U.S.A.) DSCl - Dangerous Substances Classification and Labeling (Europe) DSD/DPD - Dangerous Substance or Dangerous Preparations Directives (Europe) DSL - Domestic Substance List (Canada) EEC/EU - European Economic Community/European Union EINECS - European Inventory of Existing Commercial Chemical Substances EPCRA - Emergency Planning And Community Right-To-Know Act FDA - Food and Drug Administration FIFRA - Federal Insecticide, Fungicide, and Rodenticide Act  HCS - Hazardous Communication System HMIS - Hazardous Material Information System IARC - International Agency for Research on Cancer IRIS - Integrated Risk Information System LD50/LC50 - Lethal Dose/Concentration kill 50% LDLo/LCLo - Lowest Published Lethal Dose/Concentration NFPA - National Fire Prevention Association NIOSH - National Institute for Occupational Safety & Health NPRI - National Pollutant Release Inventory NSNR - New Substances Notification Regulations (Canada) NTP - National Toxicology Program OSHA - Occupational Safety & Health Administration PEL - Permissible Exposure Limit RCRA - Resource Conservation and Recovery Act SARA - Superfund Amendments and Reorganization Act STEL - Short Term Exposure Limit (15 minutes) TDG - Transportation Dangerous Goods (Canada) TDLo/TCLo - Lowest Published Toxic Dose/Concentration TLV-TWA - Threshold Limit Value-Time Weighted Average TLm - Median Tolerance Limit TSCA - Toxic Substances Control Act USEPA - United States Environmental Protection Agency USP - United States Pharmacopoeia WHMIS - Workplace Hazardous Material Information System		
For Copy of MSDS	Prepared by Product Safety - JDW on 2/5/2007.		
Continued on Next Page		Internet: www.petro-canada.ca/msds	
		Available in French	

<b>DIESEL FUEL</b>		<b>Page Number: 6</b>
<b>Internet: <a href="http://www.petro-canada.ca/msds">www.petro-canada.ca/msds</a></b> <b>Canada-wide: telephone: 1-800-668-0220; fax: 1-800-837-1228</b> <b>For Product Safety Information: (905) 804-4752</b>		Data entry by Product Safety - JDW.
<i>To the best of our knowledge, the information contained herein is accurate. However, neither the above named supplier nor any of its subsidiaries assumes any liability whatsoever for the accuracy or completeness of the information contained herein. Final determination of suitability of any material is the sole responsibility of the user. All materials may present unknown hazards and should be used with caution. Although certain hazards are described herein, we cannot guarantee that these are the only hazards that exist.</i>		



## Material Safety Data Sheet

WHMIS (Pictograms)	WHMIS (Classification)	Protective Clothing	TDG (pictograms)
 	<b>B-2, D-2A, D-2B</b>	   	

Section 1. Chemical Product and Company Identification			
Product Name	<b>JET B AVIATION TURBINE FUEL</b>		Code W219 SAP: 150, 151, 152
Synonym	Jet B; Jet B DI; JP-4; Jet F-40; NATO F-40; Turbine Fuel, Aviation, Wide Cut Type (Can/CGSB-3.22).		Validated on 9/28/2007.
Manufacturer	PETRO-CANADA P.O. Box 2844 150 – 6th Avenue South-West Calgary, Alberta T2P 3E3		In case of Emergency Petro-Canada: 403-296-3000 Canutec Transportation: 613-996-6666 Poison Control Centre: Consult local telephone directory for emergency number(s).
Material Uses	Used as aviation turbine fuel. May contain a fuel system icing inhibitor.		

Section 2. Composition and Information on Ingredients					
Name	CAS #	% (W/W)	Exposure Limits (ACGIH)		
			TLV-TWA(8 h)	STEL	CEILING
Complex mixture of petroleum hydrocarbons (C6-C14).	64741-41-9	60-100	Not established	Not established	Not established
Benzene	71-43-2	0.1-0.5	0.5 ppm	2.5 ppm	Not established
Fuel System Icing Inhibitor (FSII) (if added*): Diethylene Glycol Monomethyl Ether	111-77-3	0.1-0.15	Not established	Not established	Not established
Anti-static, antioxidant, corrosion inhibitor and metal deactivator additives. * Please note that Jet B DI, JP-4, Jet F-40 and NATO F-40 all contain Fuel System Icing Inhibitor (FSII).corrosion inhibitor	Not applicable	<0.1	Not applicable	Not applicable	Not applicable
Manufacturer Recommendation	Not applicable				
Other Exposure Limits	Consult local, state, provincial or territory authorities for acceptable exposure limits.				

Section 3. Hazards Identification.	
Potential Health Effects	Flammable liquid. Exercise caution when handling this material. May cause cancer. May cause teratogenicity/embryotoxicity. Contact with this product may cause skin irritation. Inhalation of vapours can cause irritation of the respiratory tract and CNS depression with symptoms of nausea, headaches, vomiting, dizziness, fatigue, light-headedness, reduced coordination, unconsciousness and possibly death. Aspiration into the lungs may produce potentially fatal chemical pneumonitis (fluid in the lungs), severe lung damage, or respiratory failure. For more information refer to Section 11 of this MSDS.

Section 4. First Aid Measures	
Eye Contact	Avoid direct contact. Quickly and gently blot or brush chemical off the face. Immediately flush the contaminated eye(s) with lukewarm, gently flowing water for 15-20 minutes, while holding the eyelid(s) open. If a contact lens is present, DO NOT delay irrigation or attempt to remove the lens. Take care not to rinse contaminated water into the unaffected eye or onto the face. Immediately obtain medical attention.
Skin Contact	As quickly as possible, remove contaminated clothing, shoes and leather goods (e.g., watchbands, belts, etc.). Avoid direct contact. Wear chemical protective clothing if necessary. Quickly and gently, blot or brush away excess chemical. Immediately wash with lukewarm, gently flowing water and non-abrasive soap for 15-20 minutes. Immediately obtain medical attention. Completely decontaminate clothing, shoes and leather goods before reuse or discard.
Inhalation	Take proper precautions to ensure your own safety before attempting rescue (e.g. wear appropriate protective equipment). If breathing has stopped, trained personnel should begin artificial respiration (AR) or, if the heart has stopped, immediately start cardiopulmonary resuscitation (CPR) or automated external defibrillation (AED). Quickly transport victim to an emergency care facility.

Continued on Next Page

Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Available in French

JET B AVIATION TURBINE FUEL		Page Number: 2
<b>Ingestion</b>	NEVER give anything by mouth if victim is rapidly losing consciousness, or is unconscious or convulsing. Have victim rinse mouth thoroughly with water. DO NOT INDUCE VOMITING. Have victim drink 240 to 300 mL (8 to 10 oz) of water to dilute material in stomach. If vomiting occurs naturally, have victim lean forward to reduce risk of aspiration. Repeat administration of water. Have victim rinse mouth with water again. If breathing has stopped, trained personnel should begin artificial respiration (AR) or, if the heart has stopped, immediately start cardiopulmonary resuscitation (CPR) or automated external defibrillation (AED). Quickly transport victim to an emergency care facility.	
<b>Note to Physician</b>	Not available	

Section 5. Fire-fighting Measures			
<b>Flammability</b>	Flammable liquid (NFPA).	<b>Flammable Limits</b>	LOWER: 1.3% UPPER: 8% (NFPA)
<b>Flash Points</b>	CLOSED CUP: -31°C (-24°F) (NFPA)	<b>Auto-Ignition Temperature</b>	240°C (464°F) (NFPA)
<b>Fire Hazards in Presence of Various Substances</b>	Flammable in presence of open flames, sparks, and heat. Vapours are heavier than air and may travel considerable distance to sources of ignition and flash back. This product can accumulate static charge and ignite. May accumulate in confined spaces.		
<b>Products of Combustion</b>	Carbon oxides (CO, CO <sub>2</sub> ), nitrogen oxides (NO <sub>x</sub> ), sulphur oxides (SO <sub>x</sub> ), aldehydes, ketones, smoke and irritating vapours as products of incomplete combustion.		
<b>Fire Fighting Media and Instructions</b>	<p>NAERG2004, GUIDE 128, Flammable liquids (Non-polar/Water-immiscible). CAUTION: This product has a very low flash point: Use of water spray when fighting fire may be inefficient.</p> <p>If tank, rail car or tank truck is involved in a fire, ISOLATE for 800 meters (1/2 mile) in all directions; also consider initial evacuation for 800 meters (1/2 mile) in all directions.</p> <p>SMALL FIRES: Dry chemical, CO<sub>2</sub>, water spray or regular foam. LARGE FIRES: Water spray, fog or regular foam. Do not use straight streams. Move containers from fire area if you can do it without risk. Fires Involving Tanks or Car/Trailer Loads: Fight fire from maximum distance or use unmanned hose holders or monitor nozzles.</p> <p>Cool containers with flooding quantities of water until well after fire is out. Withdraw immediately in case of rising sound from venting devices or any discolouration of tank. ALWAYS stay away from the ends of tanks. For massive fire, use unmanned hose holders or monitor nozzles; if this is impossible withdraw from area and let fire burn. Wear positive pressure self-contained breathing apparatus (SCBA). Structural firefighters' protective clothing will only provide limited protection.</p>		

Section 6. Accidental Release Measures	
<b>Material Release or Spill</b>	IN THE EVENT OF A LARGE SPILL CONSIDER THE FOLLOWING CONTROL MEASURES: Consult current National Emergency Response Guide Book (NAERG) for appropriate spill measures if necessary. Evacuate non-essential personnel. Extinguish all ignition sources. Ventilate area. Avoid breathing vapours or mists of material. Stop leak if safe to do so. Dike spilled material. Avoid contact with spilled material. Do not allow spilled material to enter sewer systems as vapours may accumulate and may cause an explosion/fire hazard. If spilled in a confined space, ensure appropriate confined space entry protocols are followed. Ensure clean-up personnel wear appropriate personal protective equipment. Use appropriate inert absorbent material to absorb spilled product. Do not use paper or other flammable materials to absorb product. Collect used absorbent for later disposal. Do not allow spilled materials to come into contact with incompatible materials (see Section 10). Ground and bond all equipment used to clean up the spilled material, as it may be a static accumulator. Notify appropriate authorities immediately.

Section 7. Handling and Storage	
<b>Handling</b>	FLAMMABLE MATERIAL. Handle with care. Avoid contact with any sources of ignition, flames, heat, and sparks. Avoid inhalation of product vapours or mists. Avoid skin contact. Avoid eye contact. Wear proper personal protective equipment (See Section 8). Ensure all equipment is grounded/bonded. Do not ingest this product. Avoid generating mists. Avoid confined spaces and areas with poor ventilation. Avoid contact with any incompatible or reactive materials. Empty containers may contain product residue. Do not pressurize, cut, heat, or weld empty containers. Do not reuse containers without commercial cleaning and/or reconditioning. Personnel who handle this material should practice good personal hygiene during and after handling to help prevent accidental ingestion of this product.
<b>Storage</b>	Store away from heat and sources of ignition. Store away from incompatible and reactive materials (See section 5 and 10). Ensure the storage containers are grounded/bonded. Keep container tightly closed. Store in dry, cool, well-ventilated area.

**Section 8. Exposure Controls/Personal Protection**

<b>Engineering Controls</b>	For normal application, special ventilation is not necessary. If user's operations generate vapours or mist, use ventilation to keep exposure to airborne contaminants below the exposure limit. Make-up air should always be supplied to balance air removed by exhaust ventilation. Ensure that eyewash station and safety shower are close to work-station.
<b>Personal Protection</b>	<i>- The selection of personal protective equipment varies, depending upon conditions of use.</i>
<b>Eyes</b>	As a minimum, safety glasses with side shields should be worn when handling this material.
<b>Body</b>	If this material may come into contact with the body during handling and use, we recommend wearing appropriate protective clothing to prevent contact with the skin. (Contact your PPE provider for more information).
<b>Respiratory</b>	A NIOSH-approved air-purifying respirator with an organic vapour cartridge or canister may be permissible under certain circumstances where airborne concentrations are expected to exceed exposure limits. Protection provided by air-purifying respirators is limited. Use a positive-pressure, air-supplied respirator if there is any potential for uncontrolled release, exposure levels are unknown, or any other circumstances where air-purifying respirators may not provide adequate protection.
<b>Hands</b>	If this material may come in contact with the hands during handling and use, we recommend wearing gloves of the following material(s): polyvinyl alcohol (PVA), and fluoro-elastomer. Consult your PPE provider for breakthrough times and the specific glove that is best for you based on your use patterns. It should be realized that eventually any material regardless of their imperviousness, will get permeated by chemicals. Therefore, protective gloves should be regularly checked for wear and tear. At the first signs of hardening and cracks, they should be changed.
<b>Feet</b>	Wear appropriate footwear to prevent product from coming in contact with feet and skin.

**Section 9. Physical and Chemical Properties**

<b>Physical State and Appearance</b>	Clear liquid.	<b>Viscosity</b>	Not available (similar to Gasoline)
<b>Colour</b>	Clear and colourless.	<b>Pour Point</b>	Freezing point: <-51°C(<-60°F) for all types of Jet B including F40.
<b>Odour</b>	Gasoline like.	<b>Softening Point</b>	Not applicable.
<b>Odour Threshold</b>	Not available	<b>Dropping Point</b>	Not applicable.
<b>Boiling Point</b>	50 to 270°C (122 to 518°F)	<b>Penetration</b>	Not applicable.
<b>Density</b>	0.75 to 0.80 kg/L @ 15°C (59°F).	<b>Oil / Water Dist. Coefficient</b>	Not available
<b>Vapour Density</b>	3.5 (Air = 1)	<b>Ionicity (in water)</b>	Not available
<b>Vapour Pressure</b>	21 kPa (158 mmHg) @ 37.8°C (100°F).	<b>Dispersion Properties</b>	Not available
<b>Volatility</b>	Volatile.	<b>Solubility</b>	Insoluble in water. Partially miscible in some alcohols. Miscible in other petroleum solvents.

**Section 10. Stability and Reactivity**

<b>Corrosivity</b>	Not available		
<b>Stability</b>	The product is stable under normal handling and storage conditions.	<b>Hazardous Polymerization</b>	Will not occur under normal working conditions.
<b>Incompatible Substances / Conditions to Avoid</b>	Reactive with oxidizing agents, diborane, and halogen compounds.	<b>Decomposition Products</b>	May release COx, NOx, SOx, aldehydes, ketones, smoke and irritating vapours when heated to decomposition.

**Section 11. Toxicological Information**

<b>Routes of Entry</b>	Skin contact, eye contact, inhalation and ingestion.
<b>Acute Lethality</b>	Acute toxicity information is not available for the product as a whole, therefore, data for some of the ingredients is provided below:  <u>Benzene (71-43-2):</u> Acute oral toxicity (LD50): 930 mg/kg (rat). Acute dermal toxicity (LD50): >9400 mg/kg (rabbit). Acute inhalation toxicity (LC50): 13200 ppm/4h (rat).  <u>Diethylene Glycol Monomethyl Ether (111-77-3):</u> Acute oral toxicity (LD50): 4140-5180 mg/kg (rat). Acute dermal toxicity (LD50): >2000 mg/kg (rabbit). Acute inhalation toxicity (LC50): >50000 mg/m³/4h (rat).

Continued on Next Page

Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Available in French

JET B AVIATION TURBINE FUEL		Page Number: 4
<b>Chronic or Other Toxic Effects</b>		
Dermal Route:	This product contains a component (at $\geq 1\%$ ) that can cause skin irritation. Therefore, this product is considered to be a skin irritant. Prolonged or repeated contact may defat and dry skin, and cause dermatitis.	
Inhalation Route:	Ingestion of this product may cause Central Nervous System (CNS) Depression, symptoms of which may include; weakness, dizziness, slurred speech, drowsiness, unconsciousness and in cases of severe overexposure; coma and death.	
Oral Route:	Ingestion of this product may lead to aspiration of the liquid, especially if vomiting occurs. This may result in chemical pneumonitis (inflammation of the lungs) and/or pulmonary edema (an accumulation of fluid in the lungs).	
Eye Irritation/Inflammation:	Short-term exposure is expected to cause only slight irritation, if any.	
Immunotoxicity:	Not available	
Skin Sensitization:	Contact with this product is not expected to cause skin sensitization, based upon the available data and the known hazards of the components.	
Respiratory Tract Sensitization:	Contact with this product is not expected to cause respiratory tract sensitization, based upon the available data and the known hazards of the components.	
Mutagenic:	Benzene is tumorigenic by RTECS criteria.	
Reproductive Toxicity:	This product is not known to contain any components at $\geq 0.1\%$ that have been shown to cause reproductive toxicity. Therefore, based upon the available data and the known hazards of the components, this product is not expected to be a reproductive toxin.	
Teratogenicity/Embryotoxicity:	This product contains a component(s) at $\geq 0.1\%$ that has been shown to cause teratogenicity and/or embryotoxicity in laboratory tests. Therefore, this product is considered to be a teratogen/embryotoxin [Diethylene Glycol Monomethyl Ether].	
Carcinogenicity (ACGIH):	This product contains the following chemical(s) at $\geq 0.1\%$ that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. (Considered to be A1 by the ACGIH. Benzene, 71-43-2)	
Carcinogenicity (IARC):	This product contains the following chemical(s) at $\geq 0.1\%$ that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. (Considered to be carcinogenic to humans (group 1) by IARC. Benzene, 71-43-2)	
Carcinogenicity (NTP):	This product contains the following chemical(s) at $\geq 0.1\%$ that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. (Known to be a human carcinogen according to NTP. Benzene, 71-43-2)	
Carcinogenicity (IRIS):	This product contains the following chemical(s) at $\geq 0.1\%$ that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. (Considered to be carcinogenic by IRIS. Benzene, 71-43-2)	
Carcinogenicity (OSHA):	This product contains the following chemical(s) at $\geq 0.1\%$ that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. (Considered to be carcinogenic by OSHA. Benzene, 71-43-2)	
<b>Other Considerations</b>	No additional remark.	

Section 12. Ecological Information			
<b>Environmental Fate</b>	Not available	<b>Persistence/Bioaccumulation Potential</b>	Not available
<b>BOD5 and COD</b>	Not available	<b>Products of Biodegradation</b>	Not available
<b>Additional Remarks</b> No additional remark.			

Section 13. Disposal Considerations	
<b>Waste Disposal</b>	Spent/ used/ waste product may meet the requirements of a hazardous waste. Consult your local or regional authorities. Ensure that waste management processes are in compliance with government requirements and local disposal regulations.

<b>TDG Classification</b>	FUEL, AVIATION, TURBINE ENGINE, 3, UN1863, PGII (CL-TDG)	<b>Special Provisions for Transport</b>	See Transportation of Dangerous Goods Regulations.
---------------------------	---	---	---

<b>Other Regulations</b>	<p>This product is acceptable for use under the provisions of WHMIS-CPR. All components of this formulation are listed on the CEPA-DSL (Domestic Substances List).</p> <p>All components of this formulation are listed on the US EPA-TSCA Inventory.</p> <p>All components of this product are on the European Inventory of Existing Commercial Chemical Substances (EINECS).</p> <p>This product has been classified in accordance with the hazard criteria of the Controlled Products Regulations (CPR) and the MSDS contains all of the information required by the CPR.</p> <p>Please contact Product Safety for more information.</p>
--------------------------	---

DSD/DPD (Europe)		Not evaluated.	HCS (U.S.A.)		HCS Class: Flammable liquid having a flash point lower than 37.8°C (100°F). HCS Class: May cause cancer. HCS Class: Target organ effects. HCS Class: Irritating substance.																																				
ADR (Europe) (Pictograms)		NOT EVALUATED FOR EUROPEAN TRANSPORT  NON ÉVALUÉ POUR LE TRANSPORT EUROPÉEN.	DOT (U.S.A.) (Pictograms)		Not evaluated for transport  Non évalué pour le transport																																				
HMIS (U.S.A.)		<table><tr><td>Health Hazard</td><td>(2*)</td></tr><tr><td>Fire Hazard</td><td>(3)</td></tr><tr><td>Reactivity</td><td>(0)</td></tr><tr><td>Personal Protection</td><td>(H)</td></tr></table>	Health Hazard	(2*)	Fire Hazard	(3)	Reactivity	(0)	Personal Protection	(H)	NFPA (U.S.A.)		<table><tr><td rowspan="4">Health</td><td>3</td><td>Fire Hazard</td><td rowspan="4">Rating</td><td>0</td><td>Insignificant</td></tr><tr><td>2</td><td>0</td><td>Reactivity</td><td>1</td><td>Slight</td></tr><tr><td colspan="3">Specific hazard</td><td>2</td><td>Moderate</td></tr><tr><td colspan="3"></td><td>3</td><td>High</td></tr><tr><td colspan="3"></td><td colspan="3">4</td><td>Extreme</td></tr></table>	Health	3	Fire Hazard	Rating	0	Insignificant	2	0	Reactivity	1	Slight	Specific hazard			2	Moderate				3	High				4			Extreme
Health Hazard	(2*)																																								
Fire Hazard	(3)																																								
Reactivity	(0)																																								
Personal Protection	(H)																																								
Health	3	Fire Hazard	Rating	0	Insignificant																																				
	2	0		Reactivity	1	Slight																																			
	Specific hazard			2	Moderate																																				
				3	High																																				
			4			Extreme																																			

<b>References</b>	Available upon request. * Marque de commerce de Petro-Canada - Trademark
-------------------	---

## Glossary

ACGIH - American Conference of Governmental Industrial Hygienists	HCS - Hazardous Communication System
ADG - Agreement on Dangerous goods by Road (Europe)	HMIS - Hazardous Material Information System
ASTM - American Society for Testing and Materials	IARC - International Agency for Research on Cancer
BOD5 - Biological Oxygen Demand in 5 days	IRIS - Integrated Risk Information System
CAS - Chemical Abstract Services	LD50/LC50 - Lethal Dose/Concentration kill 50%
CEPA - Canadian Environmental Protection Act	LDLo/LCLo - Lowest Published Lethal Dose/Concentration
CERCLA - Comprehensive Environmental Response, Compensation and Liability Act	NFPA - National Fire Prevention Association
CFR - Code of Federal Regulations	NIOSH - National Institute for Occupational Safety & Health
CHIP - Chemical Hazard Information and Packaging Approved Supply List	NPRI - National Pollutant Release Inventory
COD - Chemical Oxygen Demand	NSNR - New Substances Notification Regulations (Canada)
CPR - Controlled Products Regulations	NTP - National Toxicology Program
DOT - Department of Transportation (U.S.A.)	OSHA - Occupational Safety & Health Administration
DSL - Dangerous Substances Classification and Labeling (Europe)	PEL - Permissible Exposure Limit
DSD/DPD - Dangerous Substance or Dangerous Preparations Directives (Europe)	RCRA - Resource Conservation and Recovery Act
DSL - Domestic Substance List (Canada)	SARA - Superfund Amendments and Reorganization Act
EEC/EU - European Economic Community/European Union	STEL - Short Term Exposure Limit (15 minutes)
EINECS - European Inventory of Existing Commercial Chemical Substances	TDG - Transportation Dangerous Goods (Canada)
EPCRA - Emergency Planning And Community Right-To-Know Act	TDLo/TCLo - Lowest Published Toxic Dose/Concentration
FDA - Food and Drug Administration	TLV-TWA - Threshold Limit Value-Time Weighted Average
FIFRA - Federal Insecticide, Fungicide, and Rodenticide Act	TLM - Median Tolerance Limit
	TSCA - Toxic Substances Control Act
	USEPA - United States Environmental Protection Agency
	USP - United States Pharmacopoeia
	WHMIS - Workplace Hazardous Material Information System




For Copy of MSDS Internet: <a href="http://www.petro-canada.ca/msds">www.petro-canada.ca/msds</a>	Prepared by Product Safety - RS on 9/28/2007.
Canada-wide: telephone: 1-800-668-0220; fax: 1-800-837-1228	Data entry by Product Safety - DSR.
For Product Safety Information: (905) 804-4752	



*To the best of our knowledge, the information contained herein is accurate. However, neither the above named supplier nor any of its subsidiaries assumes any liability whatsoever for the accuracy or completeness of the information contained herein. Final determination of suitability of any material is the sole responsibility of the user. All materials may present unknown hazards and should be used with caution. Although certain hazards are described herein, we cannot guarantee that these are the only hazards that exist.*



## Material Safety Data Sheet

WHMIS (Pictograms)	WHMIS (Classification)	Protective Clothing	TDG (pictograms)
	A, B-1		

Section 1. Chemical Product and Company Identification			
<b>Product Name</b>	<b>PROPANE</b>	<b>Code</b>	W222 SAP: 169
<b>Synonym</b>	Propane HD-5, Propane commercial, Liquefied Petroleum Gas (LPG), C3H8, CGSB Propane Grade 1, CGSB Propane Grade 2, odourized propane, stench propane, automotive propane.	<b>Validated on</b>	9/28/2006.
<b>Manufacturer</b>	PETRO-CANADA P.O. Box 2844 Calgary, Alberta T2P 3E3	<b>In case of Emergency</b>	Petro-Canada: 403-296-3000 Canutec Transportation: 613-996-6666 Poison Control Centre: Consult local telephone directory for emergency number(s).
<b>Material Uses</b>	Propane is used as a fuel gas, refrigerant, automotive fuel and as a raw material for organic synthesis. The grade determines the propane content. It is supplied as pressurized liquid in tanks.		

Section 2. Composition and Information on Ingredients					
			Exposure Limits (ACGIH)		
Name	CAS #	% (V/V)	TLV-TWA(8 h)	STEL	CEILING
HD-5 Propane	74-98-6	>90	1000 ppm	Not established	Not established
Propane	115-07-1	<5	500 ppm	Not established	Not established
Propene					
Commercial Propane	74-98-6	>75	1000 ppm	Not established	Not established
Propane	115-07-1	<20	500 ppm	Not established	Not established
Propene					
Both grades may contain:					
Ethane	74-84-0	<6	1000 ppm	Not established	Not established
Butane +	106-97-8	<5	1000 ppm	Not established	Not established
<b>Manufacturer Recommendation</b>	At high concentrations, can displace oxygen and cause asphyxiation. A minimum requirement of 19.5% of oxygen at sea level (148 torr O <sub>2</sub> , dry air) is recommended.				
<b>Other Exposure Limits</b>	Consult local, state, provincial or territory authorities for acceptable exposure limits.				

Section 3. Hazards Identification.	
<b>Potential Health Effects</b>	The product is contained under pressure. Do not puncture, incinerate or heat container as contents may explode. Flammable gas. Exercise caution when handling this material. At high concentrations, can displace oxygen and cause asphyxiation. A minimum requirement of 19.5% of oxygen at sea level (148 torr O <sub>2</sub> , dry air) is recommended. Inhalation of this product may cause respiratory tract irritation and Central Nervous System (CNS) Depression, symptoms of which may include; weakness, dizziness, slurred speech, drowsiness, unconsciousness and in cases of severe overexposure; coma and death. Contact with gas or liquefied gas may cause burns and frostbite. Ingestion is not an applicable route of exposure for gases. For more information refer to Section 11 of this MSDS.

Section 4. First Aid Measures	
<b>Eye Contact</b>	No effects expected. If irritation does occur, remove source of contamination or move victim to fresh air. If irritation persists, obtain medical advice. If frostbite has occurred, quickly remove victim from source of contamination. Immediately and briefly, flush with lukewarm, gently flowing water. DO NOT attempt to rewarm. Cover both eyes with a sterile dressing. DO NOT allow victim to drink alcohol or smoke. Quickly transport victim to an emergency care facility.
<b>Skin Contact</b>	As quickly as possible, remove contaminated clothing, shoes and leather goods (e.g., watchbands, belts, etc.). No health effects expected. If irritation does occur, flush with lukewarm, gently flowing water for 5 minutes. If irritation persists, obtain medical advice. If frostbite has occurred, quickly remove victim from source of contamination and briefly flush with lukewarm, gently flowing water. DO NOT attempt to rewarm the affected area on site. DO NOT rub area or apply direct heat. Gently remove clothing or jewellery that may restrict circulation. Carefully cut around any clothing that sticks to the skin, and remove the rest of the garment. Loosely cover the affected area with a sterile dressing. DO NOT allow victim to drink alcohol or smoke. Quickly transport victim to an emergency care facility.

Continued on Next Page

Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Available in French

<b>PROPANE</b>		<b>Page Number: 2</b>
<b>Inhalation</b>	If symptoms are experienced remove source of contamination or move victim to fresh air and obtain medical advice.	
<b>Ingestion</b>	Ingestion is not an applicable route of exposure for gases.	
<b>Note to Physician</b>	Not available	

<b>Section 5. Fire-fighting Measures</b>			
<b>Flammability</b>	Class I - flammable gas (NFPA).	<b>Flammable Limits</b>	Lower: 2.1%; Upper: 9.5%, (NFPA).
<b>Flash Points</b>	CLOSED CUP: -104°C (-155°F).	<b>Auto-Ignition Temperature</b>	450°C (842°F), (NFPA).
<b>Fire Hazards in Presence of Various Substances</b>	Extremely flammable in presence of open flames, sparks, and heat. Vapours are heavier than air and may travel considerable distance to sources of ignition and flash back. Rapid escape of vapours may generate static charge causing ignition. May accumulate in confined spaces.	<b>Explosion Hazards in Presence of Various Substances</b>	Do not cut, weld, heat, drill or pressurize empty container. Containers may explode in heat of fire. Vapour explosion hazard indoors, outdoors or in sewers. Propane may form explosive mixtures with air.
<b>Products of Combustion</b>	Carbon oxides (CO, CO <sub>2</sub> ), acrid smoke and irritating vapours as products of incomplete combustion.		
<b>Fire Fighting Media and Instructions</b>	NAERG2004, GUIDE 115, Flammable Gas: CAUTION: This product has a low flash point, use of water spray when fighting fire may be inefficient. SMALL FIRE: Use DRY chemicals, CO <sub>2</sub> , water spray or foam. LARGE FIRE: Use water spray, fog or foam. DO NOT use water jet. If tank, rail car or tank truck is involved in a fire, ISOLATE for 1600 meters (1 mile) in all directions; also, consider initial evacuation for 1600 meters (1 mile) in all directions. DO NOT extinguish a leaking gas flame unless leak can be stopped. Shut off fuel to fire if it is possible to do so without hazard. If this is impossible, withdraw from area and let fire burn out under controlled conditions. Withdraw immediately in case of rising sound from venting safety device or any discolouration of tank due to fire. Cool containing vessels with water spray in order to prevent pressure build-up, autoignition or explosion. Self-contained breathing apparatus (SCBA) will be required if approaching the fire from downwind, or to enter enclosed areas or buildings. Handle damaged cylinders with extreme care.		

<b>Section 6. Accidental Release Measures</b>	
<b>Material Release or Spill</b>	IN THE EVENT OF A LARGE SPILL CONSIDER THE FOLLOWING CONTROL MEASURES: Consult current National Emergency Response Guide Book (NAERG) for appropriate spill measures if necessary. Extinguish all ignition sources. Notify appropriate authorities immediately. Evacuate non-essential personnel. Stop leak if safe to do so. Avoid contact with spilled material. Avoid breathing vapours or mists of material. Ventilate area. Ensure clean-up personnel wear appropriate personal protective equipment.

<b>Section 7. Handling and Storage</b>	
<b>Handling</b>	EXTREMELY FLAMMABLE GAS. Handle with care. Avoid contact with any sources of ignition, flames, heat, and sparks. Ensure all equipment is grounded/bonded. Avoid confined spaces and areas with poor ventilation. Avoid skin contact. Avoid eye contact. Avoid inhalation of product vapours. Wear proper personal protective equipment (See Section 8). Rapid escape of vapour may generate static charge causing ignition. Use spark-proof electrical equipment. Do not allow escaping compressed gas or liquid to come in contact with skin or eyes as it can cause frostbite. SPECIAL PRECAUTIONS: Sludges and tank scale from propane storage tanks, trucks and rail cars, and filters/screens may contain naturally occurring radioactive material ("NORM") in the form of lead 210. Similarly, equipment used for the transfer of propane such as product pipelines, pumps and compressors, may have detectable levels of radioactive lead 210 on inner surfaces. Workers involved in cleaning, repair or other maintenance on inner surfaces of such equipment should avoid breathing dust generated from such activities. Suitable codes of practice should be developed for these activities, detailing appropriate occupational hygiene and disposal practices.
<b>Storage</b>	Store away from incompatible and reactive materials (See section 5 and 10). Store away from heat and sources of ignition. Store as flammable material. Compressed gases should be stored in a separate safety storage cabinet or room. Avoid direct sunlight. Keep container tightly closed. Store in dry, cool, well-ventilated area. Ensure the storage containers are grounded/bonded.

<b>Section 8. Exposure Controls/Personal Protection</b>	
<b>Engineering Controls</b>	For normal application, special ventilation is not necessary. If user's operations generate vapours or mist, use ventilation to keep exposure to airborne contaminants below the exposure limit. Make-up air should always be supplied to balance air removed by exhaust ventilation. Ensure that eyewash station and safety shower are close to work-station.
<b>Personal Protection</b>	<b>- The selection of personal protective equipment varies, depending upon conditions of use.</b>
<b>Eyes</b>	As a minimum, safety glasses with side shields should be worn when handling this material.
<b>Body</b>	If this material may come in contact with the body during handling and use, we recommend wearing appropriate protective clothing to prevent contact with the skin. (Contact your PPE provider for more information.)
<b>Respiratory</b>	Always wear NIOSH-approved self-contained breathing apparatus when handling this material.

Continued on Next Page

Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Available in French

<b>PROPANE</b>	<b>Page Number: 3</b>
<b>Hands</b>	Wear appropriate chemically protective gloves. Wear insulated gloves to prevent frostbite.
<b>Feet</b>	Wear appropriate footwear to prevent product from coming in contact with feet and skin.

<b>Section 9. Physical and Chemical Properties</b>			
<b>Physical State and Appearance</b>	Gas at room temperature; liquid when stored under pressure.	<b>Viscosity</b>	Not applicable
<b>Colour</b>	Colourless.	<b>Pour Point</b>	Not applicable.
<b>Odour</b>	Propane is an odourless gas. Odourized propane will contain up to 28 g ethyl mercaptan per 1000 L of propane.	<b>Softening Point</b>	Not applicable.
<b>Odour Threshold</b>	Odour is not an adequate warning to prevent overexposure to propane. Prolonged exposure to mercaptans can cause olfactory desensitization.	<b>Dropping Point</b>	Not applicable.
<b>Boiling Point</b>	-42°C (-44°F)	<b>Penetration</b>	Not applicable.
<b>Density</b>	508 kg/m <sup>3</sup> @ 15°C (59°F)	<b>Oil / Water Dist. Coefficient</b>	Not available
<b>Vapour Density</b>	1.56 (air=1)	<b>Ioncity (in water)</b>	Not available
<b>Vapour Pressure</b>	10763 mmHg (1435 kPa) @ 38°C (100°F)	<b>Dispersion Properties</b>	Not available
<b>Volatility</b>	Volatile	<b>Solubility</b>	Slightly soluble in water.

<b>Section 10. Stability and Reactivity</b>			
<b>Corrosivity</b>	Not available		
<b>Stability</b>	The product is stable under normal handling and storage conditions.	<b>Hazardous Polymerization</b>	Will not occur under normal working conditions.
<b>Incompatible Substances / Conditions to Avoid</b>	Reactive with oxidizing agents and halogenated compounds.	<b>Decomposition Products</b>	May release COx, acrid smoke and irritating vapours when heated to decomposition.

<b>Section 11. Toxicological Information</b>	
<b>Routes of Entry</b>	Inhalation, skin contact and eye contact.
<b>Acute Lethality</b>	Acute toxicity information is not available for the product as a whole, therefore, data for some of the ingredients is provided below:  <u>Propene (115-07-1):</u> Acute inhalation toxicity (LC50): >50000 ppm/4h (rat).  <u>Butane (106-97-8):</u> Acute inhalation toxicity (LC50): 276000 ppm/4h (rat).
<b>Chronic or Other Toxic Effects</b>	
Dermal Route:	Contact with gas or liquefied gas may cause burns and frostbite to the skin.
Inhalation Route:	At high concentrations, can displace oxygen and cause asphyxiation. A minimum requirement of 19.5% of oxygen at sea level (148 torr O <sub>2</sub> , dry air) is recommended. Inhalation of this product may cause respiratory tract irritation. Inhalation of this product may cause Central Nervous System (CNS) Depression, symptoms of which may include; weakness, dizziness, slurred speech, drowsiness, unconsciousness and in cases of severe overexposure; coma and death.
Oral Route:	Ingestion is <u>not</u> an applicable route of exposure for gases.
Eye Irritation/Inflammation:	Contact with gas or liquefied gas may cause burns and frostbite to the eyes.
Immunotoxicity:	Not available
Skin Sensitization:	Contact with this product is not expected to cause skin sensitization, based upon the available data and the known hazards of the components.
Respiratory Tract Sensitization:	Contact with this product is not expected to cause respiratory tract sensitization, based upon the available data and the known hazards of the components.
Mutagenic:	This product is not known to contain any components at >= 0.1% that have been shown to cause mutagenicity. Therefore, based upon the available data and the known hazards of the components, this product is not expected to be a mutagen.

Continued on Next Page

Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Available in French

PROPANE		Page Number: 4
Reproductive Toxicity:	This product is not known to contain any components at $\geq 0.1\%$ that have been shown to cause reproductive toxicity. Therefore, based upon the available data and the known hazards of the components, this product is not expected to be a reproductive toxin.	
Teratogenicity/Embryotoxicity:	This product is not known to contain any components at $\geq 0.1\%$ that have been shown to cause teratogenicity and/or embryotoxicity. Therefore, based upon the available data and the known hazards of the components, this product is not expected to be a teratogen/embryotoxin.	
Carcinogenicity (ACGIH):	This product is not known to contain any chemicals at reportable quantities that are listed as Group A1 or A2 carcinogens by ACGIH.	
Carcinogenicity (IARC):	This product is not known to contain any chemicals at reportable quantities that are listed as Group 1, 2A, or 2B carcinogens by IARC.	
Carcinogenicity (NTP):	This product is not known to contain any chemicals at reportable quantities that are listed as carcinogens by NTP.	
Carcinogenicity (IRIS):	This product is not known to contain any chemicals at reportable quantities that are listed as carcinogens by IRIS.	
Carcinogenicity (OSHA):	This product is not known to contain any chemicals at reportable quantities that are listed as carcinogens by OSHA.	
<b>Other Considerations</b>	No additional remark.	

Section 12. Ecological Information			
<b>Environmental Fate</b>	Not available	<b>Persistence/Bioaccumulation Potential</b>	Not available
<b>BOD5 and COD</b>	Not available	<b>Products of Biodegradation</b>	Not available
<b>Additional Remarks</b> No additional remark.			

Section 13. Disposal Considerations	
<b>Waste Disposal</b>	Consult your local or regional authorities. Ensure that waste management processes are in compliance with government requirements and local disposal regulations.

Section 14. Transport Information		
<b>TDG Classification</b>	PROPANE, 2.1, UN1978 (CL-TDG)	<b>Special Provisions for Transport</b> See Transportation of Dangerous Goods Regulations.

Section 15. Regulatory Information

Other Regulations

This product is acceptable for use under the provisions of WHMIS-CPR. All components of this formulation are listed on the CEPA-DSL (Domestic Substances List).

All components of this formulation are listed on the US EPA-TSCA Inventory.

All components of this product are on the European Inventory of Existing Commercial Chemical Substances (EINECS).

This product has been classified in accordance with the hazard criteria of the Controlled Products Regulations (CPR) and the MSDS contains all of the information required by the CPR.

Please contact Product Safety for more information.

DSD/DPD (Europe)

Not evaluated.

HCS (U.S.A.)

HCS Class: Flammable gas.

ADR (Europe) (Pictograms)

NOT EVALUATED FOR EUROPEAN TRANSPORT

NON ÉVALUÉ POUR LE TRANSPORT EUROPÉEN.

DOT (U.S.A) (Pictograms)

Not evaluated for transport

Non évalué pour le transport

HMIS (U.S.A.)

Health Hazard1\*

Fire Hazard4

Reactivity0

Personal ProtectionK

NFPA (U.S.A.)

Health1

Fire Hazard4

Reactivity0

Specific hazard

Rating

0 Insignificant

1 Slight

2 Moderate

3 High

4 Extreme

**Section 16. Other Information****References**

Available upon request.

\* Marque de commerce de Petro-Canada - Trademark

**Glossary**

ACGIH - American Conference of Governmental Industrial Hygienists  
 ADR - Agreement on Dangerous goods by Road (Europe)  
 ASTM - American Society for Testing and Materials  
 BOD5 - Biological Oxygen Demand in 5 days  
 CAS - Chemical Abstract Services  
 CEPA - Canadian Environmental Protection Act  
 CERCLA - Comprehensive Environmental Response, Compensation and Liability Act  
 CFR - Code of Federal Regulations  
 CHIP - Chemical Hazard Information and Packaging Approved Supply List  
 COD - Chemical Oxygen Demand  
 CPR - Controlled Products Regulations  
 DOT - Department of Transportation (U.S.A.)  
 DSCL - Dangerous Substances Classification and Labeling (Europe)  
 DSD/DPD - Dangerous Substance or Dangerous Preparations Directives (Europe)  
 DSL - Domestic Substance List (Canada)  
 EEC/EU - European Economic Community/European Union  
 EINECS - European Inventory of Existing Commercial Chemical Substances  
 EPCRA - Emergency Planning And Community Right-To-Know Act  
 FDA - Food and Drug Administration  
 FIFRA - Federal Insecticide, Fungicide, and Rodenticide Act

HCS - Hazardous Communication System  
 HMIS - Hazardous Material Information System  
 IARC - International Agency for Research on Cancer  
 IRIS - Integrated Risk Information System  
 LD50/LC50 - Lethal Dose/Concentration kill 50%  
 LDLo/LCLo - Lowest Published Lethal Dose/Concentration  
 NFPA - National Fire Prevention Association  
 NIOSH - National Institute for Occupational Safety & Health  
 NPRI - National Pollutant Release Inventory  
 NSNR - New Substances Notification Regulations (Canada)  
 NTP - National Toxicology Program  
 OSHA - Occupational Safety & Health Administration  
 PEL - Permissible Exposure Limit  
 RCRA - Resource Conservation and Recovery Act  
 SARA - Superfund Amendments and Reorganization Act  
 STEL - Short Term Exposure Limit (15 minutes)  
 TDG - Transportation Dangerous Goods (Canada)  
 TDLo/TCLo - Lowest Published Toxic Dose/Concentration  
 TLV-TWA - Threshold Limit Value-Time Weighted Average  
 TLM - Median Tolerance Limit  
 TSCA - Toxic Substances Control Act  
 USEPA - United States Environmental Protection Agency  
 USP - United States Pharmacopoeia  
 WHMIS - Workplace Hazardous Material Information System

**For Copy of MSDS**Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Canada-wide: telephone: 1-800-668-0220; fax: 1-800-837-1228

For Product Safety Information: (905) 804-4752








Prepared by Product Safety - JDW on 9/28/2006.

Data entry by Product Safety - DSR.

*To the best of our knowledge, the information contained herein is accurate. However, neither the above named supplier nor any of its subsidiaries assumes any liability whatsoever for the accuracy or completeness of the information contained herein. Final determination of suitability of any material is the sole responsibility of the user. All materials may present unknown hazards and should be used with caution. Although certain hazards are described herein, we cannot guarantee that these are the only hazards that exist.*



## Material Safety Data Sheet

WHMIS (Pictograms)	WHMIS (Classification)	Protective Clothing	TDG (pictograms)
 	B-2, D-2A, D-2B	   	

Section 1. Chemical Product and Company Identification			
Product Name	GASOLINE, UNLEADED		Code W102E
Synonym	Regular, Unleaded Gasoline (US Grade), Mid-Grade, Plus, Super, WinterGas, SummerGas, Supreme, SuperClean WinterGas, RegularClean, PlusClean, Premium, marked or dyed gasoline, Super Premium (94 RO), TQRUL, transitional quality regular unleaded, BOB, Blendstock for Oxygenate Blending		Validated on 7/4/2005.
Manufacturer	PETRO-CANADA P.O. Box 2844 Calgary, Alberta T2P 3E3		In case of Emergency Petro-Canada: 403-296-3000 Canutec Transportation: 613-996-6666 Poison Control Centre: Consult local telephone directory for emergency number(s).
Material Uses	Unleaded gasoline is used in spark ignition engines including motor vehicles, inboard and outboard boat engines, small engines such as chain saws and lawn mowers, and recreational vehicles.		

Section 2. Composition and Information on Ingredients					
			Exposure Limits (ACGIH)		
Name	CAS #	% (W/W)	TLV-TWA(8 h)	STEL	CEILING
Gasoline	8006-61-9	85-100	300 ppm	500 ppm	Not established
Methyl tert-butyl ether	1634-04-4	0-15	50 ppm	Not established	Not established
Benzene	71-43-2	<1.5	0.5 ppm	2.5 ppm	Not established
Note: Petro-Canada does not use MTBE in the manufacturing of its gasoline, however MTBE can be introduced from time to time through the use of external gasoline blendstocks.					
Manufacturer	Not applicable				
Recommendation					
Other Exposure Limits	Consult local, state, provincial or territory authorities for acceptable exposure limits.				

Section 3. Hazards Identification.	
Potential Health Effects	Flammable liquid. Exercise caution when handling this material. May cause cancer. May cause heritable genetic effects (mutagenicity). This product contains an ingredient or ingredients, which have been shown to cause chronic toxic effects. Contact with this product may cause skin and eye irritation. Inhalation of this product may cause respiratory tract irritation and Central Nervous System (CNS) Depression, symptoms of which may include; weakness, dizziness, slurred speech, drowsiness, unconsciousness and in cases of severe overexposure; coma and death. Ingestion of this product may cause gastro-intestinal irritation. Aspiration of this product may result in severe irritation or burns to the respiratory tract. For more information refer to Section 11 of this MSDS.

Section 4. First Aid Measures	
Eye Contact	Avoid direct contact. Quickly and gently blot or brush away chemical. Immediately flush the contaminated eye(s) with lukewarm, gently flowing water for 15-20 minutes or until the chemical is removed, while holding the eyelid(s) open. Take care not to rinse contaminated water into the unaffected eye or onto the face. Obtain medical attention immediately.
Skin Contact	Avoid direct contact. Wear chemical resistant protective clothing if necessary. Quickly and gently, blot or brush away excess chemical. Wash gently and thoroughly with warm water and non-abrasive soap for 15-20 minutes or until chemical is removed. Under running water, remove contaminated clothing, shoes and leather goods (e.g., watch bands, belts, etc.). Obtain medical attention immediately. Completely decontaminate clothing, shoes and leather goods before reuse or discard.
Inhalation	Take proper precautions to ensure your own safety before attempting rescue (e.g. wear appropriate protective equipment). If breathing has stopped, trained personnel should begin artificial respiration (AR) or, if the heart has stopped, cardiopulmonary resuscitation (CPR) immediately. Immediately transport victim to an emergency care facility.

Continued on Next Page

Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Available in French

<b>GASOLINE, UNLEADED</b>		<b>Page Number: 2</b>
<b>Ingestion</b>	NEVER give anything by mouth if victim is rapidly losing consciousness, or is unconscious or convulsing. Have victim rinse mouth thoroughly with water. DO NOT INDUCE VOMITING. Have victim drink 240 to 300 mL (8 to 10 oz) of water to dilute material in stomach. If vomiting occurs naturally, have victim lean forward to reduce risk of aspiration. Repeat administration of water. If breathing has stopped, trained personnel should begin artificial respiration (AR) or, if the heart has stopped, cardiopulmonary resuscitation (CPR) immediately. Quickly transport victim to an emergency care facility.	
<b>Note to Physician</b>	Not available	

<b>Section 5. Fire-fighting Measures</b>			
<b>Flammability</b>	Flammable liquid (NFPA).	<b>Flammable Limits</b>	Lower: 1.3%; Upper: 7.6% (NFPA).
<b>Flash Points</b>	Closed Cup: -50 to -38°C (-58 to -36°F), ASTM D56 Standard Test Method for Flash Point by Tag Closed Tester.	<b>Auto-Ignition Temperature</b>	257°C (495°F) (NFPA).
<b>Fire Hazards in Presence of Various Substances</b>	Extremely flammable in presence of open flames, sparks, and heat. Vapours are heavier than air and may travel considerable distance to sources of ignition and flash back. Rapid escape of vapour may generate static charge causing ignition. May accumulate in confined spaces.	<b>Explosion Hazards in Presence of Various Substances</b>	Do not cut, weld, heat, drill or pressurize empty container. Containers may explode in heat of fire. Vapours may form explosive mixtures with air.
<b>Products of Combustion</b>	Carbon oxides (CO, CO <sub>2</sub> ), nitrogen oxides (NO <sub>x</sub> ), polynuclear aromatic hydrocarbons, phenols, smoke and irritating vapours as products of incomplete combustion.  See Section 11 (Other Considerations) for information regarding the toxicity of the combustion products.		
<b>Fire Fighting Media and Instructions</b>	NAERG2004 GUIDE 128, Flammable liquids (Non-polar/Water-immiscible). CAUTION: This product has a very low flash point: Use of water spray when fighting fire may be inefficient. If tank, rail car or tank truck is involved in a fire, ISOLATE for 800 meters (1/2 mile) in all directions; also consider initial evacuation for 800 meters (1/2 mile) in all directions. SMALL FIRES: Dry chemical, CO <sub>2</sub> , water spray or regular foam. LARGE FIRES: Water spray, fog or regular foam. Do not use straight streams. Move containers from fire area if you can do it without risk. Fires Involving Tanks or Car/Trailer Loads: Fight fire from maximum distance or use unmanned hose holders or monitor nozzles. Cool containers with flooding quantities of water until well after fire is out. Withdraw immediately in case of rising sound from venting devices or any discolouration of tank. ALWAYS stay away from the ends of tanks. For massive fire, use unmanned hose holders or monitor nozzles; if this is impossible withdraw from area and let fire burn. Wear positive pressure self-contained breathing apparatus (SCBA). Structural firefighters' protective clothing will only provide limited protection.		

<b>Section 6. Accidental Release Measures</b>	
<b>Material Release or Spill</b>	IN THE EVENT OF A LARGE SPILL CONSIDER THE FOLLOWING CONTROL MEASURES: Consult current National Emergency Response Guide Book (NAERG) for appropriate spill measures if necessary. Extinguish all ignition sources. Stop leak if safe to do so. Evacuate non-essential personnel. Ventilate area. Dike spilled material. Use appropriate inert absorbent material to absorb spilled product. Collect used absorbent for later disposal. Ensure clean-up personnel wear appropriate personal protective equipment. Avoid contact with spilled material. Avoid contaminating sewers, streams, rivers and other water courses with spilled material. Avoid breathing vapours or mists of material. Ground and bond all equipment used to clean up the spilled material, as it may be a static accumulator. Notify appropriate authorities immediately.

<b>Section 7. Handling and Storage</b>	
<b>Handling</b>	FLAMMABLE MATERIAL. Handle with care. Avoid contact with any sources of ignition, flames, heat, and sparks. Avoid skin contact. Avoid eye contact. Avoid inhalation of product vapours or mists. Wear proper personal protective equipment (See Section 8). Empty containers may contain product residue. Do not pressurize, cut, heat, or weld empty containers. Do not reuse containers without commercial cleaning and/or reconditioning. Personnel who handle this material should practice good personal hygiene during and after handling to help prevent accidental ingestion of this product. Ensure all equipment is grounded/bonded. Avoid confined spaces and areas with poor ventilation. Do not ingest this product.
<b>Storage</b>	Store as flammable material. Store away from incompatible and reactive materials (See section 5 and 10). Store away from heat and sources of ignition. Store in dry, cool, well-ventilated area. Keep container tightly closed. Ensure the storage containers are grounded/bonded. Avoid direct sunlight.



**Section 8. Exposure Controls/Personal Protection**

<b>Engineering Controls</b>	For normal application, special ventilation is not necessary. If user's operations generate vapours or mist, use ventilation to keep exposure to airborne contaminants below the exposure limit. Make-up air should always be supplied to balance air removed by exhaust ventilation. Ensure that eyewash station and safety shower are close to work-station.
<b>Personal Protection</b>	<i>- The selection of personal protective equipment varies, depending upon conditions of use.</i>
<b>Eyes</b>	As a minimum, safety glasses with side shields should be worn when handling this material.
<b>Body</b>	If this material may come in contact with the body during handling and use, we recommend wearing appropriate protective clothing to prevent contact with the skin. (Contact your PPE provider for more information.)
<b>Respiratory</b>	A NIOSH-approved air-purifying respirator with an organic vapour cartridge or canister may be permissible under certain circumstances where airborne concentrations are expected to exceed exposure limits. Protection provided by air-purifying respirators is limited. Use a positive-pressure, air-supplied respirator if there is any potential for uncontrolled release, exposure levels are unknown, or any other circumstances where air-purifying respirators may not provide adequate protection.
<b>Hands</b>	If this material may come in contact with the hands during handling and use, we recommend wearing gloves of the following material(s): polyvinyl alcohol (PVA), fluoro-elastomer. Consult your PPE provider for breakthrough times and the specific glove that is best for you based on your use patterns.
<b>Feet</b>	Wear appropriate footwear to prevent product from coming in contact with feet and skin.

**Section 9. Physical and Chemical Properties**

<b>Physical State and Appearance</b>	Clear liquid.	<b>Viscosity</b>	Not available.
<b>Colour</b>	Clear to slightly yellow, undyed liquid. May be dyed red for taxation purposes.	<b>Pour Point</b>	Not applicable.
<b>Odour</b>	Gasoline. MTBE has a terpene-like odour.	<b>Softening Point</b>	Not applicable.
<b>Odour Threshold</b>	Less than 1 ppm.	<b>Dropping Point</b>	Not applicable.
<b>Boiling Point</b>	25 to 220°C (77 to 428°F) Initial boiling point by ASTM D86 Standard Test Method.	<b>Penetration</b>	Not applicable.
<b>Density</b>	0.685 - 0.80 kg/L @ 15°C (59°F).	<b>Oil / Water Dist. Coefficient</b>	Not available
<b>Vapour Density</b>	3 to 4 (Air = 1) (NFPA).	<b>Ionicity (in water)</b>	Not available
<b>Vapour Pressure</b>	<107 kPa @ 37.8°C (100°F)	<b>Dispersion Properties</b>	Not available
<b>Volatility</b>	Volatile.	<b>Solubility</b>	Hydrocarbon components virtually insoluble in water. Soluble in alcohol, ether, chloroform, and benzene. Dissolves fats, oils and natural resins.

**Section 10. Stability and Reactivity**

<b>Corrosivity</b>	Non corrosive.		
<b>Stability</b>	The product is stable under normal handling and storage conditions.	<b>Hazardous Polymerization</b>	Will not occur under normal working conditions.
<b>Incompatible Substances / Conditions to Avoid</b>	Reactive with oxidizing agents, acids, interhalogens and uranium hexafluoride.	<b>Decomposition Products</b>	May release COx, NOx, phenols, polynuclear aromatic hydrocarbons, acrid smoke and irritating vapours when heated to decomposition.

**Section 11. Toxicological Information**

<b>Routes of Entry</b>	Skin contact, eye contact, inhalation, and ingestion.
<b>Acute Lethality</b>	<p><u>Gasoline (8006-61-9):</u>            Acute Oral toxicity (LD50): 13600 mg/kg (rat)            Acute Dermal toxicity (LD50): &gt;5000 mg/kg (rabbit)</p> <p><u>MTBE (1634-04-4):</u>            Acute Oral toxicity (LD50): 2963 mg/kg (rat)            Acute Dermal toxicity (LD50): &gt;6800 mg/kg (rabbit)            Acute Inhalation toxicity (LC50): 23576 ppm/4h (rat)</p> <p><u>Benzene (71-43-2):</u></p>

Continued on Next Page

Internet: [www.petro-canada.ca/msds](http://www.petro-canada.ca/msds)

Available in French

GASOLINE, UNLEADED		Page Number: 4	
		Acute Oral toxicity (LD50): 930 mg/kg (rat) Acute Dermal toxicity (LD50): >9400 mg/kg (rabbit) Acute Inhalation toxicity (LC50): 13229 ppm/4h (rat)	
<b>Chronic or Other Toxic Effects</b>			
Dermal Route:	Contact may cause skin irritation. Prolonged or repeated contact may defat and dry skin, and cause dermatitis.		
Inhalation Route:	Inhalation of this product may cause respiratory tract irritation. Inhalation of this product may cause Central Nervous System (CNS) Depression, symptoms of which may include; weakness, dizziness, slurred speech, drowsiness, unconsciousness and in cases of severe overexposure; coma and death.		
Oral Route:	Ingestion of this product may cause gastro-intestinal irritation. Aspiration of this product may result in severe irritation or burns to the respiratory tract. Ingestion of this product may cause Central Nervous System (CNS) Depression, symptoms of which may include; weakness, dizziness, slurred speech, drowsiness, unconsciousness and in cases of severe overexposure; coma and death.		
Eye Irritation/Inflammation:	Contact may cause eye irritation.		
Immunotoxicity:	Not available		
Skin Sensitization:	Contact with this product is not expected to cause skin sensitization, based upon the available data and the known hazards of the components.		
Respiratory Tract Sensitization:	Contact with this product is not expected to cause respiratory tract sensitization, based upon the available data and the known hazards of the components.		
Mutagenic:	This product contains a component(s) at >= 0.1% that has been shown to cause mutagenicity in laboratory tests. Therefore, this product is considered to be a mutagen. (Benzene)		
Reproductive Toxicity:	This product is not known to contain any components at >= 0.1% that have been shown to cause reproductive toxicity. Therefore, based upon the available data and the known hazards of the components, this product is not expected to be a reproductive toxin.		
Teratogenicity/Embryotoxicity:	This product is not known to contain any components at >= 0.1% that have been shown to cause teratogenicity and/or embryotoxicity. Therefore, based upon the available data and the known hazards of the components, this product is not expected to be a teratogen/embryotoxin.		
Carcinogenicity (ACGIH):	This product contains the following chemical(s) at >=0.1% that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. [Considered to be A1 by the ACGIH. Benzene (71-43-2)] [Considered to be A3 by the ACGIH. Gasoline (8006-61-9), MTBE (1634-04-4)]		
Carcinogenicity (IARC):	This product contains the following chemical(s) at >=0.1% that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. [Considered to be carcinogenic to humans (group 1) by IARC. Benzene (71-43-2)] [Considered to be carcinogenic to humans (group 2B) by IARC. Gasoline (8006-61-9)]		
Carcinogenicity (NTP):	This product contains the following chemical(s) at >=0.1% that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. [Known to be a human carcinogen according to NTP. Benzene (71-43-2)]		
Carcinogenicity (IRIS):	This product contains the following chemical(s) at >=0.1% that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. [Considered to be carcinogenic by IRIS. Benzene (71-43-2)]		
Carcinogenicity (OSHA):	This product contains the following chemical(s) at >=0.1% that are listed as carcinogenic compounds. Therefore this product is considered to be carcinogenic. [Considered to be carcinogenic by OSHA. Benzene (71-43-2)]		
Other Considerations	Gasoline engine exhaust is possibly carcinogenic to humans (IARC Group 2B).		
<b>Section 12. Ecological Information</b>			
Environmental Fate	Not available	Persistence/Bioaccumulation Potential	Not available
BOD5 and COD	Not available	Products of Biodegradation	Not available
Additional Remarks No additional remark.			

GASOLINE, UNLEADED		Page Number: 5															
Section 13. Disposal Considerations																	
Waste Disposal	Spent/ used/ waste product may meet the requirements of a hazardous waste. Consult your local or regional authorities. Ensure that waste management processes are in compliance with government requirements and local disposal regulations.																
Section 14. Transport Information																	
TDG Classification	GASOLINE, 3, UN1203, PGII (CL-TDG)	Special Provisions for Transport	See Transportation of Dangerous Goods Regulations.														
Section 15. Regulatory Information																	
Other Regulations	This product is acceptable for use under the provisions of WHMIS-CPR. All components of this formulation are listed on the CEPA-DSL (Domestic Substances List).																
	All components of this formulation are listed on the US EPA-TSCA Inventory.																
	All components of this product are on the European Inventory of Existing Commercial Chemical Substances (EINECS).																
	This product has been classified in accordance with the hazard criteria of the Controlled Products Regulations (CPR) and the MSDS contains all of the information required by the CPR.																
	Please contact Product Safety for more information.																
DSD/DPD (Europe)	Not evaluated.	HCS (U.S.A.)	CLASS: Contains material which may cause cancer. CLASS: Flammable liquid having a flash point lower than 37.8°C (100°F). CLASS: Irritating substance. CLASS: Target organ effects.														
ADR (Europe) (Pictograms)	NOT EVALUATED FOR EUROPEAN TRANSPORT NON ÉVALUÉ POUR LE TRANSPORT EUROPÉEN.	DOT (U.S.A) (Pictograms)	Not evaluated for transport Non évalué pour le transport														
HMIS (U.S.A.)	<table><tr><td>Health Hazard</td><td>2*</td></tr><tr><td>Fire Hazard</td><td>3</td></tr><tr><td>Reactivity</td><td>0</td></tr><tr><td>Personal Protection</td><td>H</td></tr></table>	Health Hazard	2*	Fire Hazard	3	Reactivity	0	Personal Protection	H	NFPA (U.S.A.) <table><tr><td>3</td><td>Fire Hazard</td></tr><tr><td>2</td><td>Health</td></tr><tr><td>0</td><td>Reactivity</td></tr></table> <p>Specific hazard</p>	3	Fire Hazard	2	Health	0	Reactivity	Rating 0 Insignificant 1 Slight 2 Moderate 3 High 4 Extreme
Health Hazard	2*																
Fire Hazard	3																
Reactivity	0																
Personal Protection	H																
3	Fire Hazard																
2	Health																
0	Reactivity																
Section 16. Other Information																	
References	Available upon request * Marque de commerce de Petro-Canada - Trademark																
Glossary	<table><tr><td>ACGIH - American Conference of Governmental Industrial Hygienists ADR - Agreement on Dangerous goods by Road (Europe) ASTM - American Society for Testing and Materials BOD5 - Biological Oxygen Demand in 5 days CAS - Chemical Abstract Services CEPA - Canadian Environmental Protection Act CERCLA - Comprehensive Environmental Response, Compensation and Liability Act CFR - Code of Federal Regulations CHIP - Chemical Hazard Information and Packaging Approved Supply List COD - Chemical Oxygen Demand CPR - Controlled Products Regulations DOT - Department of Transportation (U.S.A.) DSCl - Dangerous Substances Classification and Labeling (Europe) DSD/DPD - Dangerous Substance or Dangerous Preparations Directives (Europe) DSL - Domestic Substance List (Canada) EEC/EU - European Economic Community/European Union EINECS - European Inventory of Existing Commercial Chemical Substances EPCRA - Emergency Planning And Community Right-To-Know Act FDA - Food and Drug Administration FIFRA - Federal Insecticide, Fungicide, and Rodenticide Act</td><td>HCS - Hazardous Communication System HMIS - Hazardous Material Information System IARC - International Agency for Research on Cancer IRIS - Integrated Risk Information System LD50/LC50 - Lethal Dose/Concentration kill 50% LDLo/LCLo - Lowest Published Lethal Dose/Concentration NFPA - National Fire Prevention Association NIOSH - National Institute for Occupational Safety &amp; Health NPRI - National Pollutant Release Inventory NSNR - New Substances Notification Regulations (Canada) NTP - National Toxicology Program OSHA - Occupational Safety &amp; Health Administration PEL - Permissible Exposure Limit RCRA - Resource Conservation and Recovery Act SARA - Superfund Amendments and Reorganization Act STEL - Short Term Exposure Limit (15 minutes) TDG - Transportation Dangerous Goods (Canada) TDLo/TCLo - Lowest Published Toxic Dose/Concentration TLV-TWA - Threshold Limit Value-Time Weighted Average TLm - Median Tolerance Limit TSCA - Toxic Substances Control Act USEPA - United States Environmental Protection Agency USP - United States Pharmacopoeia WHMIS - Workplace Hazardous Material Information System</td></tr></table>			ACGIH - American Conference of Governmental Industrial Hygienists ADR - Agreement on Dangerous goods by Road (Europe) ASTM - American Society for Testing and Materials BOD5 - Biological Oxygen Demand in 5 days CAS - Chemical Abstract Services CEPA - Canadian Environmental Protection Act CERCLA - Comprehensive Environmental Response, Compensation and Liability Act CFR - Code of Federal Regulations CHIP - Chemical Hazard Information and Packaging Approved Supply List COD - Chemical Oxygen Demand CPR - Controlled Products Regulations DOT - Department of Transportation (U.S.A.) DSCl - Dangerous Substances Classification and Labeling (Europe) DSD/DPD - Dangerous Substance or Dangerous Preparations Directives (Europe) DSL - Domestic Substance List (Canada) EEC/EU - European Economic Community/European Union EINECS - European Inventory of Existing Commercial Chemical Substances EPCRA - Emergency Planning And Community Right-To-Know Act FDA - Food and Drug Administration FIFRA - Federal Insecticide, Fungicide, and Rodenticide Act	HCS - Hazardous Communication System HMIS - Hazardous Material Information System IARC - International Agency for Research on Cancer IRIS - Integrated Risk Information System LD50/LC50 - Lethal Dose/Concentration kill 50% LDLo/LCLo - Lowest Published Lethal Dose/Concentration NFPA - National Fire Prevention Association NIOSH - National Institute for Occupational Safety & Health NPRI - National Pollutant Release Inventory NSNR - New Substances Notification Regulations (Canada) NTP - National Toxicology Program OSHA - Occupational Safety & Health Administration PEL - Permissible Exposure Limit RCRA - Resource Conservation and Recovery Act SARA - Superfund Amendments and Reorganization Act STEL - Short Term Exposure Limit (15 minutes) TDG - Transportation Dangerous Goods (Canada) TDLo/TCLo - Lowest Published Toxic Dose/Concentration TLV-TWA - Threshold Limit Value-Time Weighted Average TLm - Median Tolerance Limit TSCA - Toxic Substances Control Act USEPA - United States Environmental Protection Agency USP - United States Pharmacopoeia WHMIS - Workplace Hazardous Material Information System												
ACGIH - American Conference of Governmental Industrial Hygienists ADR - Agreement on Dangerous goods by Road (Europe) ASTM - American Society for Testing and Materials BOD5 - Biological Oxygen Demand in 5 days CAS - Chemical Abstract Services CEPA - Canadian Environmental Protection Act CERCLA - Comprehensive Environmental Response, Compensation and Liability Act CFR - Code of Federal Regulations CHIP - Chemical Hazard Information and Packaging Approved Supply List COD - Chemical Oxygen Demand CPR - Controlled Products Regulations DOT - Department of Transportation (U.S.A.) DSCl - Dangerous Substances Classification and Labeling (Europe) DSD/DPD - Dangerous Substance or Dangerous Preparations Directives (Europe) DSL - Domestic Substance List (Canada) EEC/EU - European Economic Community/European Union EINECS - European Inventory of Existing Commercial Chemical Substances EPCRA - Emergency Planning And Community Right-To-Know Act FDA - Food and Drug Administration FIFRA - Federal Insecticide, Fungicide, and Rodenticide Act	HCS - Hazardous Communication System HMIS - Hazardous Material Information System IARC - International Agency for Research on Cancer IRIS - Integrated Risk Information System LD50/LC50 - Lethal Dose/Concentration kill 50% LDLo/LCLo - Lowest Published Lethal Dose/Concentration NFPA - National Fire Prevention Association NIOSH - National Institute for Occupational Safety & Health NPRI - National Pollutant Release Inventory NSNR - New Substances Notification Regulations (Canada) NTP - National Toxicology Program OSHA - Occupational Safety & Health Administration PEL - Permissible Exposure Limit RCRA - Resource Conservation and Recovery Act SARA - Superfund Amendments and Reorganization Act STEL - Short Term Exposure Limit (15 minutes) TDG - Transportation Dangerous Goods (Canada) TDLo/TCLo - Lowest Published Toxic Dose/Concentration TLV-TWA - Threshold Limit Value-Time Weighted Average TLm - Median Tolerance Limit TSCA - Toxic Substances Control Act USEPA - United States Environmental Protection Agency USP - United States Pharmacopoeia WHMIS - Workplace Hazardous Material Information System																
For Copy of MSDS	Prepared by Product Safety - JDW on 7/4/2005.																
Continued on Next Page		Internet: <a href="http://www.petro-canada.ca/msds">www.petro-canada.ca/msds</a>															
		Available in French															

GASOLINE, UNLEADED		Page Number: 6
Internet: <a href="http://www.petro-canada.ca/msds">www.petro-canada.ca/msds</a> Canada-wide: telephone: 1-800-668-0220; fax: 1-800-837-1228 For Product Safety Information: (905) 804-4752		Data entry by Product Safety - JDW.
<p><i>To the best of our knowledge, the information contained herein is accurate. However, neither the above named supplier nor any of its subsidiaries assumes any liability whatsoever for the accuracy or completeness of the information contained herein. Final determination of suitability of any material is the sole responsibility of the user. All materials may present unknown hazards and should be used with caution. Although certain hazards are described herein, we cannot guarantee that these are the only hazards that exist.</i></p>		