

Location		Date	Lab Report #	Result			Detection Limit
				Fecal Coliforms	Total Coliforms	E. coli	
Windy	HOP-1 (fresh water intake)						
	First Aid Room Sink	May 14/08	L630094	<1	<1	<1	1
	Kitchen Coffee Sink	May 14/08	L630094	<1	<1	<1	1
	Main Kitchen Sink	May 14/08	L630094	<1	<1	<1	1
	Dry Sink #1 Men's	May 14/08	L630094	<1	<1	<1	1
	Dry Sink #2 Women's	May 14/08	L630094	<1	<1	<1	1
	HOP-1 (fresh water intake)						
	First Aid Room Sink	June 11/08	L642181	<1	<1	<1	1
	Kitchen Coffee Sink	June 11/08	L642181	<1	<1	<1	1
	Main Kitchen Sink	June 11/08	L642181	<1	<1	<1	1
	Dry Sink #1 Men's	June 11/08	L642181	<1	<1	<1	1
	Dry Sink #2 Women's	June 11/08	L642181	<1	<1	<1	1
	HOP-1 (fresh water intake)	July 3/08	L651406	<1	5	<1	1
	First Aid Room Sink	July 9/08	L653550	<1	<1	<1	1
	Kitchen Coffee Sink	July 9/08	L653550	<1	<1	<1	1
	Main Kitchen Sink	July 9/08	L653550	<1	<1	<1	1
	Dry Sink #1 Men's	July 9/08	L653550	<1	<1	<1	1
	Dry Sink #2 Women's	July 9/08	L653550	<1	<1	<1	1
	HOP-1 (fresh water intake)						
	First Aid Room Sink	July 16/08	L657935	<1	3*	<1	1
	Kitchen Coffee Sink	July 16/08	L657935	<1	<1	<1	1
	Main Kitchen Sink	July 16/08	L657935	<1	<1	<1	1
	Dry Sink #1 Men's	July 16/08	L657935	<1	<1	<1	1
	Dry Sink #2 Women's	July 16/08	L657935	<1	<1	<1	1
	HOP-1 (fresh water intake)	July 21/08		<1	12*	<1	1
	First Aid Room Sink	July 23/08	taken July 23/08				
	Kitchen Coffee Sink	July 23/08					
	Main Kitchen Sink	July 23/08					
	Dry Sink #1 Men's	July 23/08					
	Dry Sink #2 Women's	July 23/08					
Boston	BOS-1 (fresh water intake)						
	Bathroom Sink by Room 19 ?	June 9/08	L639846	<1	<1	<1	1
	Kitchen Coffee Sink ?	June 9/08	L639846	<1	<1	<1	1
	Major Drilling Side Bathroom Sink ?	June 9/08	L639846	<1	1	<1	1
	Bathroom Sink by Room 19 ?	June 16/08	L642969	<1	1	<1	1
	Kitchen Coffee Sink ?	June 16/08	L642969	<1	<1	<1	1
	Major Drilling Side Bathroom Sink ?	June 16/08	L642969	<1	1	<1	1
	Medic Sink	July 7/08	L652921	<1	<1	<1	1
	Kitchen	July 7/08	L652921	<1	<1	<1	1
	Men's Bathroom	July 7/08	L652921	<1	<1	<1	1
	Construction Bathroom ?	July 7/08	L652921	<1	<1	<1	1
	BOS-1 (fresh water intake)	July 14/08	L656384	<1	12	1	1
	Medic Sink	July 14/08	L656384	<1	<1	<1	1
	Kitchen	July 14/08	L656384	<1	<1	<1	1
	Men's Bathroom	July 14/08	L656384	<1	<1	<1	1

	BOS-1 (fresh water intake)	July 21/08		<1	24.1*	1*	1
	Medic Sink	July 21/08		<1	<1	<1	1
	Kitchen Sink	July 21/08		<1	<1	<1	1
	Men's Bathroom	July 21/08		<1	<1	<1	1
Matrix Camp							
	Kitchen	July 21/08		<1	<1	<1	1
	Kitchen	July 21/08		<1	<1	<1	1
	Kitchen	July 21/08		<1	<1	<1	1
	Men's Washroom Sink	July 21/08		<1	1*	<1	1
	Women's Washroom Sink	July 21/08		<1	5.2*	<1	1
	Fresh Water Intake	July 23/08	taken July 23/08				

|*by phone, results should be in July 21 afternoon

|*by phone, results should be in July 21 afternoon

*not sure if sample originated at Boston Camp

|*by phone, results should be in July 21 afternoon

|*by phone, results should be in July 21 afternoon