



P.O. BOX 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓂᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File No.: **2BE-HOP0712**

August 7, 2009

To: Hope Bay Mining Limited
Cc: Kitikmeot Distribution

RE: Licence 2BE-HOP0712, Hope Bay Regional Exploration Project

NOTICE OF ERRATA

Part B, Item 10 incorrectly identified the criteria for Fecal Coliform as 10×10^4 CFU/100mL. The correct criteria should have been written as 1×10^4 , or 10,000 CFU/100mL. The following indicates the corrected criteria for the parameters indicated.

PART B CONDITIONS APPLYING TO WASTE DISPOSAL

10. All effluent being discharged from the WWTF, monitoring station HOP-2 shall not exceed the following effluent quality standards:

Parameter	Maximum Average Concentration
BOD ₅	80 mg/L
Total Suspended Solids	100 mg/L
Faecal Coliforms	10,000 CFU/100mL
pH	between 6 and 9
Oil and grease	No visible sheen

Original signed by:

Phyllis Beaulieu
Manager of Licensing
Nunavut Water Board