



P.O. Box 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᐭᓕᓂᓪ ᑲᑎᐭᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYIT
OFFICE DES EAUX DU NUNAVUT

File No.: **2BE-HOP1222**

August 28, 2012

To: Kitikmeot Distribution

RE: Licence 2BE-HOP1222, Hope Bay Regional Exploration Project

NOTICE OF ERRATA

Under the Background information section and the table summarizing the Licence history, the description for the Amendment No.1 issued July 2, 2008 was omitted. It should read as follows:

Amendment No. 1 Issued July 2, 2008	Increase in water use from 50m ³ /day to 100m ³ /day
-------------------------------------	----------------------------------------------------------------------------

Part D, Item 11 contained an error in the effluent quality table for the parameters pH and Oil and Grease. The following indicates the corrected criteria.

PART D CONDITIONS APPLYING TO WASTE DISPOSAL

11. All effluent being discharged from the WWTF, monitoring station HOP-2 shall not exceed the following effluent quality standards:

Parameter	Maximum Allowable Grab Sample Concentration
BOD ₅	80 mg/L
Total Suspended Solids	100 mg/L
Fecal Coliforms	10,000 CFU/100mL
pH	6-9
Oil and grease	No visible sheen

In addition, the condition under Part I, Item 14 did not include the complete wording and was unfinished. The full condition will now read:

PART I CONDITIONS APPLYING TO DRILLING OPERATIONS

14. The Licensee shall restore drill holes and disturbed areas to natural conditions immediately

upon completion of the drilling. The reclamation of drill holes must include the removal of any drill casing materials and, if having encountered artesian flow, the capping of holes with a permanent seal, as referred to under Part F, Item 3.

Original signed by:

Phyllis Beaulieu
Manager of Licensing
Nunavut Water Board