

Phyllis Beaulieu

From: Roberts, Jeremy [JRoberts@gov.nu.ca]
Sent: Tuesday, January 29, 2008 11:56 AM
To: Phyllis Beaulieu
Subject: RE: 2BE-KIG0708 Renewal Application

Regarding section 32, Waste Treatment and Disposal, the greywater disposal area must be 30m away from any body of water.

Jeremy Roberts, C.P.H.I.(C)
Environmental Health Officer
P.O. Box 390, Igalak Building
Kugluktuk, NU, X0B 0E0
Phone: (867) 982-7610
Fax: (867) 982-7640
E-mail: jroberts@gov.nu.ca

-----Original Message-----

From: Phyllis Beaulieu [mailto:licensing@nunavutwaterboard.org]

Sent: January 28, 2008 11:51 AM

To: 'Hessdorfer, Tina'

Cc: Amy Liu; Andrew Keim ; Angela Li-Muller; Bobby Suluk ; Bradley Flynn; Brian Aglukark; Purdy, Bryan; Carson Gillis; cleypermits; Colette Spagnuolo; Conformity NPC; Dave Hohnstein ; David Abernethy ; David Ningeongan; Don Carr; Baddaloo, Earle; Erin Calder ; George Hakongak; Hamlet of Chesterfield; Heather Jones-Otazo; Yeh, Helen; Ian Rumbolt; Ivy Stone; J. Tulugak; Jane Chisholm; Jayko Alooooloo ; Jeannie Ehaloak ; Roberts, Jeremy; Jim Rogers ; John Dawe; Gladstone, Josh; Julian Lim; Keith Grady; Keith Morrison; Ken Landa; 'Kivalliq Inuit Association'; Leslie Payette; Lewis Gidzinski; Luis Manzo; M. Serra ; Melodie Sammurto; Mifflin, Michael; Atkinson, Mike; Mike Fournier; Myra Robertson; Paula Hughson; Peter Kusugak ; Eno, Robert; Spencer Dewar ; Stephen Hartman; Tongola Sandy; V. Tattuinee ; Willins, Gavin
Subject: 2BE-KIG0708 Renewal Application

Please review the above file and provide comments on or before February 29, 2008.

Regards,

Phyllis Beaulieu
Manager of Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU X0B 1J0
Phone: (867) 360-6338
Fax: (867) 360-6369
E-mail: licensing@nunavutwaterboard.org
Visit our Web Page: www.nunavutwaterboard.org