




## NOTES:

1. ALL DIMENSIONS ARE IN MM IF NOT OTHERWISE SPECIFIED.
2. MEDIA FILTER VESSELS ARE MADE OF FRP.
3. CHEMICAL TANKS AND WASTE SETTLING TANKS ARE MADE OF POLYETHYLENE.
4. ALL CONNECTING PIPING AND FITTINGS ARE SCH.80 PVC.
5. ALL COMPONENTS ARE PRE-ASSEMBLED ONTO 304 S.S. FRAME EXCEPT FOR WASTE SETTLING TANK.
6. SOME INSTRUMENTS AND PIPING SUPPORTING ARE NOT SHOWN FOR CLARITY.

## DENOTATION:

- A: RAW WATER INLET (1" 150# FLANGE)  
 B: TREATED WATER OUTLET (1" 150# FLANGE)  
 C: SUPERNATANT TO RAW WATER STRAGE (1" 150# FLANGE)  
 D: WASTE WATER TO DRAIN (2" 150# FLANGE)



00	ISSUED FOR APPROVAL			12/09/2011	W.D.	Y.L.	F.L.	
REV	DESCRIPTION			DD / MM / YYYY	DESIG	CHEC	APPR	NOTES
				REVISION HISTORY				
<div> <b>NAPIER-REID</b> TORONTO CANADA</div> <div>Since 1950</div>				<div>MILNE INLET (PORT)</div> <div>DESIGN FLOW RATE 53 M3/DAY</div> <div>MEDIA-FILTRATION SYSTEM</div> <div>GENERAL ARRANGEMENT</div>				
CUSTOMER ARCELOR MITTAL		PROJECT MARY RIVER WTP, BAFF- INLAND, H337697-PM401		SCALE 1:17.5 OR AS NOTED	FILE NO.: 11-2630		SHEET 1 OF 1	
CONTRACTOR		CONSULTING ENGINEER HTACH LIMITED		 THIRD ANGLE	DESIGN DATE: Sep. 12, 2011		VERSION	
					PLOT DATE: Sep. 12, 2011		R 00	