WATER USE INSPECTION REPORT

Date: July 22,2009	Licensee Rep. (Name/Title): Shirley Standafer-Pfister , Dave Pixston	
Licensee: Peregrine Diamonds		Licence No.: 2BE-NAN0813

WATER SUPPLY

Source(s): Lorillard River	Quantity used: records sent via e-mail
Owner:/Operator: Peregrine Diamonds	

Indicate: A - Acceptable U - Unacceptable NA - Not Applicable NI - Not Inspected

Intake Facilities: A	Storage Structure: A	Treatment Systems: A	Chemical Storage: A
Flow Meas. Device: U	Conveyance Lines: A	Pumping Stations: NA	Screen : A

Comments: Water is pumped from the river to two 250 gallon water tanks contained within the camp dry. Water is treated with bleach only, no filtration or UV used on site.

WASTE DISPOSAL

Sewage: Sewage Treatment System (Prim./Sec/Ter.): Latrine system

Natural Water Body: No	Continuous Discharge (land or water): None	
Seasonal Discharge: None	Wetlands Treatment: None	Trench: None

Indicate: A - Acceptable U - Unacceptable NA - Not Applicable NI - Not Inspected

Discharge Quality: NI	Decant Structure: NA	Erosion: NA
Discharge Meas. Device: NA	Dyke Inspection: NA	Seepages: NA
Dams, Dykes: NA	Freeboard: NA	Spills: NI
Construction: NA	O&M Plan: on file	A&R Plan: On file
Discharge: None	Effluent Discharge Rate: None	

Comments: Human wastes for the camp (<10 persons) are deposited in two latrines on site.

Solid Waste: Back hauled off site

Owner/Operator: Peregrine Diamonds/ M&T

Landfill: None	Burn & Landfill: NA	Other: Bulk metals (Barrels)
----------------	---------------------	------------------------------

Comments: An expanded sump was recently dug on site. Records of waste shipped off site not available for review during inspection and will be forwarded. Letter of acceptance of wastes is required from the Municipality of Rankin Inlet.

FUEL STORAGE:. 45 gallon drums stored on site in secondary containment

Waste Oil Storage: None Owner/Operator: Peregrine Diamonds

Indicate: A - Acceptable U - Unacceptable NA - Not Applicable NI - Not Inspected

Berms & Liners: A	Water within Berms: NA	Evidence of Leaks: NI
Drainage Pipes: NA	Pump Station & Catchments Berm: S.C required for transfer areas.	
Pipeline Condition: NA	Condition of Tanks: None	

SURVEILLANCE NETWORK PROGRAM (SNP)

Samples Collec	Collected Owner /Operator: Not required		ot required by License
1		INAC: Potable water	
Signs Posted	SNP: none		Warning: None
Records & Reporting: Records of water usage were e-mailed following inspection. Backhauled waste and hazardous materials shipment records are to be provided and included in annual report.			
Geotechnical Inspection: N/A			

Non-Compliance of Act or Licence: The Inspector did not identify any inconsistencies with the terms of the current license.

A.Keim	Sent by E-mail	
Inspector's Name	Inspector's Signature	