




A = Acceptable
U = Unacceptable
N/A = Not applicable

N/I = Not inspected.

WATER USE INSPECTION REPORT

Date: 10 Aug 2008



Site: Siku Camp
Licence #: Cunder Amaruk Camp License

General Comments: (Continued)

- Company: Diamonds North
- Company Reps: Saz Yagtan (Project Geologist); Bill McDougall (Camp Mgr)
- * License must address before camp is allowed to ~~reopen~~ ^{reopen}
- ** Camp is located within 30m of high water mark / potable water source (U)
- No copy of water license or land use permit on site. (U)
 - No records kept on volume → flow meter not installed; volume not tracked for water usage at this camp or drills (reverse circulation). (U)
 - Fuel ^{spill} contingency plan is on site (A) ✓ → but does need to be updated; contact (info for ~~land~~ Resource Mgmt Officer and Water Resource Officer need to be ^{updated} ~~revised~~)
 ↳ copy is kept in kitchen (A) ↳ Licensee is to confirm how UV lamps are ^{disposed of} ~~disposed of~~ ^{and} ~~handled~~
 - No operation and maintenance manual / training provided for water treatment operator.
 - According to Camp Mgr - spill response training and awareness is provided through Amaruk Camp → to be confirmed by Licensee.
- Open burning is practiced → No open burning is permitted; Licensee must use an approved incinerator (U)
- Latrine used for toilet (Licensee is cautioned that latrine must be at least 30m from water)
- Lack of secondary containment for fuel drums; standing water in pools (U)
 used under valves of heating drums; spill kits on site (A)
- Entire area is susceptible to erosion and constant traffic → licensee is to address this issue before camp reopens next year.
- Grey water sump (A) Kitchen (A) (B) Dry (U) • Greywater is to be retained appropriately in a sump at least 30m from water. Highly Recommended that sump be relocated and both (A) & (B) contained in one sump.
- * Licensee is to address issues cited by Inspector before camp is permitted to reopen next season. Licensee is to provide a plan to the Inspector within 90 days ~~of opening~~.

Bill McDougall
Camp Manager

MEUSSA JOY
Water Inspector