



## INDUSTRIAL WATER USE INSPECTION REPORT

DATE: Aug 9, 2008

COMPANY REP.: Joe Kidman

LICENSEE: STORMWAY

LICENCE #: 236-SNO508

### WATER SUPPLY

Source: Uncontaminated Lake

Quantity Used: noted

Meter Rdg.: 51

Indicate:

A - Acceptable

U - Unacceptable

N/A - Not Applicable

Intake Facilities

A

Storage Structures

A

Treatment Systems

A

Recycling

Flow Meas. Device

A

Conveyance Lines

A

Pumping Stations

A

Modifications

/

Comments:

Lake is eutrophic, no sign of algal build up or sediment in Tanks. Meter installed. No issues noted.

### WASTE DISPOSAL

Tailings:

Tailings Pond ☐

Natural Lake ☐

Underground ☐

Sewage:

Sewage Treat. System ☐

Tailings Pond ☐

Natural Water Body ☐

Continuous Discharge ☐

Inter. Dischg. ☐

Solid Waste:

Open Dump ☐

Landfill ☐

Burn & Bury ☐

Underground ☐

Indicate:

A - Acceptable

U - Unacceptable

N/A - Not Applicable

Discharge Quality

\_\_\_\_\_

Conveyance Lines

\_\_\_\_\_

Disch. Meas. Dev.

\_\_\_\_\_

Freeboard

Decant Structures

\_\_\_\_\_

Pond Treatment

\_\_\_\_\_

Dams, Dykes

\_\_\_\_\_

Seepages

Dyke Inspections

\_\_\_\_\_

Runoff Diversion

\_\_\_\_\_

Erosion

\_\_\_\_\_

Spills

\_\_\_\_\_

Effluent Discharge Rate:

Samples Collected:

Comments:

Licensee ships waste to Town - Thibault -  
Sump from Kitchen and Dry continues to be an issue.  
Ground conditions are not conducive to a sump.

### GENERAL CONDITIONS

Indicate:

A - Acceptable

U - Unacceptable

N/A - Not Applicable

Ore & Waste Rock Stockpiles

/

Records & Reporting

A

Surv. Net. Prog.

/

Geotechnical Inspection

/

Posting, Signage

NA

Contingency Plan

/

Restoration Activities

/

New Construction

NA

Fuel Storage

/

Mine Water Discharge

/

Chemical Storage

NA

Annual Report

/

Comments:

Secondary containment is highly encouraged and  
required at places of fuel transfer and maintenance.

Violations of Act or Licence:

General Comments:

Camp is clean & well maintained. Secondary  
containment is required at maintenance and  
transfer areas. Storage of fuels should also have  
containment.

Page 2 attached ☐ Yes ☐ No

PROJECT GEOLOGIST

Licensee Representative's Title

A. Klein

Inspector's Name

JOE KIDMAN

Licensee Representative's Signature

[Signature]

Inspector's Signature