



Water Resources Division
Nunavut Regional Office
Iqaluit, NU
X0A 0H0

NWB File: 2BE-STO----
CIDMS #: 431248

Oct 14, 2010

Re: 2BE-STO---- – New Water Use License Application – Additional Information – Storm Project – Commander Resources Ltd.

Please be advised that Indian and Northern Affairs Canada (INAC) has completed a review of New Water Use License Application for water license 2BE-STO---- (Storm Project) submitted by Commander Resources Ltd. The NWB circulated the additional information for comments on Oct 4, 2010. All documents related to the application posted on the NWB ftp site under 2BE-STO---- were included in my review (See attached Technical Review Memo).

Should you have any questions or comments, please do not hesitate to contact me at (867) 975-4282 or by email at Ian.Parsons@inac.gc.ca.

Sincerely,

Original signed by

Ian Parsons
Water Resources Technician

Cc. Lou-Ann Cornacchio, Manager of Water Resources – Indian and Northern Affairs Canada, Nunavut Regional Office



Technical Review Memorandum

To: Phyllis Beaulieu – Manager of Licensing, Nunavut Water Board

From: Ian Parsons – Water Resources Technician, Indian & Northern Affairs Canada.

Re: 2BE-STO---- – New Water Use License Application – Additional Information – Storm Project – Commander Resources Ltd.

Recommendations/Comments

After reviewing the additional information submitted by Commander Resources, INAC has no comments with respect to the additional information.

INAC however reminds the proponent that the recommendations/comments submitted in a June 10, 2010 letter by INAC to the NWB are still required to be submitted to the NWB.

The recommendations/comments from the June 10, 2010 letter submitted by INAC to the NWB are listed below.

Abandonment and Restoration:

INAC recommends that the proponent submit to the NWB a 'stand-alone' Abandonment and Restoration Plan.

Spill Contingency Plan:

The proponent should identify by way of the Spill Contingency Plan, how accumulated contact water in the secondary fuel containment structure will be treated prior to discharge to the environment. Further, the plan should include a description of the sampling procedures the proponent will employ to verify that potentially contaminated contact water has achieved acceptable parameters for discharge (i.e, NWBs standard parameter of 15 mg/L oil and grease).

Commander Resources LTD. is required to provide the Nunavut Water Board all outstanding information referred to above in order to comply with the requirements of a new water license application for water license 2BE-STO----.



Cc. Lou-Ann Cornacchio, Manager of Water Resources – Indian and Northern
Affairs Canada, Nunavut Regional Office
Peter Kusugak, District Manager – Indian and Northern Affairs Canada,
Nunavut Regional Office