



P.O. Box 119  
GJOA HAVEN, NU X0B 1J0  
TEL: (867) 360-6338  
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓂᓪ  
NUNAVUT WATER BOARD  
NUNAVUT IMALIRIYIN KATIMAYINGI

---

File: NWB1ULU0008/TR/E1

November 8, 2005

*By Email and Regular Mail*

David Stevenson  
Project Manager, Ulu  
Wolfden Resources Inc.  
309 Court Street South  
Thunder Bay, ON P7J 1H1

**Subject: Wolfden Resources Inc. submission of a Spill Contingency Plan under Part E, Item 1**

Dear Mr. Stevenson;

The Nunavut Water Board ("NWB") would like to acknowledge receipt of the above document under Part E, Item 1 of Licence NWB1ULU0008. The document was distributed upon receipt for review and comment to interested persons with a submission deadline of July 26, 2005.

The NWB has taken into consideration the information submitted and hereby accepts and ***conditionally approves*** the Ulu Exploration Project, Spill Contingency Plan under the authority of the Chief Executive Officer dated November 8, 2005.

The Licensee shall provide, in an addendum to the Plan at the time of the next review (2005 Annual Report as per Part B, Item 5(i)), the following information and any other details that may have been determined at the time of the review:

- i. Preamble – within this section should be clear information on who the main person is that is in charge of the project with address, name, title and phone number. This is usually considered the corporate contact for the Company involved;
- ii. Again, within the preamble, should be clear information on the person responsible on site, with the name, title and 24-hour contact number; usually the project manager or designate when off-site;
- iii. Section 2.2 on Reporting – in addition to reporting to the NWT Spill Report Line, this section should include reporting the spill to the Water Resources Inspector in Iqaluit at 867-975-4298;
- iv. Figure 1 be revised to indicate reporting to the NWT Spill Report Line as well as the Water Resources Inspector, Iqaluit;
- v. Material Safety Data Sheets are a source of valuable information on the products being handled. Within Section 2.1 and 2.3, reference should be made to this information which should be available within an appendix. The detailed response or action plans contained in Section 7.0 make reference to the attached MSDS's for additional information, however they are not included within the Plan. The MSDS's are required to be current, within three years of the last revision.

- vi. Spill Kits – in addition to the SeaContainer containing spill response materials (location not identified), there should be spill kits, supplies and equipment available at all locations including the Camp 3 fuel tank farm. Additional information is required as to the capability of these spill response kits and if containers are available for transferring of liquid materials for storage/shipping as the containers identified with the spill kits are 45 gallon drums with ‘no lids’;
- vii. Sections 5.1 and 7.0 address the sewage system and the component response plan for the sewage system. These sections require additional information to address the issue of effluent quality under Part 3, Item 2 of the Licence. This may include general responses and actions with reference to the “Sewage Treatment and Solid Waste Disposal Facilities Operation and Maintenance Plan”, Section 3.4 and in the Appendix A, Section 7.2;
- viii. Section 7.0 – all Detailed Response Plans to be revised to include the notification of the Water Resources Inspector in Iqaluit;
- ix. Appendix 1 – The telephone listing be revised to include contact numbers for Nunavut where applicable. The Environment Canada contact number is 867-975-4644, the Environment Canada Emergency Response and Enforcement 24-hour pager number is 867-920-5131, the DIAND Water Resources Inspector is 867-975-4298, Government of Nunavut Department of Environment in Iqaluit is 867-975-5910 and 867-982-3204 in Kugluktuk, other numbers should be verified for Nunavut contacts;
- x. Table 1; be updated with current inventory, last updated September 4, 2004;
- xi. Table 3; the reference to Lupin be removed and include High Lake if appropriate;

Should you have any questions or require clarification on the above, please feel free to contact the undersigned at (780) 443-4406 or email [tech2@nwb.nunavut.ca](mailto:tech2@nwb.nunavut.ca) at your earliest convenience.

Yours truly,

*Original signed by:*

David Hohnstein, C.E.T.  
Technical Advisor Mining

Cc: Distribution list - Kitikmeot