



Hamlet of Arviat Water Licence Renewal and Amendment Application 3AM-ARV1016

Collins, Sarah <SCollins@gov.nu.ca>

Thu, Nov 19, 2020 at 8:03 AM

To: "Forté, Sarah (AADNC/AANDC)" <sarah.forte@canada.ca>, Richard Dwyer <richard.dwyer@nwb-oen.ca>, Licensing Department <licensing@nwb-oen.ca>

Cc: Assol Kubeisinova <assol.kubeisinova@nwb-oen.ca>, "Okonkwo, Godwin (AADNC/AANDC)" <godwin.okonkwo@canada.ca>, "EE Nord RPN NU / EA North PNR NU (EC)" <ec.eenordrpnnu-eanorthpnnu.ec@canada.ca>, "Hack, Justin (AADNC/AANDC)" <justin.hack@canada.ca>, "Shouldice, Atuat (AADNC/AANDC)" <atuat.shouldice@canada.ca>

Good Morning All,

I just received confirmation back from the consultant - the reference to the "overland discharge pipe" in the O&M manual is referring to the overland pipes between the pump houses (1 and 2) and the transition building. prior to entering the WTP. IN the drawing set, P-201, near the top of the page, you will see a couple sections of pipe that are called "insulated carrier pipes", these are the ones being referred to in the manual as being heat traced.

While not a mistake in the manual, they don't have the same title used between the manual and the drawings, which may have caused the confusion.

I hope this resolves this issue.

Thanks,

Sarah Collins, P. Eng
Municipal Planning Engineer

From: Forté, Sarah (AADNC/AANDC) <sarah.forte@canada.ca>

Sent: Tuesday, November 17, 2020 10:35 AM

To: Richard Dwyer <richard.dwyer@nwb-oen.ca>; Licensing Department <licensing@nwb-oen.ca>

Cc: Assol Kubeisinova <assol.kubeisinova@nwb-oen.ca>; Okonkwo, Godwin (AADNC/AANDC) <godwin.okonkwo@canada.ca>; EE Nord RPN NU / EA North PNR NU (EC) <ec.eenordrpnnu-eanorthpnnu.ec@canada.ca>; Hack, Justin (AADNC/AANDC) <justin.hack@canada.ca>; Shouldice, Atuat (AADNC/AANDC) <atuat.shouldice@canada.ca>; Collins, Sarah <SCollins@GOV.NU.CA>

Subject: RE: Hamlet of Arviat Water Licence Renewal and Amendment Application 3AM-ARV1016

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

[Quoted text hidden]

[Quoted text hidden]

Richard

