



P.O. Box 119  
GJOA HAVEN, NU X0B 1J0  
TEL: (867) 360-6338  
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᐱᓕᓂᓪᓴᓪ ᑲᑎᐱᓪᓴᓪ  
**NUNAVUT WATER BOARD**  
NUNAVUT IMALIRIYIN KATIMAYINGI

---

---

**File No: NWB3ARV0408**

Via Fax (867) 857-2519

August 4, 2004

Mr. Richard Van Horne  
Senior Administrative Officer  
Hamlet of Arviat  
P.O. Box 150  
Arviat, NU X0C 0E0

**Subject: Annual Report Requirement NWB3ARV0408**

Dear Mr. Van Horne:

The Nunavut Water Board (NWB) has reviewed the "Annual Water License Report No. NWB3ARV0408." documents submitted to the Board on May 10, 2004 in accordance with Part B, Item 1 of your water licence. The NWB herein approves the 2003/04 Annual Report as presented and thanks the Hamlet of Arviat for their submission.

It was noted in the review of the Annual Report submitted that the Hamlet does not currently have a Monitoring Plan in place for their solid waste and wastewater management facilities. The NWB reminds the Licensee that, in accordance with Part H, Item 2 of water license NWB3ARV0408, the Hamlet of Arviat is required to sample monthly at Monitoring Station ARV-2 and ARV-4 during the months of May to August, inclusive. The NWB, however, is aware of the challenges associated with developing, and implementing, such a sampling program. Accordingly, staff of the NWB will be contacting you within the next several weeks, to determine if we can assist you in developing, and implementing a Monitoring Plan, as is required by your water license.

Please contact the undersigned at (867) 360-6338 or e-mail Jim Wall (Technical Advisor, Municipal) at [tech1@nwb.nunavut.ca](mailto:tech1@nwb.nunavut.ca) if you have any questions.

Sincerely,

*Original Signed by:*

Philippe di Pizzo  
Executive Director