

July 29, 2021

Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU X0B 1L0

Attention: Richard Dwyer, Manager of Licensing

Re.: Response to CIRNAC Review of Chesterfield Inlet OM Manual for Transmission Line

Dear Mr. Dwyer,

Please take this letter in response to comments received from Crown-Indigenous Relations and Northern Affairs on the Water Supply Transmission Line Operation and Maintenance Plan.

1. CIRNAC Comment that Section 5.0 - Maintenance is missing from the document.
Response: While section 2.0 defines section 4.0 as Operations, and 5.0 as Maintenance, it appears this is a typo, as Maintenance is actually covered in Section 4.0, entitled Operation and Maintenance. In this section there are all maintenance items, including the items mentioned (pumping pad – 4.1.3; pipeline – various sections for flushing, draining, clogs, disassembly). Please confirm this responds to this question, if additional information is required, the Licensee will include it in the next submission of the Water Plant O&M Manual, currently in development.
2. CIRNAC Comment to include spill kit on any motorized boat on the drinking source.
Response: Noted. This will be added to the spill contingency plan.

Thank you for your consideration. Please do not hesitate to contact me with any questions or concerns.

Regards,

A. Collins

Sarah Collins, P. Eng.
A/Municipal Planning Engineer
Government of Nunavut
Community and Government Services
Phone: 867-975-5478
Email: scollins@gov.nu.ca