

Environmental Protection Operations Directorate
Prairie & Northern Region
5019 52nd Street, 4th Floor
P.O. Box 2310
Yellowknife, NT X1A 2P7

ECCC File: 6200 000 022/004
NWB File: 3AM-COR----



November 5, 2021

via email at: licensing@nwb-oen.ca

Richard Dwyer,
Manager Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU X0B 1J0

Dear Richard Dwyer

RE: 3AM-COR---- – Hamlet of Coral Harbour – Type A Water License Application – Applicant Responses

Environment and Climate Change Canada (ECCC) has reviewed the information submitted to the Nunavut Water Board (NWB) regarding the above-mentioned Type A Water License Application. ECCC has no further comments regarding the Licensee's responses to recommendations ECCC-02, -03, -04, -05, -06 and -07.

ECCC provides a follow-up comment/recommendation regarding ECCC-01:

If sludge accumulation becomes excessive, it could potentially lead to slower exfiltration and/or degraded effluent quality within the lagoon. ECCC recommends tracking exfiltration rates and effluent quality trends at the lagoon outlet to monitor for these potential changes.

ECCC's specialist advice based on our mandate pursuant to the *Canadian Environmental Protection Act* and the pollution prevention provisions of the *Fisheries Act*.

If you need more information, please contact Jennifer Sabourin at Jennifer.Sabourin@ec.gc.ca.

Sincerely,

Jennifer Sabourin
Environmental Assessment Officer

cc: Jody Small, Acting Head, Environmental Assessment North (NT and NU)

