



October 29, 2021

Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU X0B 1L0

Attention: Richard Dwyer, Manager of Licensing

RE: 3AM-GRA1624 –Government of Nunavut Community and Government Services – Municipality of Rankin Inlet – Annual Water Licence Report

Dear Richard,

The Government of Nunavut Department of Community and Government Services (CGS) has prepared a response to the follow-up comments submitted by Crown Indigenous Relations and Affairs Canada (CIRNAC) on the 2020 3AM-GRA1624 Annual Report.

Agency	Comment	Recommendation	CGS Response
CIRNAC	01	CIRNAC requests that a copy of the Chief Medical Health Officer's letter be provided to the NWB for publication on the public registry.	This document is unavailable. The licensee understands that the withdrawal amount was non-compliant under the terms of the previous licence and will make every effort to maintain compliance under the new licence.

CIRNAC	04	<p>Having conducted a search of the NWB FT site, CIRNAC cannot locate the drawings referred to in (a) and request that they be provided as soon as possible, drawings being referred to are “as built” installation/construction drawing signed and stamped by an Engineer registered in Nunavut, for the newly installed/constructed access road as well as for the newly installed pipeline.</p>	<p>This is a non-engineered road that was constructed by the Municipality in 2018. As such CGS does not have as-built drawings that it can provide to CIRNAC. The final dimensions of the extension are:</p> <p>Length: 143.26 m Width: 4.3-5.2 m Depth: 0.61-1.1 m</p> <p>The pipeline is a pipe overlain on the ground for the seasonal pumping and is not an engineered transmission line.</p> <p>This modification was reviewed during the technical meetings prior to issuing of the new license. This information should be available in the meeting transcripts and was provided in the 2018 amendment application prior to the work, then included again in the 2020 application prior to issuing of the new license and can be found on the FTP site in the following locations:</p> <p>ftp://ftp.nwb-oen.ca/registry/3%20MUNICIPAL/3A/3AM%20-%20Municipality/3AM-GRA1631/1%20APPLICATION/2020%20Amendment/200916%203AMGRA1624%20180214%20Diagram%20of%20Pipeline%20Extension%20to%20Lower%20Landing%20Lake-IMLE.pdf</p> <p>ftp://ftp.nwb-oen.ca/registry/3%20MUNICIPAL/3A/3AM%20-%20Municipality/3AM-GRA1631/1%20APPLICATION/2018%20Amendment/180214%203AM-GRA1624%20Diagram%20of%20Pipeline%20Extension%20to%20Lower%20Landing%20Lake-ILAE.pdf</p>
--------	----	--	---

Regards,



Elan Chalmers
Municipal Planning Officer
Government of Nunavut
Community and Government Services
Email: echalmers@gov.nu.ca