




- NOTES:**
1. ALL DIMENSION TO BE FIELD VERIFIED PRIOR TO FABRICATION.
 2. GRIND ALL RAW EDGES SMOOTH PRIOR TO INSTALLATION.
 3. COVER AND REMOVEABLE PLATE SHALL NOT IMPEDE THE OPERATION OR REMOVAL OF THE AUGER FROM THE CHANNEL.
 4. SUBMIT SCALED AND DIMENSIONED SHOP DRAWINGS FOR APPROVAL PRIOR TO EQUIPMENT PROCUREMENT AND INSTALLATION.
 5. HINGED COVER HANDLE TO BE MOUNTED ON SIDE WHERE ACCESS PLATFORM IS (TYPICAL). HANDLE LOCATION SHOWN ABOVE IS APPROPRIATE FOR EXISTING AUGER CHANNEL COVER. COVER ASSEMBLY FOR NEW AUGER CHANNEL WILL BE LOCATED ON THE OTHER SIDE.
 6. SLOTS MUST BE FIELD LOCATED AND CUT TO ACCOMMODATE ENTRY OF ULTRASONIC SENSOR CABLE AND SPRAY WASH ASSEMBLY INTO THE AUGER CHANNELS. SUBMIT DIMENSIONED SHOP DRAWING OF FIELD DETERMINED LOCATIONS TO ENGINEER FOR APPROVAL PRIOR TO INSTALLATION.



<p>1. This drawing is the exclusive property of Nuna Burnside and the reproduction of any part without prior written consent of this office is strictly prohibited.</p> <p>2. The contractor shall verify all dimensions, levels, and datums on site and report any discrepancies or omissions to this office prior to construction.</p> <p>3. This drawing is to be read and understood in conjunction with all other plans and documents applicable to this project.</p> <p>4. Do not scale the drawings.</p>	<p>Issue / Revision</p> <p>1 ISSUED FOR TENDER</p> <p>2 REVISED AS PER ADDENDUM 1 TO 4 AND ISSUED FOR CONSTRUCTION</p>	<p>Date</p> <p>FEBRUARY 2013</p> <p>APRIL 2013</p>	<p>PERMIT TO PRACTICE</p> <p>Nuna Burnside Engineering and Environmental Ltd.</p> <p>Signature: <i>[Signature]</i></p> <p>Date: <i>May 27/13</i></p> <p>PERMIT NUMBER: P 535</p> <p>The Association of Professional Engineers, Geologists and Geophysicists of NWT/NU</p>	<p>نونا بURNSIDE</p> <p>Nuna Burnside Engineering & Environmental LTD.</p> <p>106B Sourfield Blvd., Winnipeg, Manitoba</p> <p>telephone (204) 949-7110 fax (204) 949-7111</p> <p>web www.neeganburnside.com</p>	<p>Client</p> <p>GOVERNMENT OF NUNAVUT COMMUNITY & GOVERNMENT SERVICES</p> <p>RANKIN INLET SEWAGE TREATMENT PLANT</p>	<p>Drawing Title</p> <p>STRUCTURAL STAIR DETAILS AND AUGER CHANNEL COVER DETAILS</p>	<p>Drawn By</p> <p>C. GERUS</p> <p>Scale</p> <p>AS NOTED</p>	<p>Checked By</p> <p>M. STREIFLER</p> <p>Project No.</p> <p>300031281</p>	<p>Drawing No.</p> <p>S-9</p>