



PROP LAGOON ELEV

DEAD ZONE

1

3.0

0.60

2.00 TYP.

GABION MAT
1.0m x 3.0m
x 0.23m

CONCRETE BALLAST
BLOCK ON INLET
PIPE 2.0m c/c

150mmØ HDPE
INLET PIPE

ORIGINAL GROUND



1. CONTRACTOR TO SUBMIT SHOP DRAWINGS FOR CONCRETE BALLAST BLOCKS C/W REINFORCING.
2. CONTRACTOR TO USE 6.25mm THICK NEOPRENE SPONGE PADDING BETWEEN PIPE AND BLOCKS TO PREVENT CONTACT WIDTH TO BE 180mm.

CONCRETE BALLAST BLOCK
N.T.S

NOTES

THE POSITION OF ALL POLE LINES, CONDUITS, WATERMAINS, SEWERS AND OTHER UNDERGROUND AND OVERGROUND UTILITIES AND STRUCTURES IS NOT NECESSARILY SHOWN ON THE CONTRACT DRAWINGS, AND WHERE SHOWN, THE ACCURACY OF THE POSITION OF SUCH UTILITIES AND STRUCTURES IS NOT GUARANTEED. BEFORE STARTING WORK DETERMINE THE EXACT LOCATION OF ALL SUCH UTILITIES AND STRUCTURES AND ASSUME ALL LIABILITY FOR DAMAGE TO THEM.

ISSUED FOR
NWB REVIEW

[illegible]

DESIGNED BY

REVIEWED BY

CLIENT

GOVERNMENT OF NUNAVUT
DEPARTMENT OF COMMUNITY
AND GOVERNMENT SERVICES



exp Services Inc.
t: +1.613.686.1869 | f: +1.613.225.7337
2650 Queensview Drive, Suite 100
Ottawa, ON K2B 5H6
Canada
www.exp.com

• BUILDINGS • EARTH & ENVIRONMENT • ENERGY •
• INDUSTRIAL • INFRASTRUCTURE • SUSTAINABILITY

exp

DESIGN

IPV

CHECKED _____ CL _____

SL

IPN

PROJ. MAN

SL

WASTEWATER TREATMENT FACILITY
IGLOOLIK, NUNAVUT

DETAIL PLAN
PUMPING AND DEWATERING DETAILS

OTCD00019838.

SURVEY **exp**

42

DATE NOV 2014

NOV. 2014
DRAWING NO.

SIGNING NO. _____

100

IGL-6