

Pond Inlet, NU, X0A 0S0

ii

Letter of Transmittal

TABLE OF CONTENTS

1.0	INTRODUCTION.....	1
1.1	Background	1
1.2	Design Requirements.....	2
1.3	Service Conditions	2
	Population.....	2
	Water Consumption and Production Flow.....	3
	Water Quality.....	4
	Truck Fill Rates.....	4
1.4	CT Concept Calculation Review	4
2.0	Methodology.....	5
2.1	General Overview	5
2.2	Mechanical and Electrical	6
2.3	Structural.....	7
2.4	Building Envelope	7
2.5	Civil.....	7
3.0	Analysis.....	8
3.1	Water Treatment	9
3.2	Mechanical and Electrical	9
3.3	Structural.....	10
3.4	Building Code Analysis	10
3.5	Civil.....	11
4.0	Results (Proposed Facilities)	12
4.1	General.....	12
4.2	Mechanical and Electrical Systems	12
4.3	Building.....	12
	General	12
	Site Location.....	12
	Building Size.....	12
	Foundation.....	12
	Structural Systems	13
	Building Envelope.....	13
	Building Code Analysis.....	14
4.4	Civil.....	14
4.5	Mechanical and Electrical Systems	15
4.6	Site Location.....	15

Building Code Analysis.....	15
4.7 PIPELINE REPLACEMENT	15
5.0 CONCLUSIONS	17
6.0 LIMITATIONS OF LIABILITY	17
7.0 CLOSURE.....	17

LIST OF FIGURES

Figure 1 – Location of Igloolik, Nunavut.....	18
Figure 2 – Location of Existing Reservoir and Truck Filling Station	19
Figure 3 – Area Plan	21
Figure 4 – Site Plan.....	22
Figure 5 – Lower Level Floor Plan	23
Figure 6 – Upper Level Floor Plan	24
Figure 7 – West Elevation (Front)	25
Figure 8 – North Elevation (Side).....	26
Figure 9 – East Elevation (Rear).....	27
Figure 10 – South Elevation (Side)	28
Figure 11 – Building Section 1	29
Figure 12 – Building Section 2	30

LIST OF TABLES

Table 1 – Projected Water Usage and Factored Demand.....	20
--	----

APPENDICES

- Appendix A** – CT Concept Calculation Review
- Appendix B** – Mechanical and Electrical Engineering Design Development Report
- Appendix C** – Climatic Data
- Appendix D** – Seismic Data
- Appendix E** – General Terms & Conditions

1.0 INTRODUCTION

1.1 Background

The Government of Nunavut – Community and Government Services (GN-CGS) retained ARKTIS Piusitippaa Inc. (ARKTIS) to design an improved Water Supply System consisting of Water Truck Fill Station, Water Storage Reservoir, Intake Piping System, Piping Support System and Water Source for a design life of 20 years in the Municipality of Igloolik, Nunavut, which is located at 69°21'45" N latitude and 81°49'51" W longitude in the northwest region of the Foxe Basin within the Qikiqtaaluk Region of Nunavut approximately 860 km northwest of Iqaluit (see **Figure 1**). The location of the existing facility is shown in **Figure 2**.

The original scope of work included the cost-benefit analysis of three design options for the improvement of the Water Supply System in Igloolik. The options identified in the GN-CGS RFP were:

1. Expansion of the existing reservoir and construction of a new intake pump house and intake pipe line;
2. Expansion of the existing reservoir and refurbishment of the existing intake pump house and intake pipe line; and
3. Construction of a road leading to South Lake and construction of a new intake pump house at the lake.

Soon after the award of the design contract, the GN-CGS determined that the preferred design option was the expansion of the existing reservoir and construction of a new intake pump house and intake pipe line, and therefore analysis of the other two options was no longer required.

Concurrently with the development of this project, ARKTIS was also retained by the GN-CGS to complete the design of the water truck filling station in Pangnirtung, a community of similar population size, projected water demand, and with water also drawn from a reservoir.

In June 2013, the GN-CGS revised their requirements for both facilities; the current scope of work for the project is described in ARKTIS *Proposal for Consulting Services* dated 4 July 2013.

Given the similarities between the facilities and the identical requirements, the two facilities are presented as a repeat design with minor changes to account for site specific elements.

The design changes stipulated by the GN-CGS, in conjunction with the preliminary design work already completed by ARKTIS, obviated the need for another Schematic Design phase. This report therefore presents the results of the Design Development phase. As per the revised scope of work, this report contains the following:

- Methodology: a description of the design procedure;
- Analysis: a description of the engineering fundamentals relevant to the design; description of the design concept and how the system will function; discussion of the engineering parameters that were arrived at and how the design meets the requirements;
- Results: a description of the proposed design
- Conclusion: Summary of the results and conclusions; description of how the design meets the design goals; and
- Figures showing preliminary design drawings, and tables.

1.2 Design Requirements

On 10 June 2013 via email, and subsequently amended during a teleconference on 20 June 2013, the GN-CGS revised the design requirements for the new Water Truck Filling Station in Igloolik as follows:

1. Two intake pipes
2. Two truck fill arms
3. Chlorination calculations based on the CT approach, with the following stipulated values to be used in the calculations:
 - a. CT Value = 12 mg·min/L
 - b. Flow Rate = 1,000 L/min
 - c. Contact time = 12 minutes
 - d. A contact pipe to achieve the required chlorine contact time

1.3 Service Conditions

Population

The population of Igloolik in 2013 was estimated to be 1736 according to the Nunavut Bureau of Statistics. The estimated population of the community at the end of the 20 year design life of the proposed facility (from 2015 to 2035) is 2,397.

Water Consumption and Production Flow

1.3.1.1 Water Consumption Estimate

For estimating Community Water Use for Igloolik, population projections for the 20 year design life of the facility, from 2015 to 2036¹, were obtained from the Nunavut Bureau of Statistics.

For a total community population up to 2,000, the Total Community Water Use was estimated for each year of the facility design life using the following equation:

$$Volume (per\ capita) = Residential\ Water\ Use \times (1.0 + (0.00023 \times Population))^2$$

For a total community population over 2,000 the Total Community Water Use was estimated for each year of the facility design life using the following equation:

$$Volume (per\ capita) = Residential\ Water\ Use \times (-1.0 + (0.323 \times \ln(Population)))$$

For trucked water and sewer service, Residential Water Use (RWU) is 90 L³ per capita per day (lpcd) as per the GNWT Department of Public Works and Services document titled *Water and Sewage Facilities Capital Program: Standards and Criteria*. Note: this change in RWU is a decrease from the rate stipulated in the RFP, requested by the GN-CGS after review of the draft version of this document.

The above calculations assume that there are no water losses during the transfer of water through the pipeline connecting Water Lake to the water reservoir.

The estimated total annual community water consumption (demand) for the last year of the design life of the facility is 119,181 m³. The results of predicted water usage for each year of the design life of the facility are presented in **Table 1**.

¹ GN-CGS RFP Terms of Reference stipulated a design life from 2010 to 2030 with a growth rate of 3.64% and projected population in the year 2030 of 3,649; however, this was changed to a design period of 2015 to 2035, and variable growth rate according to the Nunavut Bureau of Statistics by the GN-CGS after submission of the Schematic Design Report.

² GNWT Department of Public Works and Services. *Water and Sewage Facilities Capital Program: Standards and Criteria*, July, 1993.

³ GN-CGS RFP Terms of Reference stipulated a RWU of 100 L; however, this was changed by the GN-CGS after the submission of the Schematic Design Report.

1.3.1.2 Production Flow Estimate

The GNWT Department of Public Works and Services *Water and Sewage Facilities Capital Program: Standards and Criteria* document also provides a method for determining the required production flow rate based on the predicted consumption rates for the community. For trucked systems a factor of 2.1 is applied to the design consumption rate to give the design production flow. This factor is made up of two components: (1) a maximum day demand factor of 1.5; and (2) a truck delivery factor of 7/5, based on water delivery five days per week.

The predicted production flow for the design horizon of the facility is 250,281 m³ per annum (or 685,700 L/day).

The results of estimated production flow for each year of the design life of the facility are also presented in **Table 1**.

Water Quality

The water dispensed by the new water truck filling station will meet the *Guidelines for Canadian Drinking Water Quality* (Health Canada, August 2012). The source water will be filtered to reduce turbidity to less than 0.1 NTU and will undergo chlorine disinfection prior to entering the delivery vehicles. The Nunavut Health regulations stipulate a minimum residual chlorine concentration of 0.2 mg/L.

Truck Fill Rates

A minimum truck filling rate of 1,000 L/min will be provided for both firefighting demand and regular consumption demand.

1.4 CT Concept Calculation Review

As noted above, the parameters for the determination of adequate treatment of drinking water according to the CT Concept described in Part 1 of the *Standards and Guidelines for Municipal Waterworks, Wastewater and Storm Drainage Systems* (Government of Alberta, April 2012) have been stipulated by the GN-CGS. The values specified by the GN-CGS were reviewed and verified by ARKTIS in a separate document submitted 2 August 2013 (a copy of the Technical Memorandum covering the CT Concept Calculation Review is provided in **Appendix A**)

2.0 METHODOLOGY

2.1 General Overview

As noted above, the GN-CGS has stipulated a baffling factor of 1.0 for the chlorine contact chamber required as part of the truck filling station design. A baffling factor of 1.0 assumes ideal plug flow conditions. In order to approach this condition, a contact chamber must have a very high length to width ratio, which is most easily achieved in a pipe. Consequently, the requirement for a baffling factor of 1.0 equates to a requirement for a contact pipe design. It is from this point, therefore, that the re-design of the water truck filling station began.

From the CT Concept calculations a contact vessel volume was derived. The maximum diameter of pipe possible with which the pipe would still exhibit plug flow behavior was determined, in order to allow for the shortest possible contact pipe. This would in turn allow for the minimization of the overall building footprint.

Once the pipe length and diameter were determined, the mechanical engineer worked with the structural engineer to develop a pipe layout and building floor plan that would allow the building size to be kept to a minimum.

From the final pipe layout arrived at, structural loads were determined in order to design the foundation and size the structural members. To facilitate uninterrupted truck filling at two truck fill arms, the CT pipe is sized to carry 15,000L of water. Based on the volume of water alone, the approximate weight of the CT pipe is 15,000 kg (147 kN) or 33,070 lbs. Given the magnitude of this weight, ARKTIS is proposing to locate the CT pipe on a solid slab on grade, rather than suspending the CT pipe from the roof of the steel structure and expecting the steel members to carry the load back down to the slab as larger concentrated loads. To facilitate the placement of the CT pipe on the slab on grade, ARKTIS is proposing an elevated "main floor" for the truck fill main operating area where the chlorination room will be located as well as the filters, electrical panels, and access to the intakes pipe ends and pumps. The back-up generator will be located in a separate room, directly on the slab on grade.

The selection of structural steel framing for the structural system was carried over from the design of the Pangnirtung Water Truck Filling station. A concrete slab on grade was selected to support the weight of the 15,000L contact pipe. The perimeter of the slab on grade is thickened to support concentrated loads from the steel framing.

The building envelope is proposed to be fully located on the outside of the structural members, which is the best configuration to allow for continuous air, thermal and vapour barriers without interruption from structural members. Exterior steel cladding, mineral fibre insulation and interior steel liner are proposed for the wall assembly and the exterior roof panels, bearing on compression resistance rigid insulation, self-adhered air/vapour barrier on gypsum, all bearing on steel deck. These assemblies were selected since they best suit a structural steel industrial type building.

2.2 Mechanical and Electrical

The water delivery process of the truck fill station can be broken down to several building blocks that make up the complete system. These building blocks are:

- Pumping;
- Filtering;
- Chlorination;
- Water reservoir;
- Delivery system to trucks;
- Emergency power; and
- Controls and auxiliary equipment.

The design of each of these building blocks was derived from Government of Nunavut guidelines, applicable Codes and followed up by consultations with potential providers of specialized technologies. The final review and comments were provided by Government of Nunavut representatives.

See **Appendix B** for the full mechanical and electrical engineering sub-consultant Design Development report.

2.3 Structural

Structural design is completed by the structural design engineer using the National Building Code of Canada 2010, Part 4 – Structural Design, the National Building Code of Canada Structural Commentaries, climatic and seismic data specific to Igloolik, NU and limit states design to size the structural members and foundations considering both strength and serviceability. Methods of structural analysis used include hand calculations using formulas derived from accepted first principals to establish stresses on members (primarily for gravity loads such as the weight of the building and use and occupancy loads); also, more detailed finite element analysis is applied through the use of computer software to determine resulting stresses from both gravity and lateral loads (wind and seismic loads).

2.4 Building Envelope

Given that the truck fill building would require limited human use and requirement for human comfort, thermal performance was selected based on a percentage of the recommended RSI values from the Government of Nunavut *Good Building Practices Guideline* (GN-GBP) which are RSI 7.0 for roofs, RSI 4.9 for walls and RSI 7.0 for floors. Life cycle cost benefit analysis has not been performed. In keeping with recommendations from the GN-GDP, materials were selected for their durability and ease of repair. For example, the sheet steel cladding selected is a durable construction material and exposed fastener type cladding will be used to allow for easier removal and replacement compared to hidden fastener systems.

2.5 Civil

The civil engineering for the new facility is comprised of three parts: (1) the building site itself; (2) the truck turnaround area; and, (3) the water supply pipeline connecting the pumping station at Water Lake to the reservoir.

Major site grading will not be required for the new water truck filling station as the proposed location of the new facility is immediately south of, and adjacent to, the existing facility, where a granular base already exists. Minor grading may be required to provide a level foundation surface. Typical details for site grading will be provided for the 50% Construction Documents submission.

The truck turnaround area will require expansion laterally to allow for the simultaneous filling of two vehicles side-by-side. The geometry required to accommodate this scenario was assessed and a new

area will be designed, including a typical section for the turnaround pad. A terrain model will be developed using proprietary software to verify the site surface water drainage.

As per instructions provided by the GN-CGS, the pipeline connecting the pumping station at Water Lake to the existing reservoir is to be replaced. The design of the replacement involves selection of the pipe size based on the flow rate and pressure and is accomplished in coordination with the pipe manufacturer. The manufacturer provides recommendations for the pipe size, length of sections, fittings, granular bedding, and lateral restraint, based on the parameters provided.

There are two locations where the pipeline will cross underneath the access roads. HDPE pipe is sufficiently strong to be placed directly within the road embankment. A typical section will be developed detailing the installation of the pipeline through the roadways for the 50% Construction Documents stage.

3.0 ANALYSIS

3.1 Water Treatment

As stipulated by the GN-CGS, the design of the disinfection system for the water truck filling station follows the CT Concept in order to demonstrate the level of treatment that will be achieved, using chlorine as the disinfection agent. The CT Concept stems from the observation that, in order to be effective as a disinfectant, chlorine must be given enough time to react with the microorganisms present in the water to be treated. The concept was developed with the assumption that most suppliers of potable water would need to inactivate cysts and oocysts (i.e. Giardia) and viruses. The basic equation is:

$$CT = \text{Concentration} \times \text{Time}$$

Where the concentration of residual chlorine is in mg/L and the time the water is in contact with the chlorine is in minutes. CT is also influenced by both the pH and the temperature of the source water.

The Government of Alberta *Standards and Guidelines for Municipal Waterworks, Wastewater and Storm Drainage Systems* (April 2012) sets standards for the removal of both viruses and cysts/oocysts as percentages of the reduction of these organisms (e.g. 99.99% reduction is equivalent to 4-log reduction). The standard also provides a series of tables which relate temperature, pH, and residual chlorine concentration. The CT value required to meet the removal standards is derived from the tables. From required CT value, the residual chlorine is determined. The desired contact time can then be determined by varying the volume and type of the contact vessel.

For the Igloolik water truck filling station, these parameters (such as contact vessel volume and type) have been specified by the GN-CGS (for a more detailed description and discussion of the CT calculations see **Appendix A**).

3.2 Mechanical and Electrical

The mechanical and electrical engineering sub-consultant Design Development report in **Appendix B** provides the engineering analysis for these systems with respect to the design of the water truck filling station.

3.3 Structural

According to the National Building Code of Canada 2010 (NBCC 2010), design of structures must be completed using Part 4 – Structural Design. Within Part 4 of the NBCC 2010 loads for snow, wind and seismic can be determined through the use of climatic data for the 50 year return period. Appendix C of the NBCC 2010 provides climatic data for a specific city or town within each of the provinces. However, there is no data provided for Igloolik, NU within the appendix. As such, and in conformance with the NBCC 2010, ARKTIS contacted the Atmospheric Environmental Service, Environment Canada (AES-EC) to obtain climatic data for Igloolik. To facilitate the AES-EC provision of climatic data, ARKTIS supplied the following coordinate and elevation data: 69°21'45" N, 81°49'51" W, 54 m above sea level which relates to the location of the existing truck building. The information requested pertained to the 1 in 50 year ground snow load (S_s), associated rain load (S_r), and the reference wind velocity (q). Refer to **Appendix C** for climatic data results.

To undertake seismic design, the spectral response acceleration values were obtained from the Geological Survey of Canada of Natural Resources Canada, specifically from the Natural Resources of Canada website, www.EarthquakesCanada.ca. Again, the coordinates 69°21'45" N, 81°49'51" W were used at the NRC website to generate the seismic data through interpolation between seven points within a 10km radius of the coordinates. The resulting information provides data for the following parameters: $S_a(0.2)$, $S_a(0.5)$, $S_a(1.0)$, $S_a(2.0)$ and PGA. These parameters represent NBC 2010 ground motions for 2% probability of exceedence in 50 years. Refer to **Appendix D** for seismic parameter results.

Within subsections of the NBCC 2010 Part 4, equations are provided to determine the snow, wind and seismic loads to be applied to the building being designed. In addition, the National Building Code Structural Commentary is used to determine distribution of snow and wind on the building surfaces.

Limit states design is the method of analysis required by the NBCC 2010 and used by ARKTIS for design of the structure.

3.4 Building Code Analysis

Using Part 3 of the National Building Code of Canada, ARKTIS determined the building classification (major occupancy classification) and occupancy load for the new truck fill station. As well, based on the building classification the requirement for use of combustible or non-combustible construction is determined. Occupancy load determines the number and size of exits from the truck fill space.

3.5 Civil

The existing water supply pipeline connecting the pump house at Water Lake to the water reservoir is made up of 150 mm diameter HDPE pipe sections approximately with mechanical couplings spaced at approximately 35 m intervals.

High Density Polyethylene (HDPE) pipe is relatively lightweight, tough, and durable, virtually corrosion proof, with a high resistance to breakage due to freezing and low frequency of repairs required, when compared to alternative pipe choices. These facts, coupled with the longer lengths possible (thereby minimizing the number of fittings required) make HDPE pipe the optimum choice for the replacement of the supply pipeline.

Although it is anticipated that the pipeline will only be used once per year to fill up the reservoir, the replacement line will remain in place year-round. The pipeline will therefore be empty for most of the year. For an empty HDPE pipe, with a seasonal temperature change of 60°C, the pipe can be expected to move laterally by as much as 0.8 m with lateral restraints spaced every 15 m.

A continuous grade must be maintained from the high point at the reservoir down to the pumping station at Water Lake in order to ensure that water drains from the pipeline when it is not in use. A pipe bed constructed of gravel or crushed rock will be required to support the pipe, and to ensure a smooth grade for the length of the pipeline. Pipe joints can either be fused or flanged mechanical connections. Although fused joints allow for essentially leak proof connections, for pipeline lengths greater than 300 m, the fusion procedure may become unmanageable, making flanged mechanical connections more desirable.

4.0 RESULTS (PROPOSED FACILITIES)

4.1 General

The following sections summarize the water supply system, water treatment system, building, and building services for the proposed water truck filling facility. **Figure 5** through **Figure 12** at the end of this report illustrate preliminary plans, elevations, and sections for the building.

4.2 Mechanical and Electrical Systems

The mechanical and electrical engineering sub-consultant Design Development report in **Appendix B** describes the proposed mechanical and electrical systems with respect to the design of the water truck filling station.

4.3 Building

General

The new water truck filling station will accommodate water filtration and disinfection equipment, and incorporates separate rooms for an emergency diesel generator and chemical handling/laboratory room. The building contains all service equipment necessary to operate the building and to draw water from the existing reservoir and deliver it to water trucks via two (2) parallel fill arms for simultaneous filling. A preliminary plan, elevation, and section are provided at the end of this report.

Site Location

The new truck fill station will be located along the east side of the existing access road, south of the existing truck fill station. Water trucks will travel along the existing access road as normal, turn around at the existing roundabout, and drive up to the new station, parking under an unoccupied fill arm. Trucks can park adjacent to one another for simultaneous filling.

Building Size

The exterior dimensions of the building are 7.9 m by 12.6 m.

Foundation

The foundation is an insulated concrete slab-on-grade. The underside of the slab is insulated to protect the permafrost from the heated structure above.

Structural Systems

4.3.1.1 Floor

The main floor of the 1-storey building consists of the finished concrete surface of the slab-on-grade.

4.3.1.2 Walls and Roof

The primary structure of the walls and roof is comprised of a pre-engineered steel moment and braced frames that will resist both gravity and lateral loads. The secondary structure supports the exterior cladding and is framed using cold-formed steel girts and purlins connected to the structural frames of the building, adding to the overall structural capacity of the building system. A mono-sloped roof sheds rain, snow and ice to the rear of the building avoiding disruption of filling operations and to preventing accidental injuries to workers.

Building Envelope

4.3.1.3 Walls

The wall envelope will consist of exterior sheet steel cladding over two layers of mineral fibre insulation with interior sheet steel liner panels. All joints are sealed allowing the interior panels to serve as the envelope's air and vapour control membranes. The panels are connected on the exterior of the steel structural framing. Insulation provides an RSI of 4.44.

4.3.1.4 Roof

The roof envelope is similar to the wall envelope described above. Exterior sheet steel roofing panels over two layers of mineral fibre insulation with interior sheet steel liner panels. The panels are connected on the exterior of the steel structural framing. Insulation provides an RSI of 5.92.

4.3.1.5 Floor Plan Layout

In order to minimize the area taken up by the chlorine contact pipe, the building has been divided into two levels and three rooms. The largest room is comprised of two parts, a lower crawlspace level (63.4 m²) occupied by the 15,000 L serpentine chlorine contact pipe, and a pump room on the upper main level with a grated floor (48.8 m²) occupied by the pumping and piping equipment. The other two rooms consist of a generator room (29.3 m²) at the level of the main concrete floor, and a chlorination room (14.6 m²) for chemical handling and storage built on top of the crawlspace.

The generator room is provided with its own exterior access and will houses the generator only. The pump room is also provided with an exterior access and contains the pumps, filters, truck fill arm plumbing, and electrical and service equipment. The chlorination room is accessed via the pump room and contains the chlorine mixing equipment.

The generator room entrance can be accessed at ground level, while the pump room is accessed via a short stairway.

The two fill arms protrude from the front elevation of the building and are supported by a structural steel frame perpendicular to the building.

The front elevation is protected from vehicular impact by a series of concrete filled steel bollards.

Building Code Analysis

As indicated above, NBCC 2010, Part 3, Table 3.1.2.1. was used to determine that the new truck fill building will be classified as a low-hazard industrial occupancy (Group F, Division 3). According to the NBCC 2010, Volume 1, Division A, Part 1, Section 1.4, “low hazard industrial occupancy means an industrial occupancy in which the combustible content is not more than 50 kg/m² or 1200MJ/m² of floor area. The same code section also indicates that an “industrial occupancy means the occupancy or use of a building or part thereof for the assembling, fabricating, manufacturing, processing, repairing or storing of goods and materials”. The above definitions suit the intended use of the new truck fill station. Based on the occupancy type (industrial) and the use, ARKTIS used Table 3.1.17.1. to determine the occupant load for the new truck fill building. The most appropriate floor use for the truck fill building is the area per person of 9.30m² which is for industrial uses, storage spaces. Based on the space within the operational area of the truck fill building (approximately 61.2 m²), the occupant load is 7 people.

4.4 Civil

The preliminary work for the truck turnaround area could not be completed at this time. A preliminary area plan (**Figure 3**) and a preliminary site plan (**Figure 4**) are provided at the end of this report.

4.5 Mechanical and Electrical Systems

The mechanical and electrical engineering sub-consultant Design Development report in **Appendix B** provides the engineering analysis for these systems with respect to the design of the water truck filling station.

4.6 Site Location

The proposed truck fill station will be located along the south side of the existing access road, south of the existing truck fill station. Water trucks will travel along the existing access road as normal, turn around at the existing roundabout, and drive up to the new station, parking under an unoccupied fill arm. Trucks can park adjacent to one another for simultaneous filling.

Building Code Analysis

As indicated above, NBCC 2010, Part 3, Table 3.1.2.1. was used to determine that the new truck fill building will be classified as a low-hazard industrial occupancy (Group F, Division 3). According to the NBCC 2010, Volume 1, Division A, Part 1, Section 1.4, “low hazard industrial occupancy means an industrial occupancy in which the combustible content is not more than 50 kg/m² or 1200MJ/m² of floor area. The same code section also indicates that an “industrial occupancy means the occupancy or use of a building or part thereof for the assembling, fabricating, manufacturing, processing, repairing or storing of goods and materials”. The above definitions suit the intended use of the new truck fill station. Based on the occupancy type (industrial) and the use, ARKTIS used Table 3.1.17.1. to determine the occupant load for the new truck fill building. The most appropriate floor use for the truck fill building is the area per person of 9.30m² which is for industrial uses, storage spaces. Based on the space within the operational area of the truck fill building (approximately 61.2 m²), the occupant load is 7 people.

4.7 PIPELINE REPLACEMENT

For a flow rate range of 1,000 L/min to 1,450 L/min, the pipe pressure will be between approximately 100 kPa and 200 kPa. For a 1,800 m long pipe, approximately 120 pipe sections (each approximately 15 m long) will be required.

The pipeline route will require a pipe bed of gravel or crushed rock to support the weight of the pipe and the limited traffic along the pipeline length (for maintenance operations). The pipe bed should be at least 1 m thick with 1:1 side slopes with a top width of at least 2.0 m.

The pipeline must be restrained laterally at intervals to minimize seasonal movement due to thermal expansion and contraction. Lateral restraints can be in the form of strategically placed granular berms placed over top of the pipe at locations where the pipe bends. The typical berm will have 2:1 side slopes and cover the pipe by at least 0.5 m of granular material. Lateral restraints will be required at intervals of approximately 15 m along the length of the pipeline.

As noted above, there are two locations where the pipeline will cross underneath the access roads. HDPE pipe is sufficiently strong to be placed directly within the road embankment. A typical section will be developed detailing the installation of the pipeline through the roadways for the 50% Construction Documents stage.

5.0 CONCLUSIONS

This report presents the Design Development submission for the new Igloolik water truck filling station (GN-CGS Project 10-2005), in accordance with the revised scope of work described in ARKTIS *Proposal for Consulting Services* dated 4 July 2013. A design solution addressing the GN-CGS requirements of a chlorine contact pipe designed according to the CT Concept, and including two intake lines from the reservoir, and two water delivery arms, has been presented. Design parameters have been determined and design calculations completed, in coordination with all engineering disciplines involved. The design methodology has been explained, a design analysis presented, and the proposed facilities have been described.

6.0 LIMITATIONS OF LIABILITY

This report has been prepared for the exclusive use of the Government of Nunavut, Department of Community & Government Services for the specific application described in Section 1.0 of this report. It has been prepared for information purposes only. No other warranty is made, either expressed or implied. For further limitations, please refer to the General Conditions provided in **Appendix E**.

7.0 CLOSURE

We trust that this report meets your present requirements. Please contact the undersigned should there be any questions.

ARKTIS SOLUTIONS INC.

ORIGINAL SIGNED BY



Matthew Hamp
VP Nunavut Affairs & Operations




Figure 1 – Location of Igloolik, Nunavut



Table 1 – Projected Water Usage and Factored Demand

Facility Year	Calendar Year	Estimated Population ^A	Water Use	Projected Water Use ^B	Factored Daily Demand ^C
			(lpcd)	(L/day)	(L/day)
0	2015	1,784	126.93	226,441	475,526
1	2016	1,811	127.49	230,880	484,848
2	2017	1,839	128.07	235,516	494,583
3	2018	1,867	128.65	240,184	504,386
4	2019	1,894	129.21	244,716	513,903
5	2020	1,922	129.79	249,448	523,840
6	2021	1,949	130.34	254,041	533,486
7	2022	1,976	130.90	258,665	543,196
8	2023	2,005	131.03	262,717	551,705
9	2024	2,035	131.46	267,526	561,805
10	2025	2,067	131.92	272,671	572,608
11	2026	2,098	132.35	277,668	583,103
12	2027	2,129	132.78	282,679	593,625
13	2028	2,161	133.21	287,865	604,516
14	2029	2,193	133.64	293,064	615,435
15	2030	2,226	134.07	298,441	626,726
16	2031	2,260	134.51	303,995	638,390
17	2032	2,294	134.95	309,564	650,085
18	2033	2,329	135.39	315,312	662,156
19	2034	2,364	135.82	321,076	674,260
20	2035	2,397	136.22	326,524	685,700

Notes:

^A Population data projections were provided by Nunavut Bureau of Statistics

^B For Population ≤ 2,000, Total Water Use = Residential Water Use × (1.0 + (0.00023 × Population))

For Population > 2,000,

Total Water Use = Residential Water Use × (-1.0 + (0.323 × Ln(Population)))

as recommended in GNWT Water and Sewage Facilities Capital Program: Standards and Criteria, July 1993.

^C Factored demand = Projected Use X 2.1 (Max day demand factor 1.5 X truck delivery factor 7/5)

Residential Water Use is 90 lpcd.




Figure 3 – Area Plan




Figure 4 – Site Plan




Figure 5 – Lower Level Floor Plan




Figure 6 – Upper Level Floor Plan




Figure 7 – West Elevation (Front)




Figure 8 – North Elevation (Side)




Figure 9 – East Elevation (Rear)




Figure 10 – South Elevation (Side)




Figure 11 – Building Section 1




Figure 12 – Building Section 2

APPENDIX A – CT CONCEPT CALCULATION REVIEW

TECHNICAL MEMORANDUM

File:	004-GNCGS – Pangnirtung Water Reservoir
To:	Government of Nunavut – Department of Community and Government Services (GN-CGS)
Attention:	Mr. Jon Cooper, Project Officer
Subject:	GN-CGS Project #08-2009 – CT Concept Calculation Review
Author:	Mr. Matthew Hamp
Page Total:	7
Date:	2 August 2013

1.0 Introduction

As directed by the Government of Nunavut – Department of Community and Government Services (GN-CGS), the disinfection system for the proposed new water truck filling station in Pangnirtung is to be designed according to the CT Concept¹ using the following design parameters:

- i. CT Value = 12 mg·min/L
- ii. Baffling Factor, $T_{10}/T = 1.0$
- iii. Flow Rate = 1,000 L/min
- iv. Contact time = 12 minutes

In accordance with the 3 July 2013 ARKTIS *Scope of Professional Services*, the CT Concept calculations were to be completed in order to confirm the GN-CGS stipulated parameters and assumptions and to identify any discrepancies or issues of concern. This technical memorandum presents the results of this exercise.

2.0 Methodology

2.1 Overview/Summary

The methodology followed for determining the total log reduction of viruses and cysts/oocysts by filtration and disinfection, and for determining the size of the chlorine contact chamber required to achieve these disinfection rates, is that presented in Part 1 of the *Standards and Guidelines for Municipal Waterworks, Wastewater and Storm Drainage Systems* (Government of Alberta, April 2012).

¹ *Standards and Guidelines for Municipal Waterworks, Wastewater and Storm Drainage Systems* (Government of Alberta, April 2012)



ARKTIS SOLUTIONS INCORPORATED

:: 3962 Harrowsmith Road :: Harrowsmith, ON:: K0H 1V0 ::
:: Phone: 867.446.4129 :: Fax 866.475.1147 ::

This document prescribes performance standards for the treatment of potable water from a surface water source, as follows:

- i. All waterworks systems shall be provided with filtration and disinfection;
- ii. For new systems, filtration and disinfection together shall achieve a minimum of 3-log reduction of *Giardia* and *Cryptosporidium*, and 4-log reduction of viruses, until a source water assessment is completed² (note: if a source water assessment is not completed, the system must achieve 5.5-log reduction of *Giardia* and *Cryptosporidium*, and 4-log reduction of viruses);
- iii. For a system equipped with membrane filtration (the most likely scenario in the case of the Pangnirtung Water Truck Filling Station), the treated water turbidity levels from individual filter trains shall be less than or equal to 0.1 NTU at all times, and particle counts (particles greater than 2 µm) from individual filter trains shall not exceed an absolute value of 20 particles/mL³;
- iv. Disinfection shall be sufficient to:
 - o inactivate the pathogens not removed by clarification and filtration, and achieve the level of cysts / oocysts reduction as stipulated in Table 1.1 (of the standard);
 - o inactivate viruses and achieve the level of virus reduction as stipulated in Sections 1.2.1 (of the standard); and
 - o maintain a minimum total chlorine residual of 0.2 mg/L in the water distribution system.

The standard also specifies the use of the CT disinfection concept to demonstrate satisfactory treatment of potable water.

The standard allows for potable water treatment credits to be applied to the calculation of treatment effectiveness for filtration and disinfection provided the treatment methods can be shown to meet certain prescribed limits. The credits would normally be granted by the Government of Alberta Ministry of Environment and Sustainable Resource Development and would therefore be applicable to projects in Alberta only. In the case of Nunavut, since there is no government body mandated to issue these credits and the Alberta standard has not been officially adopted by The Government of Nunavut, a case for applying log reduction credits for filtration is presented herein.

² As stipulated in the standard, systems serving a population of less than 10,000 shall first monitor raw water for *E.coli* at least every two weeks for a period of one year. Per the standard, no cysts and oocysts monitoring is required if the source reservoir has an average *E.coli* concentration of less than 10/100 mL, based on all of the samples in the one year period. Should the raw water sample results exceed this standard, monitoring for cysts and oocysts is required at least four times per year for a period of two years.

³ Based on continuous monitoring at a minimum of five minute intervals



ARKTIS SOLUTIONS INCORPORATED

:: 3962 Harrowsmith Road :: Harrowsmith, ON:: K0H 1V0 ::
:: Phone: 867.446.4129 :: Fax 866.475.1147 ::

2.2 Reduction of Cysts and Oocysts

For the reduction of cysts and oocysts, *Giardia* and *Cryptosporidium* are identified in the standard as the organisms of concern to be addressed during treatment. For membrane filtration systems, credits would only be applied based on product specific challenge testing and verified by direct integrity testing of the membrane, as described in the latest edition of the USEPA Membrane Filtration Guidance Manual. Membrane cartridge filters, such as Harmsco LT2 Pleated Cartridges, are independently certified by NSF International (an independent, not-for-profit organization that provides product certification for products related to public health and the environment) to provide 3.6-log reduction of cyst-sized particles. Since the Alberta standard stipulates a minimum of 3-log reduction of cysts/oocysts, the use of this type of independently certified membrane filter is sufficient to provide the required reduction for these organisms.

2.3 Reduction of Viruses

For the reduction of viruses, some form of disinfection is required. Options for disinfection include chlorination (free chlorine), ultraviolet (UV) light, chlorine dioxide, and ozone. In addition to the inactivation of viruses, the disinfection system must provide a residual chlorine concentration in the treated water, according to both the Alberta standard and the Nunavut Public Health Regulations.

Chlorination meets the requirements of both disinfection and maintaining a residual chlorine concentration in the treated water, while at the same time greatly simplifying the treatment system by accomplishing these two requirements with one sub-system (i.e. chlorination). All other options require multiple systems to achieve the same goals.

The Alberta standard stipulates the use of the CT concept to calculate the contact time necessary to provide a 4-log inactivation of viruses. The following section sub-section details the CT concept calculations.

2.3.1 CT Concept Calculations

According the Alberta standard “the CT concept uses the combination of disinfectant residual concentration (mg/L) and the effective disinfection contact time (in minutes) at maximum hourly flows to measure effective pathogen reduction.” The basic equation is:

$$CT = \text{Concentration} \times \text{Time}$$

Where, the concentration of residual chlorine is in mg/L and the time the water is in contact with the chlorine is in minutes.

This equation can be modified to calculate the actual CT_{achieved} as follows:



ARKTIS SOLUTIONS INCORPORATED

:: 3962 Harrowsmith Road :: Harrowsmith, ON:: K0H 1V0 ::
:: Phone: 867.446.4129 :: Fax 866.475.1147 ::

$$CT_{\text{achieved}} = \text{Concentration} \times \text{Time} \times T_{10}/T_{\text{MIN}}$$

Where, T_{10}/T_{MIN} is the baffling factor, which is the ratio of the time it takes 10% of a unit of water to move through a contact vessel and the minimum time it takes for the entire unit of water to pass through the same contact vessel. The baffling factor is an indication of the mixing efficiency of a given contact vessel.

T_{MIN} can also be expressed as follows:

$$T_{\text{MIN}} = \frac{\text{minimum volume of water in the contact vessel (L)}}{\text{maximum flow rate (L/min)}}$$

The GN-CGS has stipulated that the CT calculations for the disinfection system must use the following values:

- i. CT Value = 12 mg·min/L
- ii. Baffling Factor, $T_{10}/T = 1.0$
- iii. Flow Rate = 1,000 L/min
- iv. Contact time = 12 minutes

Note: a Baffling Factor of 1.0 assumes a perfect baffling condition (i.e. ideal plug flow), which entails a very high length to width ratio, perforated inlet and outlet, and intra-vessel baffles. This condition can be represented by a water pipeline with no mixing and no short-circuiting, wherein a unit of water moves through the vessel from the inlet to the outlet across the entire cross-section of the vessel for the entire length of the vessel.

The following calculations are presented to verify that these values can indeed be used to demonstrate effective disinfection treatment to the virus and cyst/oocyst reduction levels stipulated by the standard.

What we know (in addition to the above-noted GN-CGS stipulated values):

- i. The water temperature most likely to be encountered throughout the course an operational year is 0.5°C or less. Given that there are insufficient water temperature records available and given the arctic climate in which the facility will operate, it must be assumed that for most of any given operational year, the source water will be near freezing. The effectiveness of chlorine as a disinfection agent in water is directly proportional to the temperature of the water, and therefore this is a conservative assumption;



ARKTIS SOLUTIONS INCORPORATED

:: 3962 Harrowsmith Road :: Harrowsmith, ON:: K0H 1V0 ::
:: Phone: 867.446.4129 :: Fax 866.475.1147 ::

- ii. The pH of the source water will be within the range of 6.5 to 7.0⁴; and
- iii. The minimum chlorine residual is 0.2 mg/L prescribed by both the Nunavut Public Health regulations and the Alberta standard.

Calculation of $CT_{required}$

Since the membrane filter provides the necessary 3-log reduction of cysts/oocysts, no additional chlorination is required to inactivate these organisms.

Thus, the $CT_{required}$ for virus inactivation can be determined from tables provided in Appendix 1-B of the Alberta standard. For a water temperature of 0.5°C and a pH range of 6 to 9, the $CT_{required}$ for 4-log inactivation of viruses is 12 mg·min/L.

Calculation of Chlorine Residual

The residual chlorine (at the outlet of the contact vessel) can be calculated from the CT formula, by entering known and given values for CT and contact time (T_{MIN}). For a CT of 12 mg·min/L and a contact time of 12 minutes, the residual chlorine concentration is 1.0 mg/L. Therefore, the chlorine dosage rate ultimately selected for the treatment system must be sufficient to result in a residual chlorine concentration of 1.0 mg/L (note: the minimum chlorine residual stipulated in both the Alberta standard and the Nunavut Public Health Regulations is 0.2 mg/L).

Given the input parameters for the CT calculation that have been specified by the GN-CGS, the residual chlorine of 1.0 mg/L is the only possible value for this parameter, and therefore is also indirectly specified by the GN-CGS.

Calculation of Required Contact Vessel Volume

The volume of the contact chamber required can be calculated from the relationship between contact time (T_{MIN}), maximum flow rate, and minimum volume of contact vessel. Using the calculated value for T_{MIN} and the required maximum flow rate stipulated by the GN-CGS, gives a contact chamber volume of 12,000 L or 12 m³.

⁴ As part of the *Comprehensive Performance Evaluation* of the existing water truck filling station completed by ARKTIS in July 2009, two source water samples were procured and analysed for a suite of chemical parameters and pH. The pH for these source water samples was 6.63 and 6.61. These results are sufficient to use for this exercise, however, source water characterization should be completed to confirm that the pH of the source water is consistently within this range.

3.0 Results

The CT calculations were completed using the following GN-CGS stipulated parameters:

- i. CT Value = 12 mg·min/L
- ii. Baffling Factor, $T_{10}/T = 1.0$
- iii. Flow Rate = 1,000 L/min
- iv. Contact time = 12 minutes

The calculated results are as follows:

- i. Residual Chlorine Concentration = 1.0 mg/L
- ii. Volume of Contact Vessel = 12,000 L

4.0 Discussion

The values stipulated by the GN-CGS to be used in the CT calculations, and hence, the design of the water treatment system for the water truck filling station, have been verified, giving reasonable results for residual chlorine concentration and contact vessel volume.

The contact vessel volume of 12,000 L may, however, present a problem in design given the length of pipe that will be necessary to approach ideal plug flow conditions (i.e. a Baffling Factor of 1.0). For example, a pipe of 1 metre diameter will result in a length of over 15 metres to provide the required 12,000 L capacity. Additionally, as two truck filling arms are required, capable of filling two water trucks *simultaneously*, two such contact vessels will be required. The building that will be necessary to house these contact vessels and associated equipment will have to be quite large and able to withstand the increased loads of at least 30 metres of 1 metre diameter pipe in addition to the other systems required for the facility.

Further, the Baffling Factor of 1.0 represents ideal plug flow (i.e. perfect mixing in the radial direction across a pipe, or 100% mixing efficiency, along a straight pipe with no bends). In practice, this is not possible, as real-world pipe flow does not behave ideally (e.g. there is always some turbulence and friction along the walls of the pipe), particularly in a pipe that will necessarily have multiple bends along its length in order to fit it into a limited space. Some level of hydraulic analysis would be necessary to determine whether a Baffling Factor of 1.0 is appropriate for the pipe system to be designed, which could likely result in an increase in the volume required for the contact vessel.

5.0 Recommendations

As an alternative to the contact pipe, ARKTIS recommends a baffled tank system as presented in our March 15th 2011 Briefing Note. The advantage of the baffled tank system is that a number



ARKTIS SOLUTIONS INCORPORATED

:: 3962 Harrowsmith Road :: Harrowsmith, ON:: K0H 1V0 ::
:: Phone: 867.446.4129 :: Fax 866.475.1147 ::

of pre-engineered tank designs are available (typically with Baffling Factors of 0.7) and can be used in the design to reduce the overall complexity of the system and simplify its construction. At present, there are no known pre-engineered contact pipes currently manufactured. Use of a contact pipe in the facility would thus require the design and construction of a prototype system to satisfy the requirement of a Baffling Factor of 1.0.

Although a Baffling Factor of 0.7 for a pre-engineered tank would result in a larger volume requirement and a slightly longer contact time (or slightly higher chlorine residual), it is the opinion of ARKTIS that the overall volume of building space taken up by a tank system would likely be very similar to that taken up by a pipe system, particularly when the non-ideal configuration of the pipe is taken into account (which may likely result in an adjustment to the Baffling Factor and hence increase to contact vessel volume anyway). The reason for this is that in order for the pipe system to fit inside a reasonably-sized building, multiple turns and bends would be required, which would necessarily result in an increase in overall volume of building space taken up by the piping. In short, the size of the building required for either system would likely be very similar; however, the complexity of design and difficulty of construction would be reduced with the tank system.

Further, there is a limit to the diameter that the pipe system can have, above which it would no longer exhibit plug flow behaviour (a precondition for a Baffling Factor of 1.0). The larger the diameter of piping, the shorter the length of piping required; however, the larger the diameter, the less likely the piping will exhibit plug flow behaviour, negating any advantage of such a system.

6.0 Closing

Should you have any questions whatsoever about its contents, please feel free to contact the author at 867.899.6060 and/or hamp@arktissolutions.com.

APPENDIX B – MECHANICAL AND ELECTRICAL ENGINEERING DESIGN DEVELOPMENT REPORT



Drinking Water Truck Fill Station & Infrastructure Igloolik, NU

Design Development Report



Prepared for: ARKTIS Solutions, Inc.

Project No.: 13-072

Updated October 10, 2013





Table of Contents

TABLE OF CONTENTS	1
1 EXECUTIVE SUMMARY	1
2 INTRODUCTION TO NEW DESIGN.....	2
2.1 BACKGROUND.....	2
2.2 OBJECTIVES	2
2.3 INFORMATION ASSESSED	3
2.4 SCOPE OF SCHEMATIC DESIGN PHASE.....	3
2.5 LIMITATIONS	3
2.6 METHODOLOGY.....	4
3 DESIGN ANALYSIS	5
3.1 FUNCTIONAL REQUIREMENTS	5
3.2 FUNCTIONAL BLOCKS OF THE NEW TRUCK FILL STATION.....	5
3.2.1 <i>Pumping</i>	5
3.2.2 <i>Filtering</i>	6
3.2.3 <i>Chlorination</i>	7
3.2.4 <i>Water Reservoir</i>	10
3.2.5 <i>Delivery System to Trucks</i>	12
3.2.6 <i>Power and Emergency Power</i>	13
3.2.7 <i>Controls and Auxiliary Equipment</i>	13
4 CONCLUSION	16
4.1 SUMMARY	16
4.1.1 <i>Advantages</i>	16
4.1.2 <i>Disadvantages</i>	16
4.1.3 <i>Risk Analysis</i>	16
4.1.4 <i>Schedule of Work</i>	18
4.2 COST.....	18





1 Executive Summary

The Government of Nunavut – Community and Government Services (GN-CGS) contracted ARKTIS to plan and design an improved Water Supply System consisting of Water Truck Fill Station, Water Storage Reservoir, Intake Piping System, Piping Support System and Water Source for a design life of 20 years in the Municipality of Igloolik, NU (GN-CGS Project #10-2005).

The original scope of work included the cost-benefit analysis of three design options for the improvement of the Water Supply System in Igloolik. The options identified in the GN RFP were:

1. Expansion of the existing reservoir and construction of a new intake pump house and intake pipe line;
2. Expansion of the existing reservoir and refurbishment of the existing intake pump house and intake pipe line; and
3. Construction of a road leading to South Lake and construction of a new intake pump house at the lake.



Chiarelli Engineering Management Ltd.
202-100 Craig Henry Drive
Ottawa, Ontario, K2G 5W5

(613) 225-1123 Phone
(613) 225-7298 Fax
info@cemlottawa.com

Soon after the award of the design contract, the GN-CGS determined that the preferred design option was the expansion of the existing reservoir and construction of a new intake pump house and intake pipe line, and therefore analysis of the other two options was no longer required.

Concurrently with the development of this project, ARKTIS was also retained by the GN-CGS to complete the design of the water truck filling station in Pangnirtung, a community of similar population size, projected water demand, and with water also drawn from a reservoir. In June 2013 the GN-CGS requested that ARKTIS revise our existing scope of services for both the Pangnirtung and Igloolik projects to account for changes in the design requirements for both of the proposed Water Truck Filling Stations.

This report is therefore built on the identical water delivery schematic developed for the truck fill station in Pangnirtung, NU. It is recommended to carry out the work in 2014 construction season. The project period is estimated to take about 4 months. Cost estimation of this option is not in the scope of this report.





2 Introduction to New Design

2.1 Background

The existing water reservoir and associated truck fill station designed in May 1979 and build the following year. The facility was built and operates on now outdated technology. The facility has not been modernized since its construction. Maintaining the facility is becoming increasingly difficult due to its age and availability of replacement parts.

The existing truck fill station chlorination technology reflects the technology used 30 years ago and by today's standards it is outdated and should be brought to present day standards.

In addition, the population increase has increased demands on water consumption which cannot be met by the present single filling arm and its water delivery capacity.

Based on the above the Government of Nunavut opted to replace the existing facility with a new truck fill station.



Chiarelli Engineering Management Ltd.
203-100 Craig Henry Drive
Ottawa, Ontario, K2G 5W3
(613) 225-1123 Phone
(613) 225-7298 Fax
chiarelli@travellint.com

ARKTIS Solutions Inc, the firm responsible for the design and implementation of the new truck fill station has retained Chiarelli Engineering Management Ltd. to design the mechanical and electrical system requirements for the drinking water supply operation and to address the above design issues.

2.2 Objectives

The objectives of the Design Development phase portion of this project are to:

- Understand the present day operation, capacity of the water delivery system, health concerns, safety and operational requirements and predicted growth.
- Propose a design, develop and implement a quality drinking water delivery system that will stand the test of time, and based on the design parameters stipulated by the GN-CGS (i.e. serpentine contact vessel).





2.3 Information Assessed

Previous reports and studies as well as some original design documentation were provided.

Interviews were conducted with the municipality officials and maintenance personnel who relayed operational concerns and provided historical perspectives of issues with running the water delivery in the town of Igloolik, NU.

Feedback on the previous report by the Government of Nunavut that provided guidelines for the desired truck fill station schematic and setup.

Also, manufacturers of the relevant equipment (pumps, chlorination and control systems, piping, etc.) were contacted for information on availability of replacement parts and new systems.

2.4 Scope of Design Development Phase



This phase is primarily concerned with the truck filling station and its associated equipment. It does not address concerns with operation of trucks or expansion of the water storage. It is the intent of this phase to present an agreed upon design concept, develop and implement design strategies that the Government of Nunavut can move forward with and provide the Hamlet of Igloolik with a reliable, safe potable drinking water truck fill station.

Chiarelli Engineering Management Ltd.
203-100 Craig Henry Drive
Ottawa, Ontario, K2G 5W3
(613) 225-1123 Phone
(613) 225-7298 Fax
info@cemlottawa.com

2.5 Limitations

Reviewed material, furnished by others, is expected to be free of any deficiencies or inaccuracies.

Comments and conclusions within this report represent our opinion, which has been based on our analysis and our past experience.





In issuing this phase, Chiarelli Engineering Management Ltd, does not assume any of the duties or liabilities of the designers, builders, owner or property managers of this operation. Persons who use or rely on the contents of this report do so with the understanding as to the limitations of the documents examined. Such persons understand that Chiarelli Engineering Management Ltd cannot be held liable for the damages they may suffer in respect to the design construction, purchase, ownership, use or operation of the water delivery facilities.

2.6 Methodology

The water delivery process of the truck fill station can be broken down to several building blocks that make up the complete system. These building blocks are:

- Pumping,
- Filtering,
- Chlorination,
- Water reservoir,
- Delivery system to trucks,
- Emergency power, and
- Controls and auxiliary equipment.



Chiarelli Engineering Management Ltd.
203-100 Craig Henry Drive
Ottawa, Ontario, K2G 5W3

(613) 225-1123 Phone
(613) 225-7298 Fax
chiarelli@travel-net.com

The design of each of these building blocks was derived from Government of Nunavut guidelines, applicable Codes and followed up by consultations with potential providers of specialized technologies. The final review and comments were provided by Government of Nunavut representatives.





3 Design Analysis

3.1 Functional Requirements

Functional requirements of water delivery operation can be summarized into the following points:

- Provide safe quality potable drinking water.
- Provide increased delivery capacities and quantities of drinking water.
- Be safe working environment for the personnel and equipment.

3.2 Functional Blocks of the New Truck Fill Station

In order to house pumping and water delivery equipment and supporting infrastructure the overall footprint for the building is estimated at 1100 square feet. The architectural and structural design of the new pumping building is not in the scope of this report.



Chiarelli Engineering Management Ltd.
202-100 Craig Henry Drive
Nepean, Ontario, K2G 5W3

(613) 225-1123 Phone
(613) 225-7298 Fax
chiarelli@travel-net.com

3.2.1 Pumping

The current proposed design will have redundant pumps that will pump the water out of the reservoir and into the serpentine piping arrangement through filters and chlorination process.

Each pump (WP-1 and WP-2) will have the required capacity of delivering 1000L/m specified for filling of delivery trucks. The two pumps are sequenced in operation but can run simultaneously when filling two water bowsers at the same time.






Figure 1: Pumping Arrangement

Note that during original design stage the GN-CGS specifically rejected the idea of a third intake line and pump and as a result, there is no full redundancy in the system. Therefore, the recommendation is to store a third pump set on site in case one of the two pumps fails.



Chiarelli Engineering Management Ltd.
202-100 Craig Henry Drive
Nepean, Ontario, K2G 5W3

(613) 225-1123 Phone
(613) 225-7298 Fax
chiarelli@travel-net.com

In case one of the two working pumps fail, only one pump will run whether one or two truck fill stations are initiated while the failed pump is being replaced with the spare set. In this arrangement the impact of a pump failure is minimized.

3.2.2 Filtering

The truck fill station will include filtration equipment through 20 micron, 5 micron and 1 micron filter cartridges capable of filtering water delivered by both pumps simultaneously (2000L/m).

Each filter will be monitored by a differential pressure gauge that indicates that the filter cartridge is clogged and will need to be cleaned.






Figure 2: Arrangement of Filters


3.2.3 Chlorination



The chlorination will be provided through dosing pumps, and redundancy is planned. The legislation requires a minimum 0.2 mg/L of chlorine residual reading. The chlorination process described below shall provide flexibility to set the residual chlorine in a wide range. The pre-mixed chlorine will be injected into the main fill pipe feeding water into the serpentine pipe. The minimum chlorine contact time due to application of the serpentine pipe is reduced to 12 minutes.

The second, identical chlorination system (post-chlorination) will be located between the output of the serpentine tank and the truck fill stations checking and adjusting the chlorination level just before the water is delivered to the distribution trucks.



**Figure 3: The Chlorination Loop**

The Microchem2 is the controlling unit for the chlorination process. Since the water flow in the main 100 mm water pipe can vary depending whether 1 or 2 pumps are running, the condition of the filters and the water level in the lagoon, the flow is precisely measured by the flow meter (FM-1). The controller sends a 4-20 mA signal to the chlorination dosing pump (CP-1 or CP-2) that is proportional to the water flow measured by FM-1. Water is tested continually by chlorination and pH/temperature probes connected to Microchem2 which will adjust the amount of chlorine solution pumped by CP-1 or CP-2 to ensure the required level of chlorination.





Figure 4: Microchem2 Skid with Probed

The information gathered by Microchem2 (water delivery, chlorination, temperature and pH) will be stored in the data recorder and will be accessible through a USB port or remotely through an IP address.




Chiarelli Eng
202-100 Cra
Nepean, On



Figure 5: Nanodac Data Recorder





ARTICLE	QTE	DESCRIPTION
1	2	PULSATRON PUMP
2	1	PULSATRON PUMP
3	1	HAYWARD STRAINER
4	3	CHEMLINE PRESSURE RELIEF VALVE
5	1	COLONNE DE CALIBRATION GRIFFOC
6	2	BLACOH PRESSURE GAUGE
7	4	1\"/>
8	17	PLASTOMATIC BALL VALVE
9	2	CHEMLINE BACK PRESSURE VALVE
10	2	HAYWARD CHECK VALVE
11	4	HAYWARD CHARACTERIZED BALL VALVE

N1	TO RESERVOIR OUTLET
N2	TO RESERVOIR INLET
N3	DRAIN AND GENERATOR SAMPLE
N4	RETENTION BASIN DRAIN
N5	ELECTRICAL OUTLETS FOR DOSAGE PUMPS
N6	CALCIUM-HYPOCHLORITE SOLUTION

ALL TUBING AND FITTING ON THE SUCTION SIDE OF THE PUMP ARE 1/2" PVC EXCEPT WHERE NOTED

THE CALCIUM HYPOCHLORITE CONCENTRATION OF 1.7% AVCL IS MEASURED AT THE PULVERISATION NOZZLE AT A PRESSURE OF 35 PSIG AND TEMPERATURE OF 70°F

Figure 6: Dosing Pump Skid





Only one of the two dosing pumps will be “ON”. The second pump is a backup in case that the active pump failed. This has to be switched manually. The dosing pump skid also contains calibration and cleaning accessories.

The chlorine solution for the dosing pumps will be prepared by an automated “MC4-50” feeding system. Here again, the second system is a backup in case the active one fails. It is recommended to keep the backup system dry & clean and only activate it if required.

Note that a redundant pair of these feeding systems can serve both the pre and post-chlorination systems.



Figure 7: “MC4-50” Feeding System

3.2.4 Water Reservoir

After rigorous discussions and analysis of reports and various options, this design focuses on the use of a serpentine type of piping arrangement that will be housed in a substructure of the new truck fill station. The serpentine piping will contain approx. 15,000 litres of potable drinking water that will be pre-chlorinated prior to transferring to the delivery trucks. The capacity of the stored water will meet the requirement to supply potable drinking water simultaneously to at least two medium sized water bowser vehicles or a single 13,000 litres water bowser vehicle that serve the current community.





The design centres around a single serpentine pipe of 30" in diameter. The crawl space will allow for access to the piping system. The serpentine pipe itself will be mounted on a concrete pad and will be supported on a cradle type support system. The actual description and characteristics of the construction of the truck fill station was designed by Arktis Solutions Inc. and can be found in their report.





Figure 8: 15,000 Litre Serpentine Pipe Water Tank

3.2.5 Delivery System to Trucks

The delivery system to trucks will have the ability to fill two water bowser vehicles simultaneously. In order to accomplish the simultaneous filling of trucks, the station will require two dedicated transfer arms, one for each bowser fill station.

When filling of a delivery truck is initiated, the normally closed (N/C) motorized valves of the relevant filling arm will open while the draining valve will close and one of the two pumps will start to pump water. The function of the draining valve is to drain the water from the filling pipe exposed to outside temperatures. The outdoor portion of the filling arm will be insulated to prevent formation of ice inside the pipe.





Chiarelli Engineering Management Limited
202-100 Craig Henry Drive
Nepean, Ontario, K2G 5W3

Figure 9: Schematic of the Delivery System

(613) 225-7298 Fax
chiarelli@travel-net.com

3.2.6 Power and Emergency Power

Electrical service: The present truck fill station is fed from three (3) single phase, pole mounted transformers, 25 kVA each. These transformers will have to be replaced due to the condition (age and corrosion). The load summary calculation established the load demand for the new truck fill station at 79.3 kVA. Therefore the new transformers will have to be upgraded to 37.5 kVA each.

Emergency generator: The backup generator will have to be proportional to the electrical service in size to fully maintain the operation in case of a power outage over an extended period. A matching standby diesel engine generator would be a 100 kW air cooled diesel generator set.

3.2.7 Controls and Auxiliary Equipment

The truck fill station will contain several dedicated control panels to control and monitor the operation of the redundant pumps, the chlorination pumps, the backup generator, heat tracing cables and other relevant equipment. Alarm conditions will be fed into an alarm encoder and transmitted to the operations personnel of the Hamlet of Igloolik.



Chiarelli Engineering Management Ltd.
203-100 Craig Henry Drive
Ottawa, Ontario, K2G 5W3

(613) 225-1123 Phone
(613) 225-7298 Fax
info@cemlottawa.com




Figure 10: Pump Station Control and Monitoring Schematic



Pump Sequencer: its function is to cycle the 2 submersible pumps, so that each pump is exercised equally over time. In case of a pump failure (determined by the relevant flow switch (FS-1 or FS-2)) the sequencing stops at the functioning pump and the sequencer initiates an alarm condition.

Pump Controller: its function is to tie together all other items required for the operation; fill station push buttons, controls of various valves, time delay relays, alarms and the emergency stop push button. Lights will indicate which filling station is being used and which pump is running. It will also indicate some of the alarm conditions and provides an emergency power off and reset functions.

The alarm reporting unit combines all alarm inputs. When any of the alarm conditions occurs, it turns on the strobe located outside on the truck fill station building and initiates the autodialer that will place a telephone call with a recorded message to sequence of phone numbers.

Some of the alarm levels will be settable:

- Low temperature alarm on the thermostat located in the main pumping room.





- Pressure drops across the water filters. This pressure switch will have two adjustable alarm settings: High (H) – when one truck is being filled (one pump is running) and High/High (H/H) – when two trucks are being filled (two pumps are running). The higher the allowed pressure drop across the filters, the longer it will take to fill the trucks, though the filters will need to be cleaned less frequently.

The truck fill station will also need a distribution of potable cold and hot water and a storage tank for waste water. The water storage tank will be monitored for low level when the water will need to be replenished. The waste water tank will be monitored for high level indicating that the tank needs to be emptied.




Figure 11: Domestic Cold and Hot Water Schematic

The building will be heated by oil-fired unit heaters while the ventilation of the facility will be through the installation of a Heat Recovery Ventilator (HRV).





4 Conclusion

4.1 Summary

Figure 12 below shows the overall schematic of the new proposed truck fill station comprised of the building blocks described above.

Each step of the water delivery process meets the requirements for quality, quantity, reliability, remote monitoring and historical data storage of crucial elements of the water delivery process with minimal human intervention or maintenance.

In addition, standardizing this design will make it easier to understand the process and operational requirement for the attending personnel as well as for the responsible government officials.

4.1.1 Advantages

- Meets the needs of the Hamlet and that of the Government of Nunavut
- Updates the water delivery to current standards.
- Increases the water delivery capability to meet the needs of a growing population.



Chiarelli Engineering Management Ltd.
202-100 Craig Henry Drive
Ottawa, Ontario, K2G 5W3

(613) 225-1123 Phone
(613) 225-7298 Fax
info@cemlottawa.com

4.1.2 Disadvantages

- Costly endeavor for the Government of Nunavut.

4.1.3 Risk Analysis

- High risk – potential for breakdown of the existing truck fill station causing water delivery outages.
- High risk – for paying premium for fixing broken down equipment






Figure 12: Overall Schematic of the Truck Fill Station





4.1.4 Schedule of Work

The construction of the new pumping facility should be scheduled during the summer construction period.

Description	Number of Weeks
Design	10 weeks
Tender and Award	3 weeks
Construction	10 weeks
Commissioning	1 week
TOTAL NUMBER OF WEEKS	24 weeks

4.2 Cost

Cost estimation of this option is not in the scope of this report. ARKTIS Solutions Inc. will retain cost consultants to provide cost estimates of the required classes.



Chiarelli Engineering Management Ltd.
202-100 Craig Henry Drive
Nepean, Ontario, K2G 5W3

(613) 225-1123 Phone
(613) 225-7298 Fax
chiarelli@travel-net.com



Chiarelli Engineering Management Ltd.
203-100 Craig Henry Drive
Ottawa, Ontario, K2G 5W3

(613) 225-1123 Phone
(613) 225-7298 Fax
info@cemlottawa.com

APPENDIX C – CLIMATIC DATA



Igloolik, NU

Latitude: 69 ° 21 ' 45 "

Longitude: 81 ° 49 ' 51 "

Elevation (Metres): 54

Design element	Design value
January 2.5% design dry bulb temperature °C	
January 1% design dry bulb temperature °C	
July 2.5% design dry bulb temperature °C	
July 2.5% design wet bulb temperature °C	
Annual total degree days below 18 °C	
Maximum 15 minute rainfall (mm)	
Maximum one day rainfall (50 years) (mm)	
Annual rainfall (mm)	
Annual total precipitation (mm)	
Moisture Index	
Driving Rain wind pressure 1/5 years (Pa)	
Ground snow load, snow component Ss (30 years) (kPa)	2.5
Ground snow load, rain component Sr (30 years) (kPa)	0.1
Ground snow load, snow component Ss (50 years) (kPa)	2.8
Ground snow load, rain component Sr (50 years) (kPa)	0.1
Hourly wind pressure 1/10 (kPa)	0.43
Hourly wind pressure 1/30 years (kPa)	0.52
Hourly wind pressure 1/50 years (kPa)	0.56
Hourly wind pressure 1/100 years (kPa)	0.62

Please note that the recommended values may differ from the legal requirements established by the municipal or provincial (territorial) building authorities. The design values may have been interpolated from calculated values at surrounding locations with subjective modification. Topographic effects may introduce local variations in the design values. Environment Canada has not made and does not make any representation or warranties, either expressed or implied, arising by law or otherwise, respecting the accuracy of climatic information. In no event will Environment Canada be responsible for any prejudice, loss or damage which may occur as the result of the use of climatic information.

Thursday, September 26, 201

APPENDIX D – SEISMIC DATA

2010 National Building Code Seismic Hazard Calculation

INFORMATION: Eastern Canada English (613) 995-5548 français (613) 995-0600 Facsimile (613) 992-8836
Western Canada English (250) 363-6500 Facsimile (250) 363-6565

Requested by: , ARKTIS Solutions Inc.

September 19, 2013

Site Coordinates: 69.3623 North 81.8309 West

User File Reference: Igloolik, Nunavut

National Building Code ground motions:

2% probability of exceedance in 50 years (0.000404 per annum)

Sa(0.2)	Sa(0.5)	Sa(1.0)	Sa(2.0)	PGA (g)
0.100	0.094	0.065	0.024	0.036

Notes. Spectral and peak hazard values are determined for firm ground (NBCC 2010 soil class C - average shear wave velocity 360-750 m/s). Median (50th percentile) values are given in units of g. 5% damped spectral acceleration (Sa(T), where T is the period in seconds) and peak ground acceleration (PGA) values are tabulated. Only 2 significant figures are to be used. *These values have been interpolated from a 10 km spaced grid of points. Depending on the gradient of the nearby points, values at this location calculated directly from the hazard program may vary. More than 95 percent of interpolated values are within 2 percent of the calculated values.*

Ground motions for other probabilities:

Probability of exceedance per annum	0.010	0.0021	0.001
Probability of exceedance in 50 years	40%	10%	5%
Sa(0.2)	0.025	0.054	0.073
Sa(0.5)	0.022	0.050	0.068
Sa(1.0)	0.014	0.037	0.049
Sa(2.0)	0.005	0.013	0.017
PGA	0.005	0.011	0.019

References

National Building Code of Canada 2010 NRCC no. 53301; sections 4.1.8, 9.20.1.2, 9.23.10.2, 9.31.6.2, and 6.2.1.3


Appendix C: Climatic Information for Building Design in Canada - table in Appendix C starting on page C-11 of Division B, volume 2

User's Guide - NBC 2010, Structural Commentaries NRCC no. 53543 (in preparation)
Commentary J: Design for Seismic Effects

Geological Survey of Canada Open File xxxx
Fourth generation seismic hazard maps of Canada: Maps and grid values to be used with the 2010 National Building Code of Canada (in preparation)

See the websites www.EarthquakesCanada.ca and www.nationalcodes.ca for more information

Aussi disponible en français



APPENDIX E

This report incorporates and is subject to these "General Conditions"

USE OF REPORT

This report pertains to a specific site, a specific development, and a specific scope of work. It is not applicable to any other sites, nor should it be relied upon for types of development other than those to which it refers. Any variation from the site or proposed development would necessitate a supplementary investigation and assessment.

This report and the assessments and recommendations contained within are intended for the sole use of the Government of Nunavut – Department of Community Government and Services (herein after referred to as the "Client"). Arktis Piusitippaa Inc. (herein after referred to as "API") does not accept any responsibility for the accuracy of any of the data, the analysis or the recommendations contained or referenced in the report when the report is used or relied upon by any third party unless otherwise authorized in writing by API. Any unauthorized use of the report is at the sole risk of the user.

The Service Contract states under Terms and Conditions for Consulting Services that "All copyright in the Material belongs exclusively to the Government of Nunavut, Department of Community and Government Services and on request the Contractor shall deliver document satisfactory to the Government of Nunavut, Department of Community and Government Services, waiving moral or other legal rights the Contractor or his employees or subcontractors may have in the Material and confirming and vesting such copyright in the Government of Nunavut, Department of Community and Government Services."

LIMITATIONS OF REPORT

This report is based solely on the conditions which existed on site at the time of API's investigation. The client, and any other parties using this report with the express written consent of the clients and API, acknowledge that conditions affecting the environmental assessment of the site can vary with time and that the conclusions and recommendations set out in this report are time sensitive.

The client, and any other party using this report with the express written consent of the client and API, also acknowledge that the conclusions and recommendations set out in this report are based on limited observations and testing on the subject site and that conditions may vary across the site which, in turn, could affect the conclusions and recommendations made.

The client acknowledges that API is neither qualified to, nor is it making, any recommendations with respect to the purchase, sale, investment or development of the property, the decisions on which are the sole responsibility of the client.

During the performance of the work and the preparation of this report, API may have relied on the information provided by third parties. While API endeavors to verify the accuracy of such information when instructed to do so by the client, API accepts no responsibility for the accuracy or the reliability of such information which may affect the report.

LIMITATIONS OF LIABILITY

The client recognizes that property containing contaminants and hazardous wastes creates a high risk of claims brought by third parties arising out of the presence of those materials. In consideration of these risks, and in consideration of API providing the services requested, the client agrees that API's liability to the client, with respect to any issues relating to contaminants or other hazardous wastes located on the subject site shall be limited as follows:

- a. With respect to any claims brought against API by the client arising out of the provisions or failure to provide services hereunder shall be limited to the amount of fees paid by the client to API under this Agreement, whether the action is based on breach of contract or tort;
- b. With respect to claims brought by third parties arising out of the presence of contaminants or hazardous wastes on the subject site, the client agrees to indemnify, defend and hold harmless API from and against any and all claim or claims, action or actions, demands, damages, penalties, fines, losses, costs and expenses of every nature and kind whatsoever, including solicitor-client costs, arising or alleged to arise either in whole or part out of services provided by API, whether the claim be brought against API for breach of contract or tort.

STANDARD OF CARE

Services performed by API for this report have been conducted in a manner consistent with the level of skill ordinarily exercised by members of the profession currently practicing under similar conditions in the jurisdiction in which the services are provided. Professional judgment has been applied in developing the conclusions and/or recommendations provided in this report. No warranty or guarantee, express or implied, is made concerning the test results, comments, recommendations, or any other portion of this report. The Phase I Environmental Site Assessment was conducted on the requirements of the Canadian Standards Association (CSA) Z768-01, Phase 1 Environmental Site Assessment.

ALTERNATE REPORT FORMAT

Where API submits both electronic file and hard copy versions of reports, drawings and other project-related documents and deliverables (collectively termed API's instruments of professional service), the Client agrees that only the signed and sealed (if applicable) hard copy versions shall be considered final and legally binding. The hard copy versions submitted by API shall be the original documents for record and working purposes, and, in the event of a dispute or discrepancies, the hard copy versions shall govern over the electronic versions. Furthermore, the Client agrees and waives all future right of dispute that the original hard copy signed version archived by API shall be deemed to be the overall original for the Project.

The Client agrees that both electronic file and hard copy versions (or scanned electronic versions thereof) of API's instruments of professional services shall not, under any circumstances, no matter who owns or uses them, be altered by any party except API. The Client warrants that API's instruments of professional services will be used only and exactly as submitted by API.