

Environmental Protection Operations Directorate
Prairie & Northern Region
5019 52nd Street, 4th Floor
P.O. Box 2310
Yellowknife, NT X1A 2P7

ECCC File: 6200 000 009/007
NWB File: 3BM-IGL1520/3AM-IGL----



March 20, 2020

via email at: licensing@nwb-oen.ca

Richard Dwyer
Manager Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU X0B 1J0

Dear Richard Dwyer:

RE: 3BM-IGL1520/3AM-IGL---- – Municipality of Igloolik – Type B Water Licence Renewal – Amendment Application

Environment and Climate Change Canada (ECCC) has reviewed the information submitted to the Nunavut Water Board (NWB) regarding the above-mentioned Water License renewal-amendment application. You will find our comments included in this letter.

ECCC's specialist advice is based on our mandate pursuant to the *Canadian Environmental Protection Act* and the pollution prevention provisions of the *Fisheries Act*.

ECCC has the following comments:

1. Leachate from the Solid Waste Facility

Reference(s)

- Municipality of Igloolik Plan for Compliance Licence No. 3BM-IGL1520
- Annual Report for the Hamlet of Igloolik 2019

Comment

The 2019 annual report identifies leachate from the landfill as an unauthorized discharge under the water licence. There are no follow-up actions listed for this unauthorized discharge, and the report only states that the municipality is awaiting a new facility to remediate this issue. ECCC acknowledges that a new facility may be required to prevent further leachate from the landfill. The Hamlet of Igloolik (the Proponent) should provide information on the quantity and quality of leachate, where the leachate is occurring and reporting to, and what measures are being taken to collect all leachate so it does not discharge into the receiving environment.



ECCC Recommendation(s)

ECCC recommends that the Proponent take measures to capture all leachate from the landfill site for appropriate management so that it does not get discharged into the receiving environment. In addition, information on the quality, quantity, and locations of leaching should be provided

2. Monitoring Results

Reference(s)

- Operations and Maintenance Manual Volume 1, Igloolik Wastewater Facility. Exp Services Inc. August 2014, revised February 2020.

Comment

Section 4.4 of the Wastewater Facility Operations and Maintenance Manual outlines the parameters to be analyzed at all monitoring stations for the lagoon system. ECCC notes that carbonaceous biochemical oxygen demand (cBOD) is on this list, but is not analyzed in the August 21, 2019 sample results provided with the renewal application.

ECCC Recommendation(s)

ECCC recommends that the Proponent include all parameters listed in Section 4.4 in the analysis of effluent and water quality associated with the lagoon, including cBOD.

3. Treatment Capabilities

Reference(s)

- Operations and Maintenance Manual Volume 1, Igloolik Wastewater Facility. Exp Services Inc. August 2014, revised February 2020.

Comment

The operations and maintenance manual indicates that the wastewater treatment system uses the sewage lagoons as the main method of treatment, with the filter strip wetlands providing additional treatment prior to the release into the environment. However, the laboratory results provided as part of the water licence application only include data for the three cells of the lagoon and provide no information of the final quality after the filter strip wetlands (IGL-5). Based on the lagoon effluent quality results, the concentration of total ammonia as nitrogen in effluent should be monitored. Understanding that the filter strip wetland strip provides additional treatment, the total ammonia concentrations at the end of this wetland should be provided to ensure that concentrations would not cause effects to aquatic life.

ECCC Recommendation(s)

ECCC recommends the Proponent provide monitoring data of effluent quality for the three individual sewage lagoons (IGL-4) as well as at the end of the filter strip wetland, to quantify final quality prior to release to the environment (IGL-5).

If you need more information, please contact Eva Walker at (867) 669-4744 or Eva.Walker@Canada.ca.

Sincerely,

[original signed by]

Eva Walker
Environmental Assessment Coordinator

Attachment(s):

cc: John Olyslager, Acting Head, Environmental Assessment North (NT and NU)