

Chapter 39 FORM

MANUFACTURER/DISTRIBUTOR:

DEVCAR INC

6 rue du Tutor

Lachute, QC

J8H 3R8

Phone: 450-562-7391

Fax: 450-562-7391

39.1 **DAILY MORNING REPORT**

39.2 **DAILY LOG SHEET**

Serial Number	Time	Truck Number	Inside the Water Plant			After filling the Truck		Turbidity		Reading at Garage				Name of the operator	Stroke per Minute
			Free Chlorine, mg/L (Probe)	Free Chlorine, mg/L (Pocket Hach)	Total Chlorine mg/L	Free chlorine mg/L	Total Chlorine mg/L	Raw Water NTU	Treated water after 20 minutes Contact time NTU	Time	Free Chlorine, mg/l (ppm)	Total Chlorine, mg/l (ppm)	NTU		
1															
2															
3															
4															
5															
6															
7															
8															
9															
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															
22															
23															

Igloolik Truckfill - Daily Morning Report				Date:			
				Time Started	Time Stopped	Initial of trainer	
Name of Operator / Trainer :							
Name of Operator / Trainer :							
Name of Trainee :							
Name of Trainee :							
Name of Trainee :							
Name of Trainee :							
		Yes/No	If Yes, type of alarm?			Initial of trainee	
Alarm:							
Calibration Required ?	Yes/No	Initial of trainee	Free Chlorine Measurements	PPM	Initial of trainee		
Pocket Colorimeter			Probe Reading (Controller Display)				
Ph Probe			Pocket Colorimeter Reading				
Free Chlorine Probe			pH Measurements	pH	Initial of trainee		
Filter/Strainer Cleaning	Date	Initial of trainee	PH probe reading				
Last Strainer Cleaning?			Portable PH reading				
Last 20 Micron Filter Replacement?			Water Temperature Measurements	°C	Initial of trainee		
Last 20 Micron Filter Cleaning?			Probe Reading (Controller Display)				
Last 5 Micron Filter Replacement ?			Turbidity Measurements	NTU	Initial of trainee		
Last 5 Micron Filter Cleaning ?			Portable Instrument Reading				
Last 1 Micron Filter Replacement?			Flow Meter Readings	Total M³	Initial of trainee		
Last 1 Micron Filter Cleaning ?			Flow Meter Before Filter				
			Flow Meter After Filter				
Reading Taken During First Truck Fill							
Flow Meter Readings	M³/Minute	Initial of trainee	Filter Pressure Readings	PSI	Initial of trainee		
Flow Meter Before Filter			Absolute Pressure Before Strainer				
Flow Meter After Filter			Strainer Differential Pressure				
VFD Outputs			20 micron Filter Differential Pressure				
VFD Frequency (Hertz)			5 micron Filter Differential Pressure				
VFD Current (Amps)			1 micron Filter Differential Pressure				
Comments :							