



Water Resources Division
Resource Management Directorate
Nunavut Regional Office
P.O. Box 100
Iqaluit, NU, X0A 0H0

Your file - Votre référence
3AM-IGL2131
Our file - Notre référence
GCDOCS# 93650621

April 6, 2021

Richard Dwyer
Manager of Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU, X0B 1J0
E-mail: licensing@nwb-oen.ca

Re: Crown-Indigenous Relations and Northern Affairs Canada Review of the Updated Spill Contingency Plan and Wastewater Treatment Facility Operation and Maintenance Manual for the Hamlet of Igloolik, Type A Water Licence No. 3AM-IGL2131

Dear Richard,

Thank you for the March 3, 2021 invitation to review the referenced updated Spill Contingency Plan (SCP) and Wastewater Treatment Facility Operation and Maintenance (O&M) Manual for the Hamlet of Igloolik, Type A Water Licence No. 3AM-IGL2131. Crown-Indigenous Relations and Northern Affairs Canada (CIRNAC) examined the submission pursuant to its mandated responsibilities under the *Nunavut Waters and Nunavut Surface Rights Tribunal Act* and the *Department of Crown-Indigenous Relations and Northern Affairs Act*.

In the Final Written Submission for the Hamlet of Igloolik Water Licence Amendment, dated October 29, 2020, CIRNAC requested that the following be included in an updated SCP:

- the size and storage capacity of each sewage lagoon; and
- a site photo indicating the location(s) where spill kits are stored.

In the Final Written Submission for the Hamlet of Igloolik Water Licence Amendment, dated October 29, 2020, CIRNAC requested that the following be included in an updated O&M Manual for the Wastewater Treatment Facility:

- the pathway to access the monitoring stations at the filter strip wetland;
- the locations of safety equipment and spill kits on site;
- the snow accumulation and dumping areas;
- a north arrow on maps to aid in directional instructions; and
- the procedure for measuring wastewater volumes decanted from the lagoons.



All of the requested details have been integrated into the SCP and the O&M Manual to CIRNAC's satisfaction. If there are any questions or concerns, please contact me at (867) 975-4282 or bridget.campbell@canada.ca.

Regards,

Bridget Campbell

Water Resources Coordinator, Nunavut Regional Office