

INDIAN & NORTHERN AFFAIRS
WATER RESOURCES LABORATORY
Box 1500
Yellowknife, NT. X1A 2R3
Tel. (403) 920-8129
Fax. (403) 873-9300

To: Water Resources
Water Resources\NAP
Baffin District Office
Box 100
==> Iqaluit NT X0A 0H0
Paul Smith

SAMPLE INFORMATION

Our Lab # : 941322
Your Sample ID: Baffin 0571-1
Sample Matrix : water

Account No.: Baffin

Collection:
Location: Igloolik - South Lake
Date: 07/22/94
By: PS

Report Date: 10/25/94

Approved by: *[Signature]*

- SAMPLE ANALYSIS REPORT -

Lab#	Parameter	Result Units	Detect Limit	Method Code
941322	Alkalinity	79.8 mg/L	0.300	10101
	Calcium	32.70 mg/L	0.040	20103
	T.Cadmium ICP-MS	LO.1 ug/L	0.100	100133
	Chloride	35.20 mg/L	0.080	17206
	Colour	15 Colour	5.000	02021
	Conductivity	299.0 uS/cm	0.100	02041
	T.Cobalt ICP-MS	0.1 ug/L	0.100	27009
	T.Chromium ICP-MS	1.7 ug/L	0.200	24009
	T.Copper ICP-MS	0.8 ug/L	0.100	100119
	Fluoride	0.03 mg/L	0.030	09105
	Filt.Residue	167 mg/L	10.000	10451
	Tot.Hardness	113.0 mg/L	0.100	10602
	Potassium	1.24 mg/L	0.050	19106
	Magnesium	7.50 mg/L	0.010	12102
	T.Manganese ICP-MS	1.6 ug/L	0.100	100113
	Sodium	18.30 mg/L	0.040	11102
	Non-Filt Res.	3 mg/L	3.000	10406
	T.Nickel ICP-MS	0.2 ug/L	0.100	100117
	T.Lead ICP-MS	LO.2 ug/L	0.200	100145
	pH	8.16 pH	0.050	10301
	T.Arsenic-Hyd.	LO.3 ug/L	0.300	33011
	T. Iron	32 ug/L	3.000	26002
	T.Mercury-C/V	0.02 ug/L	0.020	80011
	T-Phosphorous	0.003 mg/L	0.002	15403
	Turbidity	0.6 NTU	0.100	02081
	T.Zinc ICP-MS	0.6 ug/L	0.500	100121