



**Department of Health & Social Services: Baffin**

[illegible]

Okoa Kavamat Monakhikakvilikiot Olasilikiot

Ministère de la Santé et des Services Sociaux

P.O. Box 1000 STN 1046; 00000; C.P. 1000 STN 1046

Iqaluit, NU      Δ<sup>b</sup>→Δ<sup>c</sup>, Δ<sup>a</sup>→<sup>c</sup> X0A 0H0

Phone: ८६७८९: Fonia (867) 975-4800 Fax: ८६७८९: Faxkot: (867) 975-4833

To: City of Igloolik

Date: June 24/04

Sample Date: June 23/04

Lab Date: June 23/04

## SUBMITTED WATER SAMPLE RESULTS

The bacteriological water samples listed below were analyzed and the results are as indicated.

Location of Sample	Total Coliform	E. coli	Acceptable Yes/No	Comments
Truck # 46	0	0	yes	PKI
Truck # 43	0	0	yes	PKI
Raw water	0	0	yes	PKI
Truck # 809	0	0	yes	PKI
Truck # 50	0	0	yes	PKI
Treated (Plant)	0	0	yes	PKI

Counts above zero require immediate re-sampling. If you have any problems or questions, please call or fax an Environmental Health Officer at the numbers listed above.

Regards,

Cc:

Philip Reeve.

### Environmental Health Officer



204/1

ENTRE