



Department of Health & Social Services: Baffin

[illegible]

Okoa Kavamat Monakhikakvilikiot Olasilikiot

Ministère de la Santé et des Services Sociaux

P.O. Box 1000 STN 1046; 00000; C.P. 1000 STN 1046

lcaluit, NU $\Delta^b \rightarrow \Delta^c$ $\rightarrow^c$ XOA OHO

Phone: ٨٦٧-٩٧٥ Fonix (867) 975-4800 Fax: ٨٦٧-٩٧٥ Faxkot: (867) 975-4833

To: City of Iqaluit

Date: April 06/2004
Sample Date: April 05/2004
Lab Date: April 05/2004

Sample Date: *April/05/2004*

Lab Date: Apr. 1/05/2004.

SUBMITTED WATER SAMPLE RESULTS

The bacteriological water samples listed below were analyzed and the results are as indicated.

Clz Residuals

Location of Sample	Total Coliform	E. coli	Acceptable Yes/No	Comments
House #139 A,	0	0	yes	FAC-.09 TC-.18
House #139 A-Duplicate*	0	0	yes	" " "
Indvil Dept Engineering	0	0	yes	FAC-.30 TC-.42
House 145 A -	0	0	yes	FAC-.08 TC-.17
Rooster (1) Hopper Valley	0	0	yes	FAC.42 TC.56
Grind and Brew	0	0	yes	FAC.42 TC.47
The Snock Rest.	0	0	yes	FAC-.24 TC-.36
#222 Reheat Station	0	0	yes	FAC.27 TC.39
Six stop	0	0	yes	FAC.11 TC.27
Blank	0	0	yes	— N/A —

Counts above zero require immediate re-sampling. If you have any problems or questions, please call or fax an Environmental Health Officer at the numbers listed above.

Regards,

Cc:

Philip Reese C.P.H.I.T. (C)

Environmental Health Officer



Department of Health & Social Services: Baffin

[illegible]

Okoa Kavamat Monakhikakvilikiot Olasilikiot

Ministère de la Santé et des Services Sociaux

P.O. Box 1000 STN 1046; ՈՈՖԵՃԱԿ 1000; C.P. 1000 STN 1046

Iqaluit, NU Δ⁹Δ^c, Δ⁹Δ^c X0A 0H0

Phone: 9666: Fonia (867) 975-4800 Fax: 9666: Faxkot: (867) 975-4833

To: City of Igloolik

Date: April 29/2004

Sample Date: April 28, 2004

Lab Date: April 28/2004

SUBMITTED WATER SAMPLE RESULTS

The bacteriological water samples listed below were analyzed and the results are as indicated.

Location of Sample	Total Coliform	E. coli	Acceptable Yes/No	Comments
Public Health #155	0	0	yes	PK1
Treat Plant Treated	0	0	yes	PK1
Truck #50	0	0	yes	PK1
Truck #48	0	0	yes	PK1
Truck #89	0	0	yes	PK1
Water Plant Raw	0	0	yes	PK1
Truck #43	0	0	yes	PK1

Counts above zero require immediate re-sampling. If you have any problems or questions, please call or fax an Environmental Health Officer at the numbers listed above.

Regards,

Cc:

Philip Reeve, C.P.H.I. (C)

Environmental Health Officer