



Department of Health & Social Services: Baffin

[illegible]

Okoa Kavamat Monakhikakvilikiot Olasilikiot

Ministère de la Santé et des Services Sociaux

P.O. Box 1000 STN 1046; 0000000000 1000; C.P. 1000 STN 1046

Iqaluit, NU Δ^bΔ^c, Δ^cΔ^b X0A 0H0

Phone: 867-975-4800 Fax: 867-975-4833

To: City of Igloolik

Date: 05/28/04
Sample Date: 05/27/04
Lab Date: 05/27/04

Sample Date: 05/27/04

Lab Date: Oct/27/04

SUBMITTED WATER SAMPLE RESULTS

The bacteriological water samples listed below were analyzed and the results are as indicated.

Location of Sample	Total Coliform	E. coli	Acceptable Yes/No	Comments
Truck #46	0	0	yes	PC
Water plant	0	0	yes	PK
Plant Kaw	0	0	yes	PC
Truck #89	0	0	yes	PK
Truck #43	0	0	yes	PK
Truck #50	0	0	yes	PK

Counts above zero require immediate re-sampling. If you have any problems or questions, please call or fax an Environmental Health Officer at the numbers listed above.

Regards,

Cc:

Philip Reeve

Environmental Health Officer



Department of Health & Social Services: Bureau
 ለፍብረት ልማትና ሕዝብ አገልግሎት ልማት: የፖሊሲና
 ስልጣን ክፍል

Ministère de la Santé et des Services Sociaux

Iqaluit, NU Δ⁸Δ^c, Δ⁹Δ^c X0A 0HO

Phone: ᐃᖃᓕᓕᓐ: Fonia (867) 975-4800 Fax: ᐃᖃᓐᓕᓐᓕᓐᓕᓐ: Faxkot: (867) 975-4833

Date: Nov/26/04
Sample Date: Nov/25/04
Lab Date: Nov/25/04

The bacteriological water samples listed below were analyzed and the results are as indicated.

Location of Sample	Total Coliform	E. coli	Acceptable Yes/No	Comments
Flow Meter	1	0	yes	OK Raw
Truck #46	0	0	yes	PR
Truck #89	0	0	yes	PR
Plant Treatment	0	0	yes	PR
Truck #50	0	0	yes	PR
Truck #43	0	0	yes	PR

Counts above zero require immediate re-sampling. If you have any problems or questions, please call or fax an Environmental Health Officer at the numbers listed above.

Regards,

Cc:

Philip Reed

Environmental Health Officer