



Department of Health & Social Services: Baffin

[illegible]

Okoa Kavamat Monakhikakvilikiot Olasilikiot

Ministère de la Santé et des Services Sociaux

P.O. Box 1000 STN 1046; 00000; C.F. 1000 STN 1046

Iqaluit, NU $\Delta^b \rightarrow \Delta^c$, $\Delta^b \rightarrow^c$ XDA OHO

Phone: 867-975-4800 Fax: 867-975-4833

To:

City of Iqaluit

Date: Jan 22/04

Sample Date: Jan 21 / 04

Lab Date: Jan 21/04

SUBMITTED WATER SAMPLE RESULTS

The bacteriological water samples listed below were analyzed and the results are as indicated.

Location of Sample	Total Coliform	E. coli	Acceptable Yes/No	Comments
Raw Water	2	0	yes	Raw - OK TH
Treated Water	0	0	yes	TH.
Truck # 43	0	0	yes	TH
Truck # 46	0	0	yes	TH
Truck # 48	0	0	yes	TH
Truck # 89	0	0	yes	TH

Counts above zero require immediate re-sampling. If you have any problems or questions, please call or fax an Environmental Health Officer at the numbers listed above.

Regards,

Tracey Hewitt / Etto

Cc:

INTERNAL
PC
MA
FO
ap

Environmental Health Officer

Nunavut Water Board

JUN 16 2005

Public Registry



Phone: 867-975-4800 Fax: 867-975-4833

Date: Dec 12/03
Sample Date: Dec 10/03
Lab Date: Dec 11/03

Environmental Health Officer

