

Question on Water License Questionnaire

Under Technical Information it asks for an attachment of detailed plan or drawings of the sewage treatment process. The City's main treatment process is a Wastewater Treatment Plant but there is a sewage lagoon that is still used as a back-up facility if there is a problem with the Wastewater Treatment Plant. Do you require drawings for both facilities or do you only require drawings for the Wastewater Treatment Plant?

In my view it would be required for both if both are being used or planned for use.

I note that there is a large scanned document on the NWB's ftp site called "Iqaluit Waste Water Treatment Plant – Conversion and Expansion" dated October 2004. I haven't looked through the entire document as it is broken into many volumes. However, if it's still applicable you may want to consider submitting a non-scanned version of it.

For the treatment plant, I think the most important issue is to demonstrate that it is of the type and capacity able to meet the effluent criteria and that it will be operated and maintained accordingly.