

Client: City of Iqaluit
PO Box 460
Iqaluit, NU
X0A 0H0
Attention: Mr. Pat Wolfe
PO#:
Invoice to: City of Iqaluit

Report Number: 1220660
Date Submitted: 2012-09-21
Date Reported: 2012-09-28
Project: WWTP Inn Test B
COC #: 154600

Page 1 of 2

Dear Pat Wolfe:

Please find attached the analytical results for your samples. If you have any questions regarding this report, please do not hesitate to call (613-727-5692).

Report Comments:

APPROVAL: _____

Robert Walker
Senior Manager, Client Services

Exova (Ottawa) is certified and accredited for specific parameters by:
CALA, Canadian Association for Laboratory Accreditation (to ISO 17025), OMAF, Ontario Ministry of Agriculture, Food and Rural Affairs (for farm soils), Licensed by Ontario MOE for specific tests in drinking water.

Exova (Mississauga) is accredited for specific parameters by:
SCC, Standards Council of Canada (to ISO 17025)

Please note: Field data, where presented on the report, has been provided by the client and is presented for informational purposes only.

Client: City of Iqaluit
PO Box 460
Iqaluit, NU
X0A 0H0
Attention: Mr. Pat Wolfe
PO#:
Invoice to: City of Iqaluit

Report Number: 1220660
Date Submitted: 2012-09-21
Date Reported: 2012-09-28
Project: WWTP Inn Test B
COC #: 154600

					Lab I.D. Sample Matrix Sample Type Sampling Date Sample I.D.
Group	Analyte	MRL	Units	Guideline	986494 Wastewater 2012-09-19 Test B (WWTP Inn)
Microbiology	Faecal Coliforms	0	ct/100mL		11200000
	Total Coliforms	0	ct/100mL		34700000

Guideline = * = **Guideline Exceedence**

** = Analysis completed at Mississauga, Ontario.

Results relate only to the parameters tested on the samples submitted.

Methods references and/or additional QA/QC information available on request.

MRL = Method Reporting Limit, AO = Aesthetic Objective, OG = Operational Guideline, MAC = Maximum Acceptable Concentration, IMAC = Interim Maximum Acceptable Concentration, STD = Standard, PWQO = Provincial Water Quality Guideline, IPWQO = Interim Provincial Water Quality Objective.