

∆ቴ⇒ልና ውፎ<<▷ኑሢና
በበቴቴቴልኑ 460
∆ቴ⇒ልና, ውፎንና
X0A 0H0
▷ቴሬ▷በሢ (867) 979-5600
ሪቴናንቴሪና (867) 979-5922

City of Iqaluit
Box 460
Iqaluit, Nunavut
X0A 0H0
Phone (867) 979-5600
Fax (867) 979-5922

Ville d'Iqaluit C.P. 460 Iqaluit, Nunavut X0A 0H0 Tél. (867) 979-5600 Télécop. (867) 979-5922

admin@city.iqaluit.nu.ca www.iqaluit.nu.ca November 13, 2015

Phyllis Beaulieu Manager of Licensing Nunavut Water Board

Re: City of Iqaluit's Response to 150331 3AM-IQA0612 COMPLETENESS ASSESSMENT-AANDC REVIEW-ILAE

Dear Ms. Beaulieu:

In support of the City of Iqaluit's (City) water licence renewal application, please accept the following letter as the response to the submission from Aboriginal Affairs and Northern Development Canada reference 150331 3AM-IQA0612 COMPLETENESS ASSESSMENT-AANDC REVIEW-ILAE, dated March 31, 2015.

Requests for Information

1. Emergency Preparedness Plan for Sewage Lagoon - The Dam Safety Inspection Report (Dam Safety Inspection Report, City of Iqaluit, Concentric Associates International Incorporated, September 21, 2011) recommends the completion of an Emergency Preparedness Plan for the sewage lagoon. The City of Iqaluit has an intention to retain the lagoon as a back-up facility. In light of the City's consultant report, localized failures and/or seeps are expected. The proponent should be requested to provide an Emergency Preparedness Plan accordingly.

Response: The City has received a letter from a Structural Engineer that is submitted with the City response that states the sewage lagoon is a Low-Risk Dam Classification and an Emergency Preparedness Plan is not required.

If you have any questions or require further information or clarification, please contact Matthew Hamp, Director of Public Works and Engineering at 867-979-5653.

Sincerely

Muhamud Hassan

Chief Administrative Officer

City of Iqaluit