

C.O.C.: G37010

REPORT No. B13-22724

Report To:

City of Iqaluit

PO Box 460,
Iqaluit NU X0A 0H0

Attention: Paul Clow

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa Ontario K1V 7P1
Tel: 613-526-0123
Fax: 613-526-1244

DATE RECEIVED: 29-Aug-13

JOB/PROJECT NO.: Test E

DATE REPORTED: 16-Sep-13

P.O. NUMBER:

SAMPLE MATRIX: Waste Water

WATERWORKS NO.

			Client I.D.		WTP Test E			
			Sample I.D.		B13-22724-1			
			Date Collected		27-Aug-13			
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed				
Conductivity @25°C	µmho/cm	1	SM 2510B	30-Aug-13/O	483			
Total Suspended Solids	mg/L	3	SM 2540D	30-Aug-13/O	248			
pH @25°C	pH Units		SM 4500H	30-Aug-13/O	7.43			
Nitrite (N)	mg/L	0.1	SM4110C	29-Aug-13/O	< 0.1			
Nitrate (N)	mg/L	0.1	SM4110C	29-Aug-13/O	0.1			
Calcium	mg/L	0.02	SM 3120	30-Aug-13/O	24.8			
Magnesium	mg/L	0.01	SM 3120	30-Aug-13/O	4.30			
Sodium	mg/L	0.2	SM 3120	30-Aug-13/O	21.2			
Potassium	mg/L	0.1	SM 3120	30-Aug-13/O	8.6			
Aluminum (total)	mg/L	0.01	SM 3120	30-Aug-13/O	0.51			
Antimony	mg/L	0.0001	EPA 200.8	30-Aug-13/O	< 0.0001			
Arsenic	mg/L	0.0001	EPA 200.8	30-Aug-13/O	< 0.0001			
Barium	mg/L	0.001	SM 3120	30-Aug-13/O	0.040			
Beryllium	mg/L	0.002	SM 3120	30-Aug-13/O	< 0.002			
Bismuth	mg/L	0.02	SM 3120	30-Aug-13/O	< 0.02			
Boron	mg/L	0.005	SM 3120	30-Aug-13/O	0.041			
Cadmium	mg/L	0.005	SM 3120	30-Aug-13/O	< 0.005			
Chromium	mg/L	0.002	SM 3120	30-Aug-13/O	0.002			
Cobalt	mg/L	0.005	SM 3120	30-Aug-13/O	< 0.005			
Copper	mg/L	0.002	SM 3120	30-Aug-13/O	0.366			
Iron (Total)	mg/L	0.005	SM 3120	30-Aug-13/O	0.957			
Lead	mg/L	0.02	SM 3120	30-Aug-13/O	< 0.02			
Lithium	mg/L	0.005	SM 3120	30-Aug-13/O	< 0.005			
Manganese (Total)	mg/L	0.001	SM 3120	30-Aug-13/O	0.212			
Molybdenum	mg/L	0.01	SM 3120	30-Aug-13/O	< 0.01			
Nickel	mg/L	0.01	SM 3120	30-Aug-13/O	< 0.01			
Silicon	mg/L	0.01	SM 3120	30-Aug-13/O	1.60			
Silver	mg/L	0.005	SM 3120	30-Aug-13/O	< 0.005			



M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill

Greg Clarkin, BSc., C. Chem
Lab Manager - Ottawa District

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.

C.O.C.: G37010

REPORT No. B13-22724

Report To:

City of Iqaluit

PO Box 460,
Iqaluit NU X0A 0H0

Attention: Paul Clow

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa Ontario K1V 7P1

Tel: 613-526-0123

Fax: 613-526-1244

DATE RECEIVED: 29-Aug-13

JOB/PROJECT NO.: Test E

DATE REPORTED: 16-Sep-13

P.O. NUMBER:

SAMPLE MATRIX: Waste Water

WATERWORKS NO.

			Client I.D.	WTP Test E			
			Sample I.D.	B13-22724-1			
			Date Collected	27-Aug-13			
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
Strontium	mg/L	0.001	SM 3120	30-Aug-13/O	0.081		
Tin	mg/L	0.05	SM 3120	30-Aug-13/O	< 0.05		
Titanium	mg/L	0.005	SM 3120	30-Aug-13/O	0.011		
Uranium	mg/L	0.00005	EPA 200.8	30-Aug-13/O	0.00020		
Vanadium	mg/L	0.005	SM 3120	30-Aug-13/O	< 0.005		
Zinc	mg/L	0.005	SM 3120	30-Aug-13/O	0.153		
Ammonia (N)-Total	mg/L	0.01	MOEE 3364	04-Sep-13/O	32.8		
o-Phosphate (P)	mg/L	0.01	MOEE 3366	04-Sep-13/O	3.43		
Phosphorus-Total	mg/L	0.01	MOEE 3367	11-Sep-13/O	5.95		
BOD	mg/L	3	SM 5210B	30-Aug-13/O	192		
Total Coliform	cfu/100mL	1	MOE E3371	29-Aug-13/O	8000000		
Fecal Coliform	cfu/100mL	1	MOE E3371	29-Aug-13/O	2000000		

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill



Greg Clarkin , BSc., C. Chem
Lab Manager - Ottawa District

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.



September 11, 2013

Greg Clarkin
Caduceon Environmental Laboratories
2378 Holly Lane
Ottawa, ON K1V 7P1

Dear Greg:

On August 30, 2013, Pollutech EnviroQuatics Limited personnel received a water sample from Caduceon Environmental Laboratories (Test E B13-22724), Ottawa Site. The following acute toxicity tests were performed on this sample observing Environment Canada methods:

- Rainbow trout 96-hour single-concentration toxicity test according to the criteria outlined in the "Biological Test Method: Reference Method for Determining Acute Lethality of Effluents to Rainbow Trout", Second Edition, Method Development and Applications Centre, Ottawa, ON., Report EPS 1/RM/13, 2000 (with 2007 amendments).
- *Daphnia magna* 48-hour LC50 toxicity test according to the criteria outlined in the "Biological Test Method: Reference Method for Determining Acute Lethality of Effluents to *Daphnia magna*", Environmental Technology Center, Ottawa, Ontario, Report EPS 1/RM/14 Second Edition, December 2000.

The results of the acute toxicity tests are summarized in Table 1.

Table 1 Summary of Acute Toxicity Results for Test E B13-22724 Water Sample Collected August 23, 2013

Sample Name Sample #	Toxicity Test	Endpoint	Effect	Result ¹
Test E B13-22724 #79911304	<i>Daphnia magna</i>	48-hour LC50 (95% Confidence)	Mortality	Non-lethal ² (Not available)
	Rainbow Trout	96-hour Single- Concentration	Mortality	100% Mortality ^{2,3}

¹ – Results relate only to the sample tested

² – Test invalid as hold time greater than five days. Tested as instructed.

³ – Most regulations regard ≤50% mortality to be a "pass". Check your applicable regulatory requirements.

bringing clarity to your environment

704 Mara Street, Suite 122, Point Edward, Ontario, Canada N7V 1X4 • T: 519.339.8787 • F: 519.336.6965
Email: info@pollutechgroup.com • www.pollutechgroup.com

Toxicity Test Endpoint Descriptions

LC50 The estimated concentration which causes acute lethality to 50% of the test organisms.

The following pages contain the required details for reporting of the acute lethality toxicity tests. If there are any further details which you require, please do not hesitate to contact us.

Sincerely,
Pollutech EnviroQuatics Limited



R. Clay Ferguson, B.Sc. (Hon.)
Laboratory Manager

File ID:\bioassay\2013\7000\7991\7991au2 T, D LC50

Rainbow Trout 96-Hour Single-Concentration Toxicity Test

METHOD: Environment Canada, "Biological Test Method: Reference Method for Determining Acute Lethality of Effluents to Rainbow Trout", Second Edition, Method Development and Applications Section, Ottawa, ON., Report EPS 1/RM/13, 2000 (with 2007 amendments). Pollutech Test Method RT-SC-R1.2.

Test Material

Client Name/Location: Caduceon Environmental Laboratories, Ottawa, ON

Sample #: 79911304 **Sample Name:** Test "E" B13-22724

Sample Method: Grab **Collected by:** n/a

Date/Time Collected: Aug. 23/13, 08:30 **Arrival Temp.:** 25.4°C

Date/Time Received: Aug. 30/13, 14:30 **Sample Description:** Cloudy brown

Sample Point Description: Other **Sample Type:** Effluent

Transportation: Road

Storage: Overnight at 15 ± 1°C In dark, no headspace
n/a – not available

Test Organisms

Species: Rainbow Trout (*Oncorhynchus mykiss*)

Source: Rainbow Springs Hatchery

Culture Temp.: 15 ± 2°C **Batch Number:** RS072413

Water Source: Dechlorinated Municipal Drinking Water

Mean Weight: 0.71 g **Min:** 0.42 g **Max:** 1.03 g

Mean Fork Length: 40.8 mm **Min:** 34 mm **Max:** 47 mm

Loading Density: 0.36 g/L **Sample Size:** 10 fish

Life Stage: Fry

Number Dead Daily In Previous 7 Days For Fish Culture: 0+0+2+1+0+4+4=11

Previous 7-Day Holding Mortalities For Fish Culture: 1.15%

Rainbow Trout 96-Hour Single-Concentration Toxicity Test - Continued

Sample Number: 79911304

Sample Name: Test "E" B13-22724

Test Conditions

Date/Time Started: Aug. 31, 2013, 13:00

Test Volume: 20 L/Vessel

Number of Fish Per Vessel: 10

of Vessels Per Conc.: 1

Test Temperature: $15 \pm 1^{\circ}\text{C}$

Pre-aeration: Yes

Duration of Pre-aeration: 120 minutes

Pre-aeration Rate: $6.5 \pm 0.26 \text{ ml/min}\cdot\text{L}^{-1}$

Aeration Rate During Test: $6.5 \pm 0.26 \text{ ml/min}\cdot\text{L}^{-1}$

Sample Adjustment: No

Sample pH Adjustment: No

Test Method Deviations: Yes, sample hold time greater than five days.

Test Facilities



CALA

Testing
Accreditation No. A1225

Testing Laboratory:

Pollutech EnviroQuatics Limited, 704 Mara St.,
Suite 122, Point Edward, Ontario, N7V 1X4

This laboratory is accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA). The test included in this report is within the scope of this laboratory.

Test Performed By:

M. Long/C. Ferguson/C. D'Andrea

Initial Measurement of Variables in Unadjusted Sample

Cond: 420 μmhos

pH: 6.6

O₂: 0.3 mg/L

Temp: 16.0°C

Test Results

	NUMBER OF MORTALITIES						
	Rep.No.			Time (hours)			
Conc'n	1	4	24	48	72	96	
100%	1	0	10	-	-	-	-
Control	1		0	0	0	0	

Number of Control Fish Showing Atypical/Stressed Behaviour: 0

Rainbow Trout 96-Hour Single-Concentration Toxicity Test - Continued

Sample Number: 79911304

Sample Name: Test "E" B13-22724

Test Results

TOXICITY TEST VARIABLES

Conc'n	Rep. No.	Variables	Time (hours)				
			0	24	48	72	96
100%	1	Cond. (μ mhos)	408				n/r
		O ₂ (mg/L)	6.2				4.3
		pH (units)	7.1				7.3
		Temp. (°C)	15.8				15.9
Control	1	Cond. (μ mhos)	186				n/r
		O ₂ (mg/L)	10.2				9.6
		pH (units)	7.5				7.8
		Temp. (°C)	15.6				16.0

n/r = not required

Summary of Test Results

Mean Mortality Rate: 100%¹

Test Results Verified By: R. C. Ferguson

¹ - Most regulations regard $\leq 50\%$ mortality to be a "pass". Check your applicable regulatory requirements.

Reference Toxicant Results

Reference Chemical: Zinc **Date Test Initiated:** 08/20/13

Fish Lot #: RS072413

Method: Spearman-Kärber ($\alpha = 10\%$)

96-Hour LC50 (95% Confidence Limits): 0.58 mg/L (0.44 mg/L; 0.78 mg/L)

Historic Geometric Mean LC50: 0.35 mg/L (0.18 mg/L; 0.67 mg/L)
(Historic Warning Limits) (± 2 Standard Deviations)

Daphnia magna 48-Hour Single *Daphnia magna* 48-Hour LC50 Toxicity Test

METHOD: Environment Canada, "Biological Test Method: Reference Method for Determining Acute Lethality of Effluents to *Daphnia magna*", Method Development and Applications Section, Ottawa, ON., Report EPS 1/RM/14, Second Edition, December 2000. Pollutech Test Method DM-LC-R10.7.

Test Material

Client Name/Location: Caduceon Environmental Laboratories, Ottawa, ON

Sample #: 79911304 **Sample Name:** Test "E" B13-22724

Sample Method: Grab **Collected by:** n/a

Date/Time Collected: Aug. 23/13, 08:30 **Arrival Temp.:** 25.4°C

Date/Time Received: Aug. 30/13, 14:30 **Sample Description:** Cloudy brown

Sample Point Description: Other **Sample Type:** Effluent

Transportation: Road

Storage: 4 ± 2 °C In dark, no headspace
n/a not available

Test Organisms

Species: *Daphnia magna* **Source:** Pollutech Culture (MOE/EPA)

Culture Temp.: 20 ± 2°C **Age:** < 24-hours old

Water Source: Reconstituted dechlorinated tap water

Cultures Used in Testing: 63 SA

Days to First Brood: 8

Average # Number of Neonates/Brood: 39

Previous 7 Days Mortality in Culture: 0%

Test Facilities

Testing Laboratory:

Pollutech EnviroQuatics Limited, 704 Mara St.,
Suite 122, Point Edward, Ontario, N7V 1X4



This laboratory is accredited by the Canadian Association for Laboratory Accreditation Inc. (CALA). The test included in this report is within the scope of this laboratory.

Test Performed By: M. Long

***Daphnia magna* 48-Hour LC50 Toxicity Test - Continued**

Sample Number: 79911304

Sample Name: Test "E" B13-22724

Test Conditions

Date/Time Started:	Sept. 01/13, 09:30	# of Neonates/Vessel:	3
Test Volume:	50 mL/Vessel	mL Solution/Neonate:	16.7 mL
Reps/Concentration:	4	Dilution Water:	DW13-72
Pre-aeration:	Yes	Pre-aeration Rate:	50 ± 2 ml/min·L ⁻¹
Pre-aeration Duration:	30 minutes	Test Temperature:	20 ± 2°C
Sample pH Adjustment:	No	Sample pH Adjustment Procedure:	N/A
Sample Hardness Adjustment:			No
Hardness Before and After Adjustment:			Not Applicable
Test Method Deviations:			Yes, sample hold time greater than five days.

Initial Measurement of Variables of Unadjusted, Undiluted Sample

pH: 7.0 **O₂:** 0.3 mg/L **Cond:** 440 µmhos **Temp:** 19.6°C

Test Results

TOXICITY TEST VARIABLES

Concentration (% Volume)	pH		Oxygen mg/L		Cond. µmhos	Hardness mg/L	Temperature C°	
	Initial	Final	Initial	Final	Initial	Initial	Initial	Final
Control	8.1	8.3	8.9	8.5	530	198	20.3	20.5
6.25	7.8	7.9	8.6	7.5	511	--	20.4	20.3
12.5	7.7	7.7	8.4	6.5	510	--	20.3	20.3
25	7.5	7.6	7.5	5.0	503	--	20.3	20.3
50	7.4	7.5	6.0	3.1	486	--	20.3	20.3
100	7.1	7.5	2.0	1.2	438	50	19.8	20.3

***Daphnia magna* 48-Hour LC50 Toxicity Test - Continued**

Sample Number: 79911304

Sample Name: Test "E" B13-22724

Test Results - continued

DAPHNIA OBSERVATIONS				
Concentration (% Volume)	Test Vessel	Number of Daphnia Immobile		Number of Daphnia Dead
		24 hr.	48 hr.	48 hr.
Control	A	0	0	0
	B	0	0	0
	C	0	0	0
	D	0	0	0
6.25	A	0	0	0
	B	0	0	0
	C	0	0	0
	D	0	0	0
12.5	A	0	0	0
	B	0	0	0
	C	0	0	0
	D	0	0	0
25	A	0	0	0
	B	0	0	0
	C	0	0	0
	D	0	0	0
50	A	0	0	0
	B	0	0	0
	C	0	0	0
	D	0	0	0
100	A	0	0	0
	B	0	0	0
	C	0	0	0
	D	0	0	0

***Daphnia magna* 48-Hour LC50 Toxicity Test - Continued**

Sample Number: 79911304


Sample Name: Test "E" B13-22724

Summary of Test Results

48-Hour LC50: Non-lethal
95% Confidence Limits: Not applicable
Analysis Method: No mortality
Results Verified By: R. C. Ferguson

Reference Toxicant Results

Reference Chemical: Phenol **Date Test Initiated:** 08/27/13
Method: Spearman-Kärber ($\alpha = 0\%$)
48-Hour LC50 (95% Confidence Limits): 17.68 mg/L (14.32 mg/L; 21.83 mg/L)
Historic Geometric Mean LC50: 17.44 mg/L (8.97 mg/L; 33.91 mg/L)
(Historic Warning Limits) (± 2 Standard Deviations)



GF-10/12

QUOTATION FOR ANALYTICAL SERVICES

Quote # :	Y13_TEST_E
Organization:	City of Iqaluit
Contact:	Sean Tiessen
Telephone:	867-979-5649
Facsimile:	
Email:	<u>S.Tiessen@city.iqaluit.nu.ca</u>
Project #:	Test E WWTP Effluent
Address:	P.O. Box 460 Iqaluit, Nunavut X0A 0H0
Additional Info:	<u>QUOTE # (S) MUST BE ON C OF C TO APPLY if not listed. General pricing will be applied.</u>
Additional Info:	1 Event a year (Summer(A, B, E, F))
Date:	January 10, 2013
Valid Until: December-31-13	

Item #	Quantity	Analysis Request	Matrix	Unit Cost, \$	Amount, \$
1	1	BOD	Effluent	25.00	\$25.00
2	1	Ammonia, NO2, NO3	Effluent	25.00	\$25.00
3	1	Orthophosphate	Effluent	15.00	\$15.00
4	1	Total Phosphorus	Effluent	15.00	\$15.00
5	1	Conductivity	Effluent	8.00	\$8.00
6	1	Total ICP Metals (Ag, Al, As, B, Ba, Be, Bi, Ca, Cd, Co, Cr, Cu, Fe, K, Mg, Mn, Mo, Li, Na, Ni, Pb, Sb, Si, Sn, Sr, Ti, U, V, Zn)	Effluent	70.00	\$70.00
7	1	LC50 Bioassay (R Trout) (sub-contracted)	Effluent	595.00	\$595.00
8	1	Total and Fecal Coliforms	Effluent	26.00	\$26.00
9	1	pH	Effluent	8.00	\$8.00
10	1	TSS	Effluent	15.00	\$15.00
11	1	Pick up from Ottawa Airport	-	25.00	\$25.00
Subtotal					827.00
Env. Surch. \$1.50/Sample					1.50
HST					107.71
Total Cost					\$936.21

Prices do not include shipping unless otherwise stated.

Damien Gilbert
Director of Business Development
Caduceon Environmental Laboratories
dgilbert@caduceonlabs.com

Laboratory Locations

Kingston - 285 Dalton Ave. Kingston, ON K7K 6Z1 Tel: (613) 544-2001 Fax: (613) 544-2770
Ottawa - 2378 Holly Lane Ottawa, ON K1V 7P1 Tel: (613) 526-0123 Fax: (613) 526-1244
Richmond Hill - 110 West Beaver Creek Road (Unit 14), Richmond Hill, ON L4B 1J9 Tel: (289) 475-8442 Fax: (866) 562-1883
Windsor - #5-3201 Marentette Ave. Windsor, ON N8X 4G3 Tel: (519) 866-9541 Fax: (519) 866-9567