

C.O.C.: G26997

REPORT No. B13-29382

Report To:

City of Iqaluit

PO Box 460,
Iqaluit NU X0A 0H0

Attention: Paul Clow

Caduceon Environmental Laboratories

2378 Holly Lane
Ottawa Ontario K1V 7P1

Tel: 613-526-0123

Fax: 613-526-1244

DATE RECEIVED: 08-Nov-13

JOB/PROJECT NO.: Test C

DATE REPORTED: 29-Nov-13

P.O. NUMBER:

SAMPLE MATRIX: Waste Water

WATERWORKS NO.

			Client I.D.	Test C			
			Sample I.D.	B13-29382-1			
			Date Collected	05-Nov-13			
Parameter	Units	M.D.L.	Reference Method	Date/Site Analyzed			
BOD	mg/L	3	SM 5210B	09-Nov-13/O	88		
Total Coliform	cfu/100mL	1	MOE E3371	08-Nov-13/O	> 10000000		
Fecal Coliform	cfu/100mL	1	MOE E3371	08-Nov-13/O	9200000		
Ammonia (N)-Total	mg/L	0.01	MOEE 3364	12-Nov-13/O	35.9		
Nitrite (N)	mg/L	0.1	SM4110C	12-Nov-13/O	< 0.1		
Nitrate (N)	mg/L	0.1	SM4110C	12-Nov-13/O	0.1		
o-Phosphate (P)	mg/L	0.01	MOEE 3366	12-Nov-13/O	3.52		
Phosphorus-Total	mg/L	0.01	MOEE 3367	20-Nov-13/O	6.44		
Conductivity @25°C	µmho/cm	1	SM 2510B	11-Nov-13/O	484		
Total Suspended Solids	mg/L	3	SM 2540D	13-Nov-13/O	204		
pH @25°C	pH Units		SM 4500H	11-Nov-13/O	7.12		

M.D.L. = Method Detection Limit

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill



Greg Clarkin , BSc., C. Chem
Lab Manager - Ottawa District

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.