

1. REFER TO MOTOR SCHEDULE FOR CONDUIT AND WIRE SIZES FOR ALL MOTORS.
2. MOTORIZED VALVE LOCATED ON CLEARWELL FLOOR LEVEL. CONFIRM EXACT LOCATION PRIOR TO ROUGHIN.
3. PUMPS LOCATED ON CLEARWELL FLOOR LEVEL. CONFIRM EXACT LOCATION PRIOR TO ROUGHIN.
4. SUPPLY CIRCUIT (2A-13 FOR LIGHTING AND 2A-15 FOR POWER AND FRACTIONAL MOTORS) TO EXISTING LIGHTING LOCATED ON C/LR LIGHT PANEL. PROVIDE ALL REQUIREMENTS ASSOCIATED WITH MAKING POWER AND LIGHTING CONNECTIONS.



MAINS:	225A	VOLTS:	120/208 VOLTS
MOUNTING:	SURFACE	LOCATION:	LOWER LEVEL
		FED FROM:	MDP
ENCLOSURE TO BE SINGLE TUB		ENTER AT:	TOP

2	RECORD DRAWING	23/04/04	
1	ISSUED FOR CONSTRUCTION	22/04/03	
0	ISSUED FOR TENDER	19/02/03	
NO.	REVISION	DATE	INITIAL

Company	Permit	Engineer	Seal
---------	--------	----------	------

Engineer Seal

RECORD DRAWING
INFORMATION CONTAINED IN THESE DRAWINGS
IS AS SUPPLIED BY:
KRT ELECTRIC
THE COMPLETENESS AND ACCURACY OF THIS
RECORD DRAWING IS NOT GUARANTEED.
INFORMATION SHOULD BE VERIFIED AT THE
ACTUAL LOCATION BEFORE USE.

ELECTRICAL

LOWER FLOOR ELECTRICAL PLAN AND SCHEDULES



**CITY of IQALUIT,
Nunavut**

CITY OF IQALUIT

IQALUIT WATER TREATMENT PLANT



Earth Tech (Canada) Inc.

DRAWN BY: FF CHECKED BY: WA	SCALE: AS NOTED	DATE: FEB. 03, 2003	SHEET NO.
CADD SYSTEM AutoCAD	DWG NO. E-2	REV. 1	CONTRACT 55524