



City of Iqaluit
IQUALUIT WASTE WATER TREATMENT PLANT
 NUNAVUT

THERMAL DISP FLOW TX



				DESIGN BY	DRAWN BY	PROJECT No.	DATE
				EVS	EVS	75360	OCT 2004
				CHECKED BY	APPROVED BY	SHEET No.	REV.
No.	DATE	REVISION	APPR	JH	MS	ISSF3	O
	1	MANUFACTURER		Magnetrol			
	2	MODEL NO.		TA1			
	3	TYPE		Single Point Insertion Thermal Dispertion Mass Flowmtr			
	4	SERVICE		Hot air from blowers			
	5						
	6						
	7						
P R O C E S S D A T A	8	FLUID		Process Air			
	9	MAX FLOW		see page 2			
	10	NORM FLOW		see page 2			
	11	MIN FLOW		see page 2			
	12	PRESS		~55kPa			
	13	MAX TEMP		125 deg C			
	14						
	15						
	16	SUPERCOMP FACTOR @ OP PRESS					
	17	MOL. WT	VAPOUR	GAS			
	18	VISCOSITY @ OP TEMP					
	19	STEAM QUALITY					
	20	SUPERHEAT					
	21	AMBIENT TEMP		10 - 20 Deg C			
	22	AMBIENT RELATIVE HUMIDITY		80 - 100%			
	23						
P R O B E	24	TYPE	MODEL NO.	Insertion "hot tap" Retractable Probe			
	25	MATERIAL		316 SS			
	26	LENGTH		see page 2			
	27	POWER		N/A			
	28	PROBE COMPRESSION FITTING REQ'D?		N/A			
	29	TEMP RANGE		-45 to 200 degC			
	30	PIPE TYPE & LINING	PIPE SIZE	Guage class SS		see page 2	
	31						
	32	XMITTER MODEL No.		TA1			
	33	ENCLOSURE		NEMA 4X			
	34	OUTPUT		4-20 mA Isolated			
	35	POWER SUPPLY		120 VAC, 12 W			
N O T E S	36						
	37	TAGGING		Each flow switch to be c/w a SS tag number			
	38						
	39	PROCUREMENT		Supply Transmitter, Probe, 'Hot Tap' Retractable Probe			
	40			Low Pressure Mounting Assembly with Safety Cable			
	41	ALTERNATES					
	42						



City of Iqaluit
IQALUIT WASTE WATER TREATMENT PLANT
NUNAVUT

ULTRASONIC LEVEL TX



				DESIGN BY	DRAWN BY	PROJECT No.	DATE
				EVS	EVS	75360	OCT 2004
				CHECKED BY	APPROVED BY	SHEET No.	REV.
				JH	MS	ISSL1	O
No.	DATE	REVISION		APPR			
	1	MANUFACTURER		SIEMENS MILLTRONICS			
	2	MODEL NO.		Multiranger 100			
	3	TYPE		Dual Channel Non-Contacting Ultrasonic			
GENERAL	4						
	5						
	6	SERVICE		Waste Water			
	7	P & ID DRAWING NO.		see page 2			
RANGE	8	VESSEL MATERIAL		see page 2			
	9	AGITATION (Y OR N)		see page 2			
	10	CABLE	TYPE	LENGTH			
	11						
SENSOR	12	SENSOR TAG NO.		see page 2			
	13	MODEL NO.		Echomax XPS-10			
	14	STYLE/TYPE		Non - Contacting Ultrasonic			
	15	CONNECTION	TYPE	RATING	Threaded 1" NPT		
OUTPUT	16	MATERIAL	SENSOR	COATING	Chemically Resistant		
	17						
	18	TRANSMITTER TAG NO.		see page 2			
	19	OUTPUT SIGNAL		Dual 4-20 mA DC (750 OHM Max.)			
ANALYSIS	20	REQUIRED SUPPLY VOLTAGE		120 VAC, 60 Hz			
	21	ENCLOSURE	RATING	MATERIAL	NEMA4X Manufacturer's Std		
	22	LOCAL DISPLAY		Digital Multi - Field Backlit LCD			
	23	AREA CLASSIFICATION		see page 2			
INSTALLATION	24	ACCURACY		+ / - 0.25 % of FSD			
	25	AMBIENT TEMP RATING (Deg. C)		-20 to +50			
	26	ADJ. SIGNAL DAMPENING		Continuous 100:1			
	27	ADJ. SPAN (cm)					
REMARKS	28	ALARM & CONTROL CONTACTS		4 - Form C, 5 Amp Non-Ind.			
	29						
	30	FLUID	LOWER	UPPER	Waste Water Air		
	31	PRESS (kPa)	NORM	MAX	Atmospheric		
PROCESS	32	TEMP (Deg. C)	MIN	MAX	-40 40		
	33	SPECIFIC GRAVITY					
	34	VISCOSITY (cp)					
	35	AMBIENT TEMP. (Deg. C)		10			
SPECIAL	36	APPROVALS REQUIRED		CSA			
	37						
	38	ACCESSORIES		Customer Stainless Steel Tag, Programmer Unit			
	39						
NOTES	40	ALTERNATES					
	41	MOUNTING INSTRUCTIONS		Provide and Install Stainless Steel Mounting Bracket			
	42			for Sensor Element.			
	43						

[illegible]



City of Iqaluit
IQALUIT WASTE WATER TREATMENT PLANT
NUNAVUT

GAUGE PRESSURE TX



				DESIGN BY	DRAWN BY	PROJECT No.	DATE	
				EVS	EVS	75360	OCT 2004	
0	JAN 03	FOR TENDER		CHECKED BY	APPROVED BY	SHEET No.	REV.	
No.	DATE	REVISION	APPR	JH	MS	ISSP1	O	
P R E S S U R E G A U G E M O N I T O R I N G	1	MANUFACTURER		Endress + Hauser				
	2	MODEL NO.		Cerebar PMC 41				
	3	TYPE		Capacitive Pressure Transmitter Gauge				
	4							
	5							
	6	TAG NO.						
	7	TYPE		Diaphragm				
	8	SERVICE		Blowers Delivery Air Pressure				
	9	RANGE						
	10	BODY MATERIAL		Aluminum				
	11	WETTED PARTS MATERIAL		316 SS				
	12	ABS PRESSURE COMPENSATION						
	13	STATIC HEAD COMPENSATION						
	14							
	15	OVER PRESSURE PROTECTION		Standard				
	16	CONNECTION TYPE	SIZE	Threaded Insert	1/2" - 14 NPT			
	17	OUTPUT		4-20 mA				
	18	SPAN ADJUST RANGE		100 %				
	19	ZERO ADJUST RANGE		100 % of Span				
	20	CALIBRATED RANGE						
	21	ACCURACY		0.1 %				
	22	SCALE		0 - 100 %				
	23							
	24	POWER SUPPLY		24 VDC External				
	25	ENCLOSURE		NEMA 4X				
	26	AREA CLASSIFICATION		General Purpose				
	27	REQUIRED APPROVALS		CSA				
	28	MOUNTING		Bracket for 2" Pipe				
	29	ACCESSORIES		Indicator - LCD Type				
	30							
	31							
	32							
	33							
	34							
	35							
	36							
N O T E S	37	TAGGING		Customer Stainless Steel Tag				
	38							
	39	ACCESSORIES		Installation, Operation and Maintenance Manual				
	40			Isolation/pressure relief valve				
	41	ALTERNATES						
	42							
	43							



				DESIGN BY	DRAWN BY	PROJECT No.	DATE
				EVS	EVS	75360	OCT 2004
				CHECKED BY	APPROVED BY	SHEET No.	REV.
				JH	MS	ISSP2	O
P R E S S U R E T R A N S M I T T E R	1	MANUFACTURER		Endress + Hauser			
	2	MODEL NO.		Deltabar S PMD 70			
	3	TYPE		Capacitive Differential Pressure Gauge			
	4						
	5						
	6	TAG NO.		LIT-			
	7	TYPE		Diaphragm			
	8	SERVICE		Fine Bubble Diffuser Level			
	9	RANGE					
	10	BODY MATERIAL		Carbon Steel, Cadmium Plated			
	11	WETTED PARTS MATERIAL		316 SS			
	12	ABS PRESSURE COMPENSATION		No			
	13	STATIC HEAD COMPENSATION		No			
	14						
	15	OVER PRESSURE PROTECTION		Standard			
	16	CONNECTION TYPE	SIZE	Threaded Insert	1/4" - 18 NPT		
	17	OUTPUT		4-20 mA			
	18	SPAN ADJUST RANGE		100 %			
	19	ZERO ADJUST RANGE		100 % of Span			
	20	CALIBRATED RANGE					
	21	ACCURACY		0.1 %			
	22	SCALE		0 - 100 %			
	23						
	24	POWER SUPPLY		24 VDC External			
	25	ENCLOSURE		NEMA 4X			
	26	AREA CLASSIFICATION		General Purpose			
	27	REQUIRED APPROVALS		CSA			
	28	MOUNTING		Bracket for 2" Pipe			
	29	ACCESSORIES		Indicator - LCD Type			
	30						
	31						
	32						
	33						
	34						
	35						
	36						
N O T E S	37	TAGGING		Stainless Steel Identification Tag			
	38						
	39	ACCESSORIES		Installation, Operation and Maintenance Manual			
	40			5 port manifold			
	41	ALTERNATES		Rosemount, ABB			
	42						
	43						



City of Iqaluit
IQUALUIT WASTE WATER TREATMENT PLANT
 NUNAVUT

PRESSURE SWITCH



				DESIGN BY EVS	DRAWN BY EVS	PROJECT No. 75360	DATE OCT 2004
				CHECKED BY JH	APPROVED BY MS	SHEET No. ISSP3	REV. 0
No.	DATE	REVISION	APPR				
P R E S S E L E M E N T	1	MANUFACTURER		United Electric			
	2	MODEL No.		J6 series - see page 2 for detail			
	3	TYPE		Stainless steel bellows & 1/4" NPTF pressure connection			
	4						
	5						
	6	TAG No.		see page 2			
	7	ACTUATION		Rising Line Pressure			
	8	SWITCH MOUNTING		1/4" NPT Female w separate isolation valve			
	9						
	10	CONNECTION	TYPE	SIZE	NPTF 1/4" Female		
	11	OVER-RANGE PROTECT		see page 2			
	12	VACUUM PROTECTION					
	13	DIAPHRAGM		316L Welded Stainless Steel Bellows			
	14	SNUBBER					
	15						
	16						
	17						
	18						
	19						
	S W I T C H	20					
21							
22		TYPE		Mechanical			
23		CONTACTS	QTY	FORM	1off SPDT		
24		ACTION (Proc)	INCR	DECR	Open on Increasing Pressure		
25		RATING		120VAC, 60Hz, 15A			
26							
27		DIFFERENTIAL	FIXED	ADJ	Fixed		
28		ADJUSTMENT	INT	EXT	Internal		
29		SETPOINT		see page 2			
30		ENCLOSURE		NEMA 4X			
31		MANUAL RESET		No			
32		AREA CLASSIFICATION		see page 2			
33		APPROVALS REQUIRED		CSA			
34							
35							
N O T E S	36	TAGGING		Each flow switch to be c/w a SS tag number			
	37						
	38	ALTERNATES		Asco			
	39						
	40						
	41						
	42						

Page No. 2 of 2