



wclw5 kNoXs/z5

tt6v4f=4 \$^)

wclw5, kNK5

X0A 0H0

scMstz G*^&H (&(_5600

hv5g4f5 G*^&H (&(_0866

City of Iqaluit

Box 460

Iqaluit, Nunavut

X0A 0H0

Phone (867) 979-5600

Fax (867) 979-0866

Ville d'Iqaluit

C.P. 460

Iqaluit, Nunavut

X0A 0H0

Tél. (867) 979-5600

Télécop. (867) 979-0866

April 5, 2019

Richard Dwyer
Manager Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven NU X0B 1J0

Re: Crown-Indigenos Relations and Northern Affairs Canada Comments on the City of Iqaluit Version 2 of the Environmental Monitoring Program and Quality Assurance and Quality Control Plan for Water Licence No. 3AM-IQA1626 – CIRNAC comments dated March 29, 2019, received April 5, 2019.

Dear Mr. Dwyer,

In response to comments received from Crown-Indigenous Relations and Northern Affairs Canada (CIRNAC) dated March 29, 2019, regarding the City of Iqaluit's (City) submission of the second revision of the Environmental Monitoring Program and Quality Assurance and Quality Control (QA/QC) under Water Licence No. 3AM-IQA1626, the City provides the following responses to CIRNAC's comments.

1. Water Quality Analytical Parameters for Potable Water

The City understands that suitable analytical methods must be used in order to assess metals in potable water. As per *Appendix D: Laboratory Accreditation & Supporting Documentation*, testing for metals in potable water will be carried out as per the methods identified under the Laboratory's Scope of Accreditation and Drinking-Water Testing Licence.

2. Prevention of Cross-Contamination

The City confirms that equipment will be cleaned with Distilled Deionized Water (DDW) in order to prevent cross-contamination. The City's Environmental Monitoring Program and Quality Assurance / Quality Control Plan has been revised to Revision 3 to include this amendment.

If there are any questions or concerns, please contact me at (613) 710-0498 or Josip.Deronja@colliersprojectleaders.com.

Regards,

Josip Deronja
Acting Engineering Manager
City of Iqaluit
Box 460, Iqaluit, NU
X0A 0H0

***cc: Matthew Hamp, Director of Public Works and Engineering
Amy Elgersma, Chief Administrative Officer
Brian Springer, Superintendent Utilidor Water & Sewer***



Water Resources Division
Resource Management Directorate
Nunavut Regional Office
P.O. Box 100
Iqaluit, NU, X0A 0H0

Your file - Votre référence
3AM-IQA1626
Our file - Notre référence
CIDM#1245339

March 29, 2019

Manager of Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU, X0B 1J0
E-mail: licensing@nwb-oen.ca

Re: Crown-Indigenous Relations and Northern Affairs Canada Comments on the City of Iqaluit Version 2 of the Environmental Monitoring Program and Quality Assurance and Quality Control Plan for Water Licence No. 3AM-IQA1626 – Municipal Undertaking

Dear Mr. Dwyer,

Thank you for your March 20, 2019 invitation to comment on the second revision of the Environmental Monitoring Program and Quality Assurance and Quality Control (QA/QC) Plan, which includes the Monitoring Program, submitted by the City of Iqaluit under Water Licence No. 3AM-IQA1626. Revision 2 included more details of the QA/QC and monitoring programs, provided up to date accreditation documents, and added a revision control section.

CIRNAC examined the submission. Comments have been provided pursuant to CIRNAC's mandated responsibilities under the *Nunavut Waters and Nunavut Surface Rights Tribunal Act* and the *Department of Indian Affairs and Northern Development Act*.

1. Water Quality Analytical Parameters for Potable Water

References:

- City of Iqaluit, Environmental Monitoring Program and Quality Assurance/ Quality Control Plan, Revision 2, Section 4.3.2, March 2019.
- Federal-Provincial-Territorial Committee on Drinking Water, Canadian Drinking Water Guidelines, Health Canada, February 2017.
- Evans Analytical Group, ICP-OES and ICP-MS Detection Limit Guidance, 2007.

The City of Iqaluit states in Table 3 (page 7) that metals in potable water will be tested by the Inductively Coupled Plasma (ICP) method. For some metals, for example lead (0.01



mg/L) and mercury (0.001 mg/L), the Canadian Drinking Water Guidelines Maximum Acceptable Concentrations are so low that the ICP-AES (atomic emission spectrometry) method may not be appropriate; its analytical detection limit for most metals is about 0.05 mg/L (Evans Analytical Group, 2007). These metals should be analyzed by methods (e.g., ICP-Mass Spectrometry) that have the appropriate detection limits.

Recommendation:

CIRNAC recommends that appropriate analytical methods be selected for the analysis of metals in potable water.

2. Prevention of Cross-Contamination

References:

- City of Iqaluit, Environmental Monitoring Program and Quality Assurance/ Quality Control Plan, Revision 2, Section 4.3.3, March 2019.

The City of Iqaluit states (page 7) "Sampling equipment such as sampling poles are cleaned with soap and water after each sample is collected to prevent cross-contamination." CIRNAC reminds the City of Iqaluit that Distilled Deionized Water (DDW) should be used rather than tap water.

Recommendation:

CIRNAC recommends using DDW to clean equipment and prevent cross-contamination and suggests the City make this distinction in the Environmental Monitoring Program and Quality Assurance/ Quality Control Plan, Revision 2.

If there are any questions or concerns, please contact me at (867) 975-4282 or bridget.campbell@canada.ca or David Zhong at (867) 975-4555 or david.zhong@canada.ca.

Sincerely,

Bridget Campbell,
Water Resource Coordinator