



Water Resources Division
Nunavut Regional Office
Iqaluit, NU X0A 0H0

Your file - Votre référence
3AM-PAN----

September 1, 2017

Our file - Notre référence
CIDM#1172282

Richard Dwyer
Licensing Administrator
Nunavut Water Board
Gjoa Haven, NU X0E 1J0

**Re: Indigenous and Northern Affairs Canada's comments on responses
submitted for the Hamlet of Pangnirtung's Type "A" Water Licence
Application – #3AM-PAN---- – Municipal Undertaking**

Dear Mr. Dwyer,

Thank-you for the email notice received on August 22, 2017 informing us of the Government of Nunavut - Community and Government Services (GN-CGS)'s responses regarding the above mentioned application were available for review. We appreciate the opportunity to reply whether the responses are satisfactory.

Indigenous and Northern Affairs Canada has looked over the responses and new documents submitted by GN-CGS. They specifically respond to our technical comments from July 28, 2015, and though several of the responses are satisfactory, others will need to be further discussed at the technical meeting. The following table lists technical comments from our July 28 submission for which we feel the information provided is incomplete and should be added to before a meeting.

Technical comment	Outstanding information
1.4 Surface water management around reservoir	The pictures of the berm repair referred to in the reply were not found.
2.2 Sewage lagoon	The sewage lagoon is indicated on the aerial photo provided, but the sewage treatment wetland is not. We would like to know the location and characteristics of the sewage treatment wetland.
3.2 Surface water management at metal dump	The water management plan provided is a powerpoint sketch, which does not give us sufficient confidence of its adequacy.
4.1 Station PAN-01 raw water supply intake	The 2016 log sheets referred to in the reply were not found. The only log sheet found was a blank one.

We look forward to the technical meeting to further discuss Pangnirtung's water licence renewal application. Please do not hesitate to contact Lisa Bachellier at 867-975-4738 or lisa.bachellier@aandc-aadnc.gc.ca or myself at 867-975-3876 or sarah.forte@aandc-aadnc.gc.ca for any additional information.

Regards,

Sarah Forté
Water Management Coordinator