

Hamlet of Pangnirtung Summary 3AM-PAN----

Nunavut Water Board Technical Meeting and Prehearing Teleconference
December 5-6, 2017

Contributions to the application review

INAC made the following submissions to the Nunavut Water Board:

1. June 7, 2017- Completeness Assessment with information requests and recommendations
2. July 28, 2017- Technical review with recommendations
3. September 1, 2017- Comments on the applicant's response to INAC's technical review

INAC's outstanding issues from the technical review regarding the water supply are: the pumping capacity and the adequacy of the Duval River as a source during the low flow months.

For wastewater treatment we are looking for clarifications on: the revised version of plant bypass contingency plan, the sewage lagoon location and characteristics of the sewage treatment wetland.

On the topic of waste, INAC requested an updated version of the surface water management plan, a revised version of the operation and maintenance manual for the runoff/leachate from landfill and metal wastes sites.

The department also made general comments on: flow metre installation for the water supply intake, geographical coordinates for the wastewater treatment sampling sites, and revisions to the spill contingency plan.

INAC appreciates efforts made to date to provide information and is looking for clarifications during the technical meeting to help move the water licence renewal application to the next step.