



P.O. Box 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪᓴ ᐃᓕᓕᓂᓪᓴ ᑲᑎᓚᓪᓴᓯ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI

File No: NWB3PAN0207

Via Fax (867) 473-8832

August 4, 2004

Mr. Greg Morash
Senior Administrative Officer
Hamlet of Pangnirtung
P.O. Box 253
Pangnirtung, NU X0A 0R0

Subject: Annual Report Requirement NWB3PAN0207

Dear Mr. Morash:

The Nunavut Water Board (NWB) has reviewed the "Annual Report for the Hamlet of Pangnirtung (2003)" documents submitted to the Board on April 29, 2004 in accordance with Part B, Item 1 of your water licence. The NWB herein approves the 2003/04 Annual Report as presented and thanks the Hamlet of Pangnirtung for their submission.

It was noted in the review of the Annual Report submitted that the Hamlet does not currently have a Monitoring Plan in place for their solid waste and wastewater management facilities. The NWB reminds the Licensee that, in accordance with Part H, Item 2 of water license NWB3PAN0207, the Hamlet of Pangnirtung is required to sample monthly at Monitoring Stations PAN-2 and PAN-4 during the months of May to August, inclusive. The Hamlet, as is noted in the aforementioned water license, is also required to sample monthly at Monitoring Station PAN-3. The NWB, however, is aware of the challenges associated with developing, and implementing, such a sampling program. Accordingly, staff of the NWB will be contacting you within the next several weeks, to determine if we can assist you in developing, and implementing a Monitoring Plan, as is required by your water license.

Please contact the undersigned at (867) 360-6338 or e-mail Jim Wall (Technical Advisor, Municipal) at tech1@nwb.nunavut.ca if you have any questions.

Sincerely,

Original Signed By:

Philippe di Pizzo
Executive Director