



March 7, 2002

FSC Project Number: 2001-7140

sent by fax: (867) 360-6369

Dionne Filiatraut
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU
X0E 1J0

Re: Application for Modification - Supporting Documentation

Water Licence N5L4-1447

Dear Dionne,

On behalf of our client, this application for a modification to Water Licence N5L4-1447 is made under Part D: Conditions Applying to Modifications.

This application is to address the construction of a new sewage treatment plant (STP) in Pangnirtung, NU.

FSC was contracted to design the building that houses the new system as well as the outfall. Drawings of the building are included that show the location of the STP. The outfall design has not been completed at present, but it is known the effluent will be discharged onto the beach above the high tide line.

BCA is responsible for the design of the sewage treatment system itself. A description of this is also included as well as a process flow diagram. The effluent characteristics can also be found within this document.

Please contact me if you need any further information.

Yours truly,
Ferguson Simek Clark

A handwritten signature in black ink, appearing to be 'Ron Kent', written over a horizontal line.

Ron Kent, P.Eng.
Head, Environment Department

gt
mar 15
mon 18

01/31/2002 THU 11:59 FAX 604 39 9309 BCA INDUSTRIAL CONTROLS

001/005



The Clearwater Group™

Head Office:
100 20329 Logan Avenue,
Langley, BC, Canada V3A 4L8
Tel. (604) 539-9399
Fax (604) 539-9309
E-MAIL: bca@clearwaterworld.com

Calgary Office:
PO Box 56052 Airways,
Calgary, AB, Canada T2E 8K5
Tel. (403) 280-0004
Fax (403) 280-7711

US Office:
Pacific Keystone Technologies Incorporated
PO Box 360, Black Diamond, WA. 98010-0491
Tel. (360) 886-1396
Fax (360) 886-2480
E-MAIL: keystone@clearwaterworld.com

WEBSITE: www.clearwaterworld.com

FAX

DATE: 31 January 2002

TIME:

FROM: Gerald Stang
BCA IndustrialPHONE: (604) 539-9399
FAX: (604) 539-9309

COPIES:

TO: Ron Kent
Ferguson Simek ClarkPHONE: (867) 920-2882
FAX: (867) 920-4319

Number of copies including this cover page: 5

Mr. Kent,

I am assisting Rick Johnson with some work on the Pangnirtung treatment plant. Please find attached a description of the process and a flow sheet outlining the same.

If you have any questions or need more information, please feel free to call or email me at gstang@clearwaterworld.com. Thanks,

Regards,

Gerald Stang

Water...
we treat it right

• WATER & WASTEWATER TREATMENT SYSTEMS •
• VALVES, METERS, CONTROLS, PUMPS, SYSTEMS •
• CLA-VAL • APCO • FERCO • LEOPOLD • WATER SPECIALTIES • DEZURIK • CORNELL • NUSONICS •

01/31/2002 THU 11:59 FAX 60' 39 9309 BCA INDUSTRIAL CONTROLS

002/001

Pangnirtung Design Criteria

The attached process flow diagram outlines the process as discussed below. The Pangnirtung plant will deal with an Average Daily Flow (ADF) of 75,000 USGPD.

Influent

BOD₅ = 500 mg/l

TSS = 350 mg/l

Effluent

BOD₅ = 100 mg/l

TSS = 120 mg/l

The influent is dropped off into a truck dump and immediately pumped through a screen into a screened sewage tank. The screened sewage is pumped into an aerated equalization tank where it is continually mixed. The screenings are compacted for disposal.

The equalization tank will be 25.18-ft diameter x 13.75-ft shell ht. With 500-mm freeboard, this is 45,100 USG. The total ADF of 75000 USGPD will be dropped off by trucks during an 8-hour day. During the day, the first 30,000 gallons will be treated. By the end of the day, the equalization tank will be near full (45,000 USG) and this will be treated over the next 12 hours. This provides an average flow to the GEO-FORM reactors of 3750 GPH over 20 hours. This gives 4 hours to ensure the flow equalization/pre-treatment tanks are empty before the next day's deliveries. The tank will be continually mixed at 140 scfm.

The well-mixed fluid is pumped out of the equalization tanks at a steady rate to the GEO-FORM reactors. We will treat the fluid with two separate treatment modules, each consisting of three, 5-ft GEO-FORMs and a two-hopper final clarifier. Each GEO-FORM module will be 13' H x 9' W x 18' L when assembled. The GEO-FORM reactors are rotating biological contactors that degrade the waste through bacterial action. The effluent from each reactor flows to a final

01/31/2002 THU 11:59 FAX 60' 539 9309 BCA INDUSTRIAL CONTROLS

003/001


clarifying tank where the solids settle out, leaving the clean effluent ready for discharge. The settled sludge is pumped to a sludge digester tank.

The sludge digester is 16.78-ft diameter x 13.75-ft shell height. With 500-mm freeboard, this is 20,000 USG. The digester is aerated at 80scfm by a 5 hp blower to ensure good degradation of the sludge. The air is periodically turned off, allowing the solids to settle and the supernatant to be drained back to the screened sewage area.

The dewatered sludge will be bagged in an automatic sludge bagger for later disposal.

01/31/2002 THU 12:00 FAX 604 539 9309 BCA INDUSTRIAL CONTROLS

004/001




A	---	---	---	---	YR/MO/DA
REV	DESCRIPTION	BY	CHK'D	APP'D	DATE

NOTE

THIS DRAWING IS THE PROPERTY OF BC GROUP, AND CONTAINS PROPRIETARY INFORMATION WHICH MUST NOT BE DUPLICATED OR DISCLOSED OTHER THAN EXPRESSLY BY THE CLEARWATER GROUP.

01/31/2002 THU 12:00 FAX 604 539 9309 BCA INDUSTRIAL CONTROLS

005/00



THE CLEARWATER
CONFIDENTIAL
TED, USED OR
RIZED BY BCA



The Clearwater Group™

DRAWN	JO
DESIGN	RJ
CHECKED	RJ
APPROVED	-
DATE	DEC. 17, 01
SCALE	N.T.S.

PANGNITUNG

BCA WASTE WATER TREATMENT PLANT
PROCESS FLOW DIAGRAM
(SO #6535)

DRAWING NO. 017271-02

REV -

FSC

DATE: MARCH 7, 2002


SCALE: 1"=0.000

FILE: sfed02.dwg

OVERALL SITE**PANGNIPTUNG SEWAGE TREATMENT PLANT**

FOUR NO.

1-1



FSC

DATE: MARCH 7, 2002

SCALE: 1/500

FILE: etdDelidwg

PROPOSED SITE**PANGNIPTUNG SEWAGE TREATMENT PLANT**

FIGURE NO.

1-2