



---	EXISTING WATERMAIN
---	EXISTING SEWER MAIN
●	ACCESS VAULT
—X—	VALVE
NC	NORMALLY CLOSED
NO	NORMALLY OPEN
(HYD)	HYDRANT AT ACCESS VAULT
WM	WATER MAIN
SAN	SEWER MAIN

- NOTES:
1. ALL WATER MAINS ARE 200mm DIAMETER EXCEPT AS MARKED.
 2. ALL SEWER MAINS ARE 150mm DIAMETER EXCEPT AS MARKED.
 3. STAGE 1A MAINS ARE CELLANESE "CELEX" PE PIPE (CESSCO). WATER MAINS ARE SERIES 125 AND SEWER MAINS ARE SERIES 45.
 4. STAGE 1B MAINS ARE DUPONT "SCLAIRCORE". WATER MAINS ARE SERIES 125 AND SEWER MAINS ARE SERIES 45.
 5. ALL VALVES ARE LOCATED IN ACCESS VAULTS. VALVES ARE SHOWN OUTSIDE ACCESS VAULTS FOR CLARITY.

SCALE: ±1 : 2500

RESOLUTE BAY
WATER AND SEWER
EXISTING
PIPING PLAN

Fig. 3-2

TO COMMUNOTOR AND
200mm SAN OUTFALL