



TYPICAL JOINT ON WATER AND SEWER SERVICE PIPES

N.T.S.

KEY TO NUMBERED PARTS:

- (11) WATER SERVICE CARRIER PIPE 100mm DIA. HDPE IPS DR 13.5 (860 kPa) WITH 50mm NOMINAL POLYURETHANE INSULATION AND FACTORY INSTALLED JACKET.
- (13) POLYURETHANE HALF SHELL CUT TO LENGTH AND COATED WITH ASPHALT MASTIC.
- (40) FIELD COAT ALL POLYURETHANE WITH MASTIC.
- (41) BUTT FUSION JOINT TO BE MADE BY A QUALIFIED AND LICENSED TECHNICIAN.
- (42) SHOP CAST 50mm THICK POLYURETHANE INSULATION WITH BLACK JACKET PROTECTIVE COATING.
- (43) HEAT SHRINK SLEEVE MIN. 100mm LAP ON BLACK JACKET AFTER SHRINKAGE.

RESOLUTE BAY
NUNAVUT

UTILIDOR REPAIRS
RESOLUTE BAY NUNAVUT



**A. D. Williams
Engineering Inc.**
Consulting Engineers

#4903-47 Street
P.O. Box 1529
Yellowknife, NT X1A 2P2
(867) 873-2395
(867) 873-2547

Edmonton Office
(780) 424-2393
(780) 425-1520
ADWE NO.:

DESIGN BY: DFG

DRAWN BY: DFG

APPROVED BY: BFG

DATE: 03.07.29

SCALE: N.T.S.

DWG NO:

SK3

REV NO:

A