



Fwd: FW: 19WN050 Correspondence and Information Request

Richard Dwyer <richard.dwyer@nwb-oen.ca>

Wed, Feb 19, 2020 at 4:14 PM

Draft To: Sergey Kuflevskiy <sergey.kuflevskiy@nwb-oen.ca>

----- Forwarded message -----

From: **Emily Koide** <ekoide@nirb.ca>

Date: Wed, Feb 19, 2020 at 3:43 PM

Subject: FW: 19WN050 Correspondence and Information Request

To: Sergey Kuflevskiy <sergey.kuflevskiy@nwb-oen.ca>

Hi Sergey,

I apologize if you did not receive the Information Request sent to Bhabesh Roy on February 3, 2020. We have been having some trouble with cc'ing on our online system but I have attached the sent document in this email.

While I have you, can you please confirm whether the activities described in Bhabesh's below email were all licenced under type B water licences?

The initial Licence has the following Components;

1. Pump station at Char Lake
2. Intake from Char lake to Signal Hill water Plant
3. Water treatment Plant at signal Hill
4. Utilidor system- water line and sewer line
5. Macirator system.
6. Proposed new wastewater treatment Plant

During Amendment :

1. New Pump station at Signal Hill: Construction stage
2. Upgrade of existing water treatment plant: Construction stage
3. Upgrade of intake line: construction is complete
4. Upgrade of Utilidor system-Water line and sewer line: Construction is complete
5. Existing Macirator unit: As it is
6. Proposed new wastewater treatment Plant- design stage

As we only need to screen activities that would be occurring under the Type A water licence is there any activities that are in the NWB application that are new for this water licence?

I will start including cc'ing you on my correspondence with Bhabesh so we can both have all the information for the coordinated process. Also, I did receive verbal confirmation that he would like the coordinated process if possible.

Thanks!

Emily Koide

Technical Advisor I

Nunavut Impact Review Board

P.O. Box 1360, Cambridge Bay, NU X0B 0C0

direct: 1-867-983-4612

toll free: 1-866-233-3033

fax: 1-867-983-2594

web: www.nirb.ca

From: Roy, Bhabesh <BRoy@gov.nu.ca>
Sent: Wednesday, February 19, 2020 2:14 PM
To: Emily Koide <ekoide@nirb.ca>
Cc: Roy, Bhabesh <BRoy@gov.nu.ca>
Subject: FW: 19WN050 Further information required

Emily

I was on leave. Yes, I received and read it. In the current NWB application, we will be submitting additional information for the new Wastewater treatment plant which are not available yet so no amendment is required in future as advised by the Board in page viii of the WL #3BM-RUT 1520.

Hope this helps.

Thanks.

Bhabesh

From: Emily Koide <ekoide@nirb.ca>
Sent: February 19, 2020 2:14 PM
To: Roy, Bhabesh <BRoy@gov.nu.ca>
Subject: RE: 19WN050 Further information required

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Hello Bhabesh,

Thank you for your response. Can I please clarify that all the new infrastructure and upgrades to existing infrastructure were approved under the Type B water licence and the Type A water licence is only for approval to extract more than 300 cubic meters per day or store over 60,000 cubic meters annually.

As well, as we are having some technical issues can you please confirm whether you received a copy of the Information Request #2 sent by the NIRB on February 3rd, 2020 (attached).

Thank you for your clarifications,

Emily Koide

Technical Advisor I

Nunavut Impact Review Board

P.O. Box 1360, Cambridge Bay, NU X0B 0C0

direct: 1-867-983-4612

toll free: 1-866-233-3033

fax: 1-867-983-2594

web: www.nirb.ca

From: Roy, Bhabesh <BRoy@gov.nu.ca>
Sent: Wednesday, February 19, 2020 11:08 AM
To: Emily Koide <ekoide@nirb.ca>
Cc: Karén Kharatyan <karen.kharatyan@nwb-oen.ca>; Roy, Bhabesh <BRoy@gov.nu.ca>
Subject: RE: 19WN050 Further information required

Emily: Licence type is still Type B.

Thanks

Bhabesh

From: Roy, Bhabesh <BRoy@gov.nu.ca>
Sent: February 19, 2020 1:06 PM
To: Emily Koide <ekoide@nirb.ca>
Cc: Roy, Bhabesh <BRoy@gov.nu.ca>; Karén Kharatyan <karen.kharatyan@nwb-oen.ca>
Subject: RE: 19WN050 Further information required

Emily

The initial Licence has the following Components;

1. Pump station at Char Lake
2. Intake from Char lake to Signal Hill water Plant
3. Water treatment Plant at signal Hill
4. Utilidor system- water line and sewer line

5. Macirator system.
6. Proposed new wastewater treatment Plant

Licence type was type B.

During Amendment :

1. New Pump station at Signal Hill: Construction stage
2. Upgrade of existing water treatment plant: Construction stage
3. Upgrade of intake line: construction is complete
4. Upgrade of Utilidor system-Water line and sewer line: Construction is complete
5. Existing Macirator unit: As it is
6. Proposed new wastewater treatment Plant- design stage

This is also type B and existing now.

Water Board 's new regulations;

If water extraction volume is more than 300 cubic meters per day or storage volume is 60,000 cubic meters annually, the water licence will be considered as Type A.

Today, we need to satisfy this criteria and changing the Type B to Type A.

These have nothing to do with the number of infrastructure.

So I do not know why you want to send the application back.

Please visit your NIRB file of screening this project may be 2 yrs. Ago.

If you have any question, please call me or talk to Karen of Water Board for more clarification.

Hope this helps.

Thanks.

Bhabesh Roy, P.Eng.