

C.O.C.: ---

REPORT No. B18-17938

Report To:

ATCO Structure & Logistics Services Ltd

PO Box 88, Hamlet of Resolute Bay

NU X0A 0V0 Canada

Attention: Philip Chubbs

Caduceon Environmental Laboratories

2378 Holly Lane

Ottawa Ontario K1V 7P1

Tel: 613-526-0123

Fax: 613-526-1244

DATE RECEIVED: 22-Jun-18

JOB/PROJECT NO.: Resolute Bay, NU

DATE REPORTED: 28-Jun-18

P.O. NUMBER:

SAMPLE MATRIX: Drinking Water

WATERWORKS NO.

			Client I.D.	Char Lake	AV-10		
			Sample I.D.	B18-17938-1	B18-17938-2		
			Date Collected	19-Jun-18	19-Jun-18		
Parameter	Units	R.L.	Reference Method	Date/Site Analyzed			
Total Coliform	cfu/100mL	1	MOE E3407	22-Jun-18/O	0	0	
E coli	cfu/100mL	1	MOE E3407	22-Jun-18/O	0	0	
Benzene	µg/L	0.5	EPA 8260	23-Jun-18/O	< 0.5	< 0.5	
Toluene	µg/L	0.5	EPA 8260	23-Jun-18/O	< 0.5	< 0.5	
Ethylbenzene	µg/L	0.5	EPA 8260	23-Jun-18/O	< 0.5	< 0.5	
Xylene, m,p-	µg/L	0.4	EPA 8260	23-Jun-18/O	< 0.4	< 0.4	
Xylene, o-	µg/L	0.1	EPA 8260	23-Jun-18/O	< 0.1	< 0.1	
Xylene, m,p,o-	µg/L	0.4	EPA 8260	23-Jun-18/O	< 0.4	< 0.4	
Toluene-d8 (SS)	%		EPA 8260	23-Jun-18/O	103	102	
PHC F1 (C6-C10)	µg/L	20	MOE E3421	23-Jun-18/O	< 20	< 20	
PHC F2 (>C10-C16)	µg/L	50	MOE E3421	26-Jun-18/K	< 50	< 50	
PHC F3 (>C16-C34)	µg/L	400	MOE E3421	26-Jun-18/K	< 400	< 400	
PHC F4 (>C34-C50)	µg/L	400	MOE E3421	26-Jun-18/K	< 400	< 400	

NOTE: Bacteria parameters passed acceptable holding times upon arrival at Lab.



R.L. = Reporting Limit

Test methods may be modified from specified reference method unless indicated by an *

Site Analyzed=K-Kingston,W-Windsor,O-Ottawa,R-Richmond Hill,B-Barrie

Greg Clarkin, BSc., C. Chem
Lab Manager - Ottawa District

The analytical results reported herein refer to the samples as received. Reproduction of this analytical report in full or in part is prohibited without prior consent from Caduceon Environmental Laboratories.