



P.O. Box 119  
GJOA HAVEN, NU X0B 1J0  
TEL: (867) 360-6338  
FAX: (867) 360-6369

ᓄᓇᓂᓐ ᐃᓕᓕᓂᓐ ᑲᑎᓕᓐ  
NUNAVUT WATER BOARD  
NUNAVUT IMALIRIYIN KATIMAYIT  
OFFICE DES EAUX DU NUNAVUT

File No.: 3BC-ALT1015/TR/B1

July 14, 2011

Andrew Tam, M.Sc., Ph.D. (Candidate)  
Assistant Environment Officer  
8 Wing Environmental Management  
Room 305, 74 Polaris Avenue Box 1000, Stn Forces  
Department of National Defence  
Astra, ON K0K 3W0

E-mail : [andrew.tam@forces.gc.ca](mailto:andrew.tam@forces.gc.ca)

**Subject: Licence No. 3BC-ALT1015 “CFS-Alert” Ellesmere Island, Qikiqtani Region,  
Nunavut; Submission of 2010 Annual Report**

Dear Mr. Tam;

The Nunavut Water Board (“NWB” or “Board”) has completed a technical review of 2010 Annual Report for the above mentioned project, which was submitted on March 29, 2011. The Report and attached submissions were distributed for information.

The annual report is found to be complete and meeting the reporting requirements of licence 3BC-ALT1015.

Site’s Monitoring Program results indicate that during 2010 monitoring event, the Total Suspended Solids (TSS) exceeded the maximum allowed concentration at monitoring station ALT-3 Sewage Terrace Final Discharge Point, which was explained by the construction activities of the Sewage Terrace System. The NWB notes that the explanation of this exceedance should be confirmed by 2011 monitoring results.

Should you have any questions, please feel free to contact the undersigned at (867) 360-6338 Ext. 30 or [k.kharatyan@nunavutwaterboard.org](mailto:k.kharatyan@nunavutwaterboard.org), at your earliest convenience.

Yours truly,

Karén Kharatyan  
Technical Advisor

cc: Distribution List – Qikiqtani