



ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓂᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File No.: 3BC-ALT1015/TR/B1

May 2, 2013

Andrew Tam, MSc., Ph.D. (Candidate)
Assistant Environment Officer
8 Wing Environmental Management
8 Wing/Canadian Forces Base Trenton
Room 305, 74 Polaris Avenue Box 1000, Stn Forces
Department of National Defence
Astra, ON K0K 3W0
Email: andrew.tam@forces.gc.ca

**Subject: Licence No. 3BC-ALT1015 “CFS-Alert” Ellesmere Island, Qikiqtani Region,
Nunavut;
Submission of 2012 Annual Report**

Dear Mr. Tam;

The Nunavut Water Board (“NWB” or “Board”) has completed a technical review of 2012 Annual Report for the above mentioned project, which was submitted on February 28, 2013. The Report and attached submissions were distributed for information.

The annual report is found to be complete and meeting the reporting requirements of licence 3BC-ALT1015. In addition, the NWB appreciates the inclusion of the 2012 CFS Alert Constructed Wetland Assessment Report, and photographs to help aid in the understanding of the activities that have taken place.

The NWB notices that BOD₅, Total Suspended Solids (TSS) and Oil Grease are reported to exceed the maximum allowable concentrations at ALT-3 Monitoring Station. The Licensee is advised to continue thoroughly assessing the performance of Sewage Terrace System (terrace wetland).

Should you have any questions, please feel free to contact the undersigned at (867) 360-6338 Ext. 30 or k.kharatyan@nunavutwaterboard.org, at your earliest convenience.

Yours truly,

Original Signed By:

Karén Kharatyan
Technical Advisor

cc: Distribution List – Qikiqtani