

Richard Dwyer

From: Roberts, Jeremy [JRoberts@GOV.NU.CA]
Sent: Monday, May 14, 2007 3:29 PM
To: Richard Dwyer
Subject: RE: SII Project 3BC-SII New Application
Follow Up Flag: Follow up
Flag Status: Purple

Good afternoon,

1. The application says sewage (blackwater and greywater) will be buried. It should be added that the pits be at least 30m from any body of water.
2. The application says the drinking water will not be treated. This could cause illness. They can use bottled water or filter and treat surface water.

Jeremy Roberts, C.P.H.I.(C)
 Environmental Health Officer
 P.O. Box 390, Igalak Building
 Kugluktuk, NU, X0B 0E0
 Phone: (867) 982-7610
 Fax: (867) 982-7640
 E-mail: jroberts@gov.nu.ca

From: Richard Dwyer [mailto:licensingtrainee@nunavutwaterboard.org]
Sent: April 27, 2007 11:26 AM
To: jchakung@nrcan.gc.ca
Cc: Dawe, John; Purdy, Bryan; 'CGS-Todd Parsons'; 'Chesterfield Inlet HTO'; cleypermits; 'DFO-Iqaluit Paul Savoie'; 'DFO-Iqaluit Tania Gordanier'; 'DIAND Leslie Harris'; 'DIAND-Andrew Keim'; 'DIAND-Iqaluit Colette Spagnuolo'; 'DIAND-Iqaluit David Abernethy'; 'DIAND-Iqaluit Ian Rumbolt'; 'DIAND-Iqaluit Jim Rogers'; 'DIAND-Iqaluit Peter Kusugak'; 'DIAND-Iqaluit Steve Bathory'; 'DIAND-Nunavut Spencer Dewar'; 'EC-Iqaluit Cindy Parker'; 'EC-Ivy Stone'; 'EC-YK Mike Fournier'; 'EC-YK Myra Robertson'; Baddaloo, Earle; Yeh, Helen; Gladstone, Josh; Atkinson, Mike; Mifflin, Mike; Eno, Robert; 'HC Angela Li-Muller'; 'HC Heather Jones-Otazo'; 'JUSTICE CANADA'; Roberts, Jeremy; 'KIV-IA JTulugak'; 'KIV-IA Melodie Sammurtok'; 'KIV-IA MSerra'; 'KIV-IA Stephen Hartman'; 'KIV-IA VTattuinee'; 'KIV-IA, Lands Luis Manzo'; 'NIRB-Leslie Payette'; 'NPC Brian Aglukark'; 'NPC Bobby Suluk'; 'NPC Central'; 'NPC Jayko Alooooloo'; 'NTI Carson Gillis'; 'NTI George Hakongak'; 'NTI Jeannie Ehloak'; 'NTI Keith Morrison'; 'NWB Joe Murdock'; 'NWB Zhong Liu'; 'NWMB Erin Calder'; 'PC Jane Chisholm'; 'PC-Paula K. Hughson'; 'TC-John Cowan'
Subject: SII Project 3BC-SII New Application

Good morning;

Canada Nunavut Geoscience Office have submitted an application for review and comment; deadline for comment May 27, 2007.

Regards,

Richard Dwyer
 Licensing Trainee
 Nunavut Water Board
 P.O. Box 119

5/15/2007

Gjoa Haven, NU X0B 1J0
Ph (867)360-6338 ext. 29
Fax (867)360-6369

Please visit our website www.nunavutwaterboard.org