

From: [Andrew Keim](#)
To: [Joeli Qamanirq](#)
Cc: [Bhabesh](#) "Roy"; [Bernie MacIsaac](#); [Phyllis Beaulieu](#)
Subject: Re: FW: Spill Report
Date: Thursday, March 26, 2009 11:42:22 AM

Mr. Qamanirq,

To be clear,

Your main lagoon is at capacity and your secondary Lagoon is nearing capacity... Is this accurate?..

If this is the case then it is my advice that you should decant your lagoon as soon as possible to avoid a breach.

Sampling is required at the beginning, mid point and end of the decant process.

Bhabesh Roy with the GN should be your your main contact for any technical assistance you require.

If there are any questions of a regulatory nature or if you have any questions about the process please do not hesitate to contact our offices here in Iqaluit.

Andrew Keim
Water Resources Officer
INAC Nunavut Regional Office
P.O. Box 2200
Iqaluit, Nunavut X0A 0H0
*NEW Email: * Andrew.Keim@inac-ainc.gc.ca
Phone: (867) 975-4289
Fax: (867) 979-6445

>>> "Joeli Qamanirq" <sao_ab@qiniq.com> 3/26/2009 1:34 PM >>>
I just ask Bhabesh Roy and he referred by question to you and it is about our secondary sewage lagoon is almost full and the other sewage lagoon is already full and we're not dumping raw sewage to the full lagoon, my Foreman Sam Willie has asked if he should do spill report each time we dump raw sewage or is there a procedure we should do.

Joeli Qamanirq
Senior Administration Officer
Hamlet of Arctic Bay
Box 150
Arctic Bay NU X0A0A0
Telephone: 867.439.9917
Fax: 867.439.8767
Private Telephone: 867.439.8104(Has VM)
Private Fax: 867.439.8280
email: sao_ab@qiniq.com

From: Roy, Bhabesh [<mailto:RBhabesh@GOV.NU.CA>]

Sent: March 26, 2009 1:12 PM

To: Joeli Qamanirq

Cc: Fuentes, Patricio; Palluq, Johnathan; Toonoo, Timoon; Scott, Grant

Subject: RE: Spill Report

Joeli,

You need to follow some procedure as Clyde River is doing. INAC needs to be informed. They will give you a guideline for sampling and testing. Andrew Keim is the contact person of INAC.

Thanks.

Bhabesh

Bhabesh Roy, M.A.Sc., P.Eng.

Municipal Planning Engineer

Community Government Services

Baffin Region, Government of Nunavut

P.O.Box 379, Pond Inlet, X0A 0S0

Ph-867 899 7314

Fax-867 899 7328

E-mail: broy@gov.nu.ca

From: Joeli Qamanirq [mailto:sao_ab@qiniq.com]

Sent: Thursday, March 26, 2009 1:22 PM

To: Roy, Bhabesh

Subject: Spill Report

Sam Willie wanted me to ask you that if he should be doing spill reports once the secondary lagoon is overflowing?

Joeli Qamanirq

Senior Administration Officer

Hamlet of Arctic Bay

Box 150

Arctic Bay NU X0A0A0

Telephone: 867.439.9917

Fax: 867.439.8767

Private Telephone: 867.439.8104(Has VM)

Private Fax: 867.439.8280

email: sao_ab@qiniq.com